

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.30	13.99	55.02	0.69	19.78	11.41	0.97	77239.63
1	4.41	11.97	63.98	0.54	21.34	11.04	0.97	78908.29
2	5.79	12.24	50.99	0.94	19.68	11.11	0.97	79760.26
3	5.92	13.72	51.82	1.46	17.39	12.02	0.97	74742.62
4	8.09	11.79	48.73	3.00	16.18	11.87	0.98	72943.35
5	11.18	11.27	49.14	2.53	16.59	11.64	0.98	70774.61
6	11.98	10.23	48.81	2.92	15.86	11.82	0.96	74436.50
7	7.35	10.13	50.48	2.05	17.09	11.88	0.97	75533.37
8	9.45	8.28	54.22	1.27	18.39	11.30	0.99	78867.90
9	9.35	8.73	46.28	2.02	16.37	11.72	0.99	74492.22
10	7.81	7.91	60.10	1.66	18.01	11.38	0.98	77381.48
11	9.47	14.46	55.14	2.45	15.50	12.00	0.99	73103.31
12	4.50	9.66	42.79	2.68	15.56	11.70	0.99	74392.28
13	10.28	10.59	47.83	3.30	15.08	11.27	0.99	75720.49
14	7.81	7.40	49.75	2.91	16.25	11.66	0.99	71956.04
15	10.21	8.35	65.11	1.64	17.58	11.42	1.00	76996.87
16	9.11	9.89	56.54	1.70	17.84	11.88	1.01	75276.39
17	9.60	8.21	64.47	1.64	17.27	11.72	1.02	77369.20
18	9.10	8.45	62.60	1.69	16.48	12.09	0.99	75038.23
19	5.95	9.46	48.68	1.30	17.42	12.00	0.99	75191.77
20	5.62	10.06	59.54	1.53	17.95	11.76	0.99	76942.93
21	7.26	9.76	51.11	1.81	17.08	11.81	0.99	77047.19
22	8.28	12.89	54.55	2.56	15.90	11.93	0.99	77140.41
23	8.34	10.08	60.16	1.67	17.25	11.70	0.99	77744.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.92	10.40	54.08	1.92	17.24	11.67	0.99	75791.65
最大值	11.98	14.46	65.11	3.30	21.34	12.09	1.02	79760.26
發生時間	6	11	15	13	1	18		2
最小值	3.30	7.40	42.79	0.54	15.08	11.04	0.95	70774.61
發生時間	0	14	12	1	13	1		5
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.01 %		-0.04		0.00 %
全幅偏移(率)	0.01 %	-0.44 %	-0.59 %	-0.04 %		-0.07		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.21	6.43	50.95	1.27	19.03	10.11	1.01	85377.52
1	3.55	6.33	59.76	1.14	20.34	10.07	1.02	85339.19
2	3.73	7.30	43.46	1.41	19.29	9.99	1.02	86824.10
3	4.81	9.14	40.95	1.17	20.50	9.49	1.02	88768.62
4	4.60	7.71	39.13	1.53	18.89	9.78	1.02	87429.62
5	3.49	5.56	43.60	1.59	18.30	10.30	1.02	83080.62
6	4.90	7.79	40.25	2.50	17.30	10.05	1.02	85858.33
7	4.15	6.98	48.58	1.83	18.32	10.63	1.03	80551.23
8	10.04	5.96	46.78	2.69	18.93	10.67	1.01	85239.41
9	8.62	4.54	51.87	4.34	17.49	10.75	1.02	85902.83
10	10.02	11.60	58.33	5.56	16.21	11.19	1.00	82470.71
11	6.41	4.76	49.93	2.27	16.41	10.29	1.03	81955.23
12	5.21	5.55	49.98	2.48	15.42	10.66	1.02	80292.31
13	11.08	7.74	62.63	3.68	14.52	10.84	1.02	83579.14
14	4.04	3.45	60.61	1.81	15.96	10.54	1.02	82352.08
15	0.42	7.61	61.31	1.48	17.21	10.79	1.02	78114.40
16	2.79	13.85	57.60	1.48	17.66	10.40	1.02	85061.09
17	8.74	6.42	55.85	2.14	17.22	10.39	1.02	85733.93
18	7.10	3.15	55.24	2.23	17.05	10.43	1.03	85779.08
19	9.21	7.33	49.73	2.51	17.19	10.36	1.01	86140.35
20	7.55	4.87	57.92	1.98	17.38	10.49	1.02	84714.94
21	9.59	3.94	57.38	2.16	17.17	10.40	1.02	85468.31
22	9.09	4.84	58.12	2.55	15.87	10.86	1.02	82605.29
23	7.09	3.44	59.53	1.58	17.56	10.37	1.02	85134.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.23	6.51	52.48	2.22	17.55	10.41	1.02	84323.89
最大值	11.08	13.85	62.63	5.56	20.50	11.19	1.05	88768.62
發生時間	13	16	13	10	3	10		3
最小值	0.42	3.15	39.13	1.14	14.52	9.49	0.99	78114.40
發生時間	15	18	4	1	13	3		15
零點偏移(率)	-0.05 %	-0.01 %	-0.04 %	0.00 %		0.00		-0.10 %
全幅偏移(率)	0.04 %	-0.17 %	-0.85 %	0.16 %		-0.31		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.30	8.84	52.08	1.53	17.71	10.38	1.00	79282.33
1	4.98	10.46	50.95	1.44	18.50	10.46	0.99	79680.67
2	5.31	7.66	54.34	1.67	16.45	10.85	0.97	78082.08
3	5.52	8.63	49.68	1.74	15.88	10.96	0.94	77252.08
4	5.50	9.96	47.25	1.99	16.00	10.56	0.95	78555.85
5	5.56	6.52	53.30	2.08	15.14	10.93	0.95	75438.35
6	5.31	9.66	50.84	2.19	16.50	10.38	0.95	78721.90
7	7.86	7.17	55.38	2.45	16.95	10.17	0.95	77216.78
8	9.34	6.25	49.20	2.90	15.26	10.60	0.98	75848.67
9	7.25	10.02	47.65	2.39	16.10	10.30	0.94	75693.31
10	5.39	5.48	48.11	2.28	15.14	10.68	0.95	75694.00
11	6.25	8.78	47.15	2.98	13.98	10.75	0.98	72881.52
12	6.35	7.59	46.50	2.51	15.03	10.68	0.92	72776.59
13	6.57	6.84	50.70	2.73	14.22	11.03	0.91	71897.86
14	10.25	8.07	52.80	3.47	13.75	11.38	0.91	70760.41
15	1.16	2.99	59.08	1.79	15.98	12.02	0.94	70030.82
16	8.75	5.86	53.69	2.29	16.77	10.67	0.96	82814.18
17	6.48	3.43	63.99	1.82	17.00	11.02	0.97	77480.97
18	7.08	5.63	57.09	1.85	16.12	10.94	0.95	80399.10
19	8.31	5.45	56.77	1.97	15.90	11.08	0.93	81128.02
20	8.95	8.71	48.42	2.35	15.73	10.81	0.94	80648.33
21	9.07	8.89	51.70	2.83	14.34	11.27	1.06	76865.58
22	11.59	11.46	54.68	3.27	14.27	11.13	0.94	77313.79
23	5.40	5.57	53.30	2.21	15.23	11.07	0.93	76686.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.73	7.50	52.28	2.28	15.75	10.84	0.95	76797.92
最大值	11.59	11.46	63.99	3.47	18.50	12.02	1.69	82814.18
發生時間	22	22	17	14	1	15		16
最小值	1.16	2.99	46.50	1.44	13.75	10.17	0.91	70030.82
發生時間	15	15	12	1	14	7		15
零點偏移(率)	-0.04 %	0.00 %	-0.00 %	0.00 %		-0.02		0.00 %
全幅偏移(率)	-0.02 %	-0.06 %	-0.96 %	-0.12 %		0.23		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								