

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.24	12.27	48.13	2.65	14.99	11.96	1.29	77334.26
1	10.56	11.51	47.93	2.08	15.91	11.24	1.29	82756.44
2	8.26	12.08	49.93	3.35	13.53	11.97	1.29	77255.35
3	10.37	12.14	56.51	1.94	15.77	11.78	1.29	77838.76
4	9.65	11.76	43.33	2.47	15.14	11.47	1.27	80514.55
5	9.54	12.01	64.24	2.12	15.71	11.67	1.29	76539.71
6	10.14	12.04	58.01	1.96	15.23	11.77	1.28	77941.54
7	12.11	11.92	46.93	2.78	14.37	11.82	1.28	78908.02
8	10.58	11.67	59.96	1.73	16.93	11.18	1.29	82477.38
9	12.47	11.73	51.57	2.87	14.72	11.50	1.29	81164.39
10	7.63	12.14	59.91	1.79	15.59	11.76	1.32	78371.15
11	11.72	11.80	51.49	2.57	15.51	11.16	1.30	82095.61
12	7.09	12.47	50.05	2.28	14.07	12.10	1.28	75442.91
13	7.55	12.65	52.17	1.77	14.79	12.17	1.28	75648.80
14	9.30	12.94	54.73	1.85	15.75	12.26	1.31	74270.82
15	9.38	12.95	57.59	1.92	15.62	12.32	1.32	73294.14
16	9.58	12.54	52.00	1.35	16.66	11.84	1.33	76611.88
17	10.51	11.32	47.03	1.26	16.84	10.69	1.31	86309.07
18	9.78	11.77	41.95	2.43	14.31	11.42	1.29	79148.34
19	12.73	12.85	49.11	3.00	14.72	11.95	1.27	76715.78
20	8.61	11.80	58.35	1.31	17.18	11.03	1.26	80384.17
21	12.49	11.29	58.19	1.50	16.43	10.86	1.27	81471.17
22	10.82	12.11	52.67	2.14	15.67	11.08	1.26	81322.86
23	12.07	12.40	42.19	2.44	14.99	11.65	1.28	78880.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.09	12.09	52.25	2.15	15.43	11.61	1.29	78862.41
最大值	12.73	12.95	64.24	3.35	17.18	12.32	1.36	86309.07
發生時間	19	15	5	2	20	15		17
最小值	7.09	11.29	41.95	1.26	13.53	10.69	1.25	73294.14
發生時間	12	21	18	17	2	17		15
零點偏移(率)	-0.08 %	-0.03 %	-0.02 %	-0.01 %		-0.04	-0.01	0.40 %
全幅偏移(率)	-1.97 %	-2.49 %	-0.61 %	-1.45 %		0.05	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.37	11.63	50.32	1.29	15.22	10.60	1.09	79250.10
1	9.44	11.89	55.56	2.04	15.88	10.73	1.08	77767.67
2	5.56	11.49	55.71	2.09	14.45	10.57	1.06	78508.25
3	10.47	11.60	64.44	1.90	15.02	10.63	1.06	78554.32
4	6.52	11.52	63.35	1.63	15.83	10.46	1.06	79757.36
5	10.72	11.83	56.21	1.85	15.07	10.69	1.04	77639.16
6	6.27	12.28	47.62	3.10	14.51	10.42	1.02	77138.92
7	9.61	12.74	56.92	1.65	15.63	10.52	1.02	76283.27
8	11.00	12.14	53.37	2.71	15.89	9.89	1.02	80479.00
9	5.84	12.44	51.59	2.10	15.90	10.14	1.04	77797.98
10	7.04	12.36	54.22	2.26	15.35	10.04	1.05	78635.08
11	6.03	12.59	63.36	1.42	15.25	10.38	1.06	77435.54
12	4.47	12.70	54.55	0.92	15.78	10.41	1.05	77783.76
13	4.83	13.07	58.98	0.73	17.03	10.53	1.04	76513.77
14	5.08	12.71	52.32	1.53	15.58	10.38	1.02	78415.06
15	6.38	13.49	51.52	1.27	16.16	10.88	1.04	74378.08
16	4.98	13.13	39.57	0.77	16.01	10.29	1.04	79930.75
17	9.17	10.61	37.63	1.25	15.04	10.46	1.04	78376.60
18	13.53	10.87	36.85	1.37	14.97	10.35	1.03	78505.15
19	9.32	10.45	44.85	1.01	15.36	10.39	1.02	77946.65
20	9.19	10.20	58.80	0.55	17.41	9.81	1.02	80081.55
21	12.33	10.40	36.83	1.03	15.71	10.04	1.02	77936.35
22	8.94	10.55	44.82	0.84	15.58	10.42	1.02	77457.78
23	15.05	11.11	58.67	1.08	17.13	9.58	1.04	79381.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.42	11.83	52.00	1.52	15.66	10.36	1.04	78164.72
最大值	15.05	13.49	64.44	3.10	17.41	10.88	1.09	80479.00
發生時間	23	15	3	6	20	15		8
最小值	4.47	10.20	36.83	0.55	14.45	9.58	1.02	74378.08
發生時間	12	20	21	20	2	23		15
零點偏移(率)	-0.10 %	-0.08 %	-0.03 %	0.00 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-0.80 %	-0.52 %	0.57 %	-0.27 %		0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.17	11.96	45.93	2.79	15.31	9.45	1.43	69982.86
1	9.30	13.80	41.95	3.14	18.54	8.73	1.43	71753.05
2	10.07	11.84	35.42	3.24	16.64	8.79	1.43	70664.70
3	9.35	11.72	34.19	2.97	16.00	8.83	1.44	70625.66
4	8.88	11.33	57.27	2.70	15.90	9.08	1.46	70309.32
5	9.91	11.56	55.89	2.26	16.26	9.28	1.46	69445.61
6	9.84	11.64	52.28	2.35	16.92	8.93	1.45	72537.49
7	4.46	11.67	33.24	1.74	16.08	9.34	1.43	70651.03
8	11.27	11.69	46.21	2.59	16.38	9.19	1.43	71040.20
9	8.74	11.70	55.96	2.52	15.85	9.19	1.43	72156.25
10	9.44	14.10	52.40	2.54	16.97	8.70	1.43	74136.25
11	9.70	12.08	53.01	2.51	16.23	8.70	1.43	73603.40
12	7.90	11.75	53.82	1.76	16.24	9.36	1.42	70994.47
13	8.11	13.25	54.32	1.67	17.49	9.70	1.42	71551.55
14	5.54	13.01	55.76	1.58	17.38	9.37	1.43	70859.54
15	8.02	12.11	51.22	1.87	17.01	9.13	1.43	73592.72
16	6.58	12.09	43.21	1.59	16.77	9.45	1.41	71289.21
17	7.27	12.12	41.64	1.73	17.49	9.44	1.41	71275.36
18	10.47	15.84	35.03	2.64	17.80	8.58	1.42	74894.95
19	8.74	12.43	29.46	2.66	18.86	7.53	1.42	70481.67
20	6.94	11.51	48.98	0.74	19.48	8.45	1.43	69839.66
21	10.83	12.89	38.13	3.37	20.02	6.98	1.43	72863.10
22	7.04	11.77	43.62	0.95	17.57	7.34	1.42	73426.25
23	11.71	13.68	47.77	0.26	15.82	8.36	1.41	70523.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.76	12.40	46.11	2.17	17.04	8.83	1.43	71604.07
最大值	11.71	15.84	57.27	3.37	20.02	9.70	1.46	74894.95
發生時間	23	18	4	21	21	13		18
最小值	4.46	11.33	29.46	0.26	15.31	6.98	1.41	69445.61
發生時間	7	4	19	23	0	21		5
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	0.00 %		-0.15	-0.01	0.20 %
全幅偏移(率)	-0.12 %	0.22 %	0.88 %	0.48 %		0.14	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								