

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.71	13.35	43.18	0.61	19.26	11.01	1.28	81314.07
1	6.83	12.97	61.66	0.39	20.89	10.71	1.27	82370.62
2	10.28	13.11	44.63	1.77	22.14	10.22	1.26	85053.71
3	9.98	13.11	60.90	1.73	20.19	10.80	1.26	82750.45
4	8.68	13.55	56.60	1.95	19.88	10.61	1.26	85293.42
5	6.62	12.69	47.22	0.81	19.90	10.49	1.24	84135.32
6	10.20	12.68	49.88	1.21	19.18	10.74	1.25	84715.26
7	9.87	12.97	56.33	0.89	19.54	11.11	1.23	81131.24
8	7.77	13.58	56.36	0.93	19.95	10.65	1.23	84180.29
9	12.26	12.34	58.90	1.22	18.59	10.78	1.24	84036.86
10	5.86	13.09	51.33	1.33	17.16	11.36	1.24	81336.94
11	10.63	12.96	52.46	1.62	16.29	11.53	1.26	79720.14
12	8.26	13.24	48.53	1.05	17.45	11.46	1.27	78960.92
13	9.36	13.00	50.89	1.11	17.58	11.30	1.27	79500.84
14	8.62	13.06	46.54	1.28	16.90	11.35	1.27	78618.34
15	9.84	12.98	51.17	1.22	16.73	11.42	1.25	78573.02
16	7.80	14.19	52.80	1.91	16.33	11.43	1.25	80884.75
17	10.53	13.08	55.37	3.13	14.76	11.83	1.24	79309.12
18	11.73	12.98	48.98	2.77	15.02	11.72	1.23	79546.67
19	12.82	12.97	51.30	1.90	16.16	11.39	1.23	81012.24
20	7.20	13.14	54.41	1.83	16.00	11.49	1.23	80990.47
21	11.15	13.15	57.53	1.51	16.63	11.48	1.24	81289.04
22	6.93	12.84	49.12	1.13	16.89	11.56	1.25	78996.70
23	10.41	12.12	54.39	1.06	17.17	11.53	1.25	80066.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.31	13.05	52.52	1.43	17.94	11.17	1.25	81407.80
最大值	12.82	14.19	61.66	3.13	22.14	11.83	1.29	85293.42
發生時間	19	16	1	17	2	17		4
最小值	5.86	12.12	43.18	0.39	14.76	10.22	1.22	78573.02
發生時間	10	23	0	1	17	2		15
零點偏移(率)	-0.02 %	-0.01 %	-0.04 %	-0.02 %		-0.07	-0.01	0.30 %
全幅偏移(率)	-0.25 %	-0.82 %	-0.67 %	-0.09 %		-0.06	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.18	12.24	47.38	0.41	21.01	9.64	1.04	81296.41
1	9.78	12.76	65.61	0.44	20.22	10.61	1.04	80072.60
2	7.84	12.23	44.64	0.98	21.05	10.06	1.04	83725.90
3	15.78	12.01	45.97	1.07	19.76	10.04	1.04	80812.32
4	10.74	11.63	43.76	0.91	19.62	9.92	1.03	82046.05
5	7.23	12.10	62.69	1.53	18.73	10.27	1.02	80661.83
6	12.96	12.05	49.38	2.34	19.17	9.96	1.01	80748.39
7	3.63	11.79	63.21	1.84	18.86	10.25	0.99	80178.62
8	3.88	11.77	53.79	1.20	18.26	10.57	0.99	80840.29
9	12.45	11.45	50.38	1.51	18.54	10.25	0.99	81699.75
10	7.00	11.69	51.37	1.83	17.26	10.63	0.99	78953.46
11	10.79	11.68	47.39	2.20	16.86	10.55	1.00	77904.59
12	7.54	11.95	55.00	2.13	16.70	10.69	0.99	79117.01
13	11.38	11.97	59.75	1.72	18.43	10.47	0.99	81576.07
14	5.66	11.74	48.62	1.17	17.76	10.39	1.00	80684.74
15	9.66	11.93	50.98	0.93	19.37	10.29	1.02	79085.85
16	10.04	12.31	49.55	1.57	17.70	10.49	1.02	83571.34
17	9.38	13.92	54.04	3.20	14.69	11.28	1.02	78123.47
18	9.15	11.78	54.14	2.86	14.77	10.93	1.02	78195.53
19	9.82	11.68	53.57	1.94	16.69	10.51	1.01	80036.35
20	12.37	11.78	54.80	1.66	17.78	10.40	1.01	82947.75
21	6.36	11.89	54.00	1.71	17.27	10.56	0.99	82189.10
22	9.93	12.26	54.52	1.82	16.99	10.94	0.98	81558.40
23	9.28	12.24	53.50	1.52	17.37	10.86	0.97	82815.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.28	12.04	52.83	1.60	18.12	10.44	1.01	80785.06
最大值	15.78	13.92	65.61	3.20	21.05	11.28	1.05	83725.90
發生時間	3	17	1	17	2	17		2
最小值	3.63	11.45	43.76	0.41	14.69	9.64	0.97	77904.59
發生時間	7	9	4	0	17	0		11
零點偏移(率)	-0.06 %	-0.02 %	-0.07 %	-0.01 %		-0.05	-0.01	0.10 %
全幅偏移(率)	-0.79 %	-1.43 %	-0.97 %	-0.05 %		0.06	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.42	12.53	50.28	3.00	20.97	9.01	1.40	79962.04
1	4.76	11.20	57.09	2.39	19.40	9.89	1.41	76973.05
2	9.70	11.26	48.16	2.80	19.87	9.85	1.41	76766.43
3	11.14	11.27	55.56	2.93	17.35	10.17	1.41	76481.74
4	9.17	11.26	58.11	2.92	17.90	10.09	1.41	76847.73
5	11.72	11.30	59.74	3.22	18.73	10.05	1.41	79614.50
6	4.25	11.47	59.56	2.65	18.10	10.32	1.41	77651.71
7	9.71	11.62	54.64	3.76	17.68	10.35	1.42	78417.88
8	8.21	12.61	61.93	3.01	17.31	10.47	1.43	76294.91
9	8.80	11.91	63.45	3.11	16.28	10.78	1.43	75015.71
10	8.76	12.39	55.68	3.60	16.84	10.33	1.41	76271.89
11	10.99	12.14	57.24	3.30	15.79	10.48	1.41	75245.08
12	9.88	11.62	56.69	3.07	18.36	10.03	1.41	78316.43
13	7.73	11.97	52.04	2.79	17.36	10.26	1.41	76906.69
14	10.02	12.28	52.19	2.99	18.11	10.08	1.41	76965.17
15	9.67	11.92	50.28	3.10	19.41	9.75	1.42	80414.45
16	8.18	12.25	51.41	2.99	18.44	10.03	1.41	79368.62
17	8.83	12.63	60.15	3.13	15.93	10.60	1.41	75893.42
18	7.71	11.74	54.15	2.33	15.88	10.46	1.42	74562.47
19	9.75	11.71	51.47	3.05	16.70	10.13	1.41	77219.98
20	8.06	11.06	49.38	3.10	19.20	9.51	1.41	82243.42
21	8.21	11.07	52.62	3.05	18.26	9.77	1.40	79104.95
22	7.86	11.27	51.62	3.13	18.08	9.90	1.39	78378.46
23	7.14	11.39	50.51	3.02	18.74	9.72	1.39	79537.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.65	11.74	54.75	3.02	17.95	10.08	1.41	77685.59
最大值	11.72	12.63	63.45	3.76	20.97	10.78	1.43	82243.42
發生時間	5	17	9	7	0	9		20
最小值	4.25	11.06	48.16	2.33	15.79	9.01	1.39	74562.47
發生時間	6	20	2	18	11	0		18
零點偏移(率)	-0.09 %	-0.01 %	-0.04 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	-0.66 %	-0.14 %	-0.34 %	-0.26 %		0.06	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								