

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.96	13.53	54.88	2.87	18.00	11.42	1.20	70316.73
1	10.35	13.83	52.80	3.03	17.94	11.63	1.18	68524.14
2	11.37	12.94	63.05	4.00	18.85	11.05	1.18	73488.65
3	10.32	13.03	59.52	2.42	17.87	11.26	1.18	71941.63
4	8.73	12.91	57.03	2.28	17.94	11.10	1.18	73312.67
5	12.78	11.59	56.66	2.69	17.81	11.14	1.18	73913.47
6	7.24	12.60	59.20	2.41	17.64	11.08	1.18	73348.96
7	9.70	11.51	59.04	1.82	17.80	11.06	1.18	73122.70
8	5.27	11.61	59.01	2.14	18.38	10.91	1.18	73866.97
9	3.54	11.81	58.33	2.14	16.75	11.46	1.20	71150.90
10	3.61	11.80	58.00	2.05	17.22	11.40	1.18	71448.31
11	3.13	12.51	53.22	1.91	18.25	11.44	1.18	70292.44
12	0.27	12.57	69.67	1.26	19.68	11.68	1.18	68113.23
13	0.12	10.48	50.55	2.19	19.09	10.95	1.18	73477.88
14	4.64	12.49	60.83	2.36	17.56	11.75	1.18	69539.37
15	8.21	13.37	56.73	2.77	17.07	11.62	1.18	70942.30
16	14.66	13.77	53.92	3.24	17.81	11.13	1.18	73632.78
17	16.51	13.48	53.40	4.25	18.73	10.96	1.18	74310.97
18	3.53	13.08	57.32	2.36	19.95	10.71	1.18	74984.05
19	3.73	8.95	39.71	2.76	17.99	11.18	1.18	72590.48
20	6.97	12.91	56.66	1.36	18.90	11.21	1.18	72108.31
21	7.88	12.69	52.96	1.35	19.72	10.98	1.18	72971.47
22	7.77	12.79	48.05	1.71	19.30	10.98	1.18	73178.96
23	8.08	14.15	50.97	2.31	17.65	11.75	1.18	68773.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.47	12.52	55.90	2.40	18.25	11.24	1.18	72056.29
最大值	16.51	14.15	69.67	4.25	19.95	11.75	1.21	74984.05
發生時間	17	23	12	17	18	14		18
最小值	0.12	8.95	39.71	1.26	16.75	10.71	1.17	68113.23
發生時間	13	19	19	12	9	18		12
零點偏移(率)	-0.07 %	-0.02 %	-0.02 %	-0.00 %		-0.10	-0.01	0.30 %
全幅偏移(率)	0.11 %	2.00 %	0.01 %	0.49 %		-0.10	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.60	12.79	66.00	1.53	17.78	11.31	1.01	79096.74
1	10.21	12.21	62.67	1.83	19.67	10.61	1.02	80864.82
2	8.75	12.61	56.09	2.70	17.85	10.96	1.02	81432.81
3	8.58	13.28	60.13	1.20	16.96	11.77	1.02	73988.24
4	10.06	12.32	53.65	1.54	17.89	10.91	1.02	80705.08
5	8.50	12.46	55.45	1.72	17.10	11.04	1.02	80461.11
6	6.15	11.94	45.87	1.50	17.67	10.59	1.04	74777.92
7	12.12	12.39	56.39	2.74	17.03	10.90	1.05	80448.75
8	7.76	12.63	62.64	2.45	16.79	11.25	1.05	79546.30
9	9.99	12.17	50.55	2.53	17.56	10.70	1.04	81030.86
10	9.71	12.41	53.74	1.98	17.89	10.80	1.04	80390.83
11	8.71	12.25	58.53	1.72	17.39	10.92	1.05	78607.82
12	10.14	12.07	55.74	3.76	18.06	10.51	1.04	79188.82
13	8.05	14.73	59.52	2.46	17.39	10.90	1.04	77770.18
14	10.46	14.35	54.21	1.95	18.26	10.45	1.04	81122.76
15	8.11	15.48	59.54	3.29	15.94	11.06	1.05	78182.29
16	7.72	15.08	56.87	1.96	16.61	11.28	1.06	78012.66
17	7.06	15.30	44.96	2.54	16.38	11.33	1.06	79796.52
18	7.53	14.95	50.89	2.57	17.27	11.08	1.04	80798.51
19	7.72	15.62	46.89	2.91	17.64	10.92	1.03	81454.63
20	6.78	15.10	48.25	1.87	17.17	11.20	1.02	77546.73
21	8.08	14.59	44.10	1.78	18.81	10.51	1.04	81450.81
22	7.18	15.67	59.06	1.41	18.25	11.31	1.04	77816.34
23	6.72	14.85	61.69	0.85	19.25	10.83	1.04	80882.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.53	13.64	55.14	2.12	17.61	10.96	1.04	79390.60
最大值	12.12	15.67	66.00	3.76	19.67	11.77	1.06	81454.63
發生時間	7	22	0	12	1	3		19
最小值	6.15	11.94	44.10	0.85	15.94	10.45	1.00	73988.24
發生時間	6	6	21	23	15	14		3
零點偏移(率)	-0.12 %	-0.01 %	-0.08 %	-0.01 %		-0.13	-0.01	-0.20 %
全幅偏移(率)	0.00 %	2.60 %	-0.07 %	1.04 %		-0.26	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.40	11.97	51.07	1.60	17.62	9.78	1.34	75337.12
1	9.75	12.23	56.68	1.80	19.52	9.77	1.34	74848.45
2	8.85	11.87	57.21	1.91	18.96	9.61	1.34	75340.79
3	8.73	11.06	57.35	1.87	18.09	9.79	1.31	74569.34
4	10.42	11.09	54.92	1.95	18.99	9.53	1.30	75817.61
5	9.12	11.48	50.28	1.78	18.83	9.68	1.29	74886.47
6	8.91	10.83	49.41	1.82	18.65	9.43	1.30	75322.05
7	8.89	10.96	53.48	1.90	18.03	9.70	1.31	78529.78
8	10.11	11.20	57.99	1.81	16.87	9.95	1.35	74445.99
9	9.36	11.63	56.91	2.00	16.69	9.85	1.32	76184.35
10	11.26	11.14	53.48	2.02	17.78	9.43	1.34	74320.78
11	8.08	10.99	52.17	1.76	18.12	9.32	1.31	75116.58
12	10.07	11.23	55.96	1.91	18.87	9.31	1.31	75876.26
13	9.68	12.83	52.98	2.14	18.97	9.57	1.31	75112.83
14	8.11	13.48	56.24	1.72	17.83	9.78	1.30	73790.10
15	8.70	13.35	54.44	1.78	17.95	9.77	1.29	72819.64
16	9.70	13.46	53.45	1.84	18.42	9.50	1.29	75032.46
17	10.01	12.93	52.65	1.76	18.30	9.31	1.29	74558.54
18	8.68	13.09	53.26	1.65	17.63	9.66	1.31	72075.29
19	8.66	12.90	51.83	1.74	19.96	9.13	1.33	70107.06
20	9.61	12.57	54.76	1.79	21.00	8.39	1.35	75256.55
21	8.71	14.76	31.53	2.28	20.83	8.03	1.32	73383.34
22	10.42	12.76	43.71	2.34	18.58	8.76	1.31	71888.32
23	9.25	12.75	41.86	1.60	19.14	8.86	1.31	72086.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.31	12.19	52.23	1.87	18.57	9.41	1.32	74446.10
最大值	11.26	14.76	57.99	2.34	21.00	9.95	1.36	78529.78
發生時間	10	21	8	22	20	8		7
最小值	8.08	10.83	31.53	1.60	16.69	8.03	1.28	70107.06
發生時間	11	6	21	0	9	21		19
零點偏移(率)	-0.08 %	0.01 %	-0.02 %	-0.00 %		-0.11	-0.01	-0.10 %
全幅偏移(率)	-1.21 %	0.02 %	-0.35 %	0.10 %		0.16	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								