

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.34	7.86	58.31	0.93	18.44	11.24	1.10	75480.29
1	9.74	9.13	50.86	1.53	17.80	11.55	1.10	72492.97
2	8.64	8.52	48.87	1.72	17.23	11.45	1.10	72993.64
3	3.93	9.32	50.36	0.99	18.06	11.51	1.11	73157.86
4	1.12	9.41	55.05	0.82	18.96	11.53	1.12	72213.59
5	7.35	7.53	43.35	1.09	20.84	10.13	1.09	78456.78
6	9.84	10.57	43.46	1.76	18.26	10.89	1.06	77436.30
7	8.96	8.54	45.07	1.72	18.71	11.08	1.07	75665.49
8	9.27	9.08	44.54	1.69	18.69	11.15	1.09	74771.00
9	9.51	7.87	49.29	1.17	19.57	11.04	1.11	75732.00
10	6.78	8.79	48.69	0.47	21.47	10.57	1.07	77098.73
11	8.80	8.50	42.86	0.84	20.30	10.73	1.08	77002.98
12	10.23	10.94	44.93	1.51	17.52	11.64	1.07	72485.91
13	8.92	8.52	50.56	1.36	17.47	11.85	1.10	70918.46
14	9.29	8.96	55.70	1.78	17.33	11.78	1.10	71210.16
15	7.82	7.79	55.40	1.11	18.76	11.54	1.12	72285.81
16	9.03	10.43	58.11	1.27	18.95	11.19	1.11	75231.00
17	6.87	5.49	57.26	0.85	19.49	10.64	1.08	78898.66
18	9.42	10.35	41.93	1.16	19.90	10.37	1.09	80242.80
19	8.30	8.56	56.58	0.48	20.81	10.46	1.10	79510.76
20	8.00	8.37	49.52	0.71	20.43	10.44	1.08	79280.18
21	3.97	8.58	58.95	0.61	20.07	10.97	1.09	75441.67
22	8.08	7.93	54.20	0.51	21.13	10.15	1.06	81315.63
23	8.12	10.26	50.15	0.62	19.90	10.76	1.05	77076.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.93	8.80	50.58	1.11	19.17	11.03	1.09	75683.31
最大值	10.23	10.94	58.95	1.78	21.47	11.85	1.22	81315.63
發生時間	12	12	21	14	10	13		22
最小值	1.12	5.49	41.93	0.47	17.23	10.13	1.05	70918.46
發生時間	4	17	18	10	2	5		13
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.03 %		0.00		0.00 %
全幅偏移(率)	2.22 %	0.42 %	0.18 %	0.31 %		0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.79	6.57	53.16	1.58	16.43	10.40	1.05	84574.06
1	8.52	7.94	50.88	2.31	16.37	10.49	1.07	83882.84
2	11.79	7.58	66.47	3.14	14.39	11.28	1.06	79728.97
3	4.08	3.38	56.98	2.00	14.56	11.59	1.07	77932.24
4	1.18	5.35	51.39	1.47	16.50	11.17	1.08	79032.51
5	9.61	3.58	60.82	2.02	17.02	9.85	1.07	88559.19
6	5.40	9.02	54.54	2.95	13.33	11.34	1.07	80130.11
7	4.12	6.57	57.06	2.23	15.96	10.50	1.07	84249.95
8	8.06	3.20	61.20	2.38	17.02	10.14	1.06	86048.31
9	9.50	3.25	48.98	1.85	18.04	9.88	1.04	87141.25
10	9.03	4.51	53.91	2.54	15.82	10.46	1.06	84534.29
11	9.59	5.82	56.20	2.19	16.01	10.39	1.05	85073.11
12	8.69	3.84	55.12	2.22	15.40	10.73	1.02	83157.46
13	8.17	2.61	59.47	1.30	17.14	10.04	1.05	86882.31
14	6.16	9.41	53.61	2.53	15.44	10.65	1.05	83358.20
15	7.84	6.50	49.63	2.17	15.37	10.69	1.06	82989.35
16	8.53	2.70	60.39	2.02	15.36	10.66	1.07	83864.37
17	8.54	2.68	58.13	2.12	15.30	10.59	1.03	84375.41
18	8.47	5.03	65.07	1.52	16.66	10.51	1.02	84089.56
19	7.99	7.54	52.51	1.13	17.92	10.03	1.05	86278.27
20	6.73	7.50	47.21	2.31	15.65	10.26	1.06	86430.76
21	8.58	5.89	65.51	1.66	15.55	10.69	1.06	83103.76
22	7.83	5.53	51.66	1.11	17.09	10.58	1.06	82607.42
23	2.76	4.82	61.18	1.14	17.12	10.98	1.07	79320.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.50	5.45	56.30	2.00	16.06	10.58	1.06	83639.33
最大值	11.79	9.41	66.47	3.14	18.04	11.59	1.10	88559.19
發生時間	2	14	2	2	9	3		5
最小值	1.18	2.61	47.21	1.11	13.33	9.85	1.01	77932.24
發生時間	4	13	20	22	6	5		3
零點偏移(率)	-0.02 %	-0.09 %	-0.01 %	-0.01 %		0.03		-0.20 %
全幅偏移(率)	0.04 %	0.08 %	-0.27 %	0.29 %		-0.16		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.36	2.73	44.40	2.22	13.93	11.26	1.05	75676.78
1	7.97	4.10	41.51	1.54	15.82	11.07	1.05	78482.91
2	9.68	7.21	30.94	2.63	16.86	9.03	1.04	84587.40
3	8.31	6.21	45.83	3.05	13.75	10.78	1.04	74173.69
4	8.43	7.09	51.96	1.67	15.69	10.91	1.05	81105.83
5	8.92	8.39	57.29	2.54	13.93	11.40	1.05	82315.22
6	8.84	8.11	48.60	1.78	15.73	10.73	1.05	83351.97
7	8.03	6.21	59.17	1.50	15.63	11.08	1.04	78556.13
8	9.75	3.38	62.15	2.00	16.13	10.40	1.05	80418.00
9	8.49	11.41	42.12	2.44	13.72	10.96	1.03	74896.89
10	9.01	12.75	45.37	2.63	13.50	11.11	1.01	72543.66
11	4.33	3.03	65.98	1.52	15.40	11.00	1.01	73859.48
12	7.86	4.10	51.23	1.64	15.52	10.60	1.02	78332.70
13	5.51	3.35	57.53	1.45	15.75	11.00	1.02	73336.74
14	1.96	5.40	65.03	1.16	16.54	10.16	1.02	79552.33
15	3.36	2.96	53.89	1.52	15.30	10.57	1.02	77322.59
16	5.67	3.20	63.28	1.22	16.90	10.55	1.03	80337.61
17	7.90	6.80	44.42	1.34	16.14	10.69	1.02	81281.06
18	4.67	5.64	44.98	1.31	15.50	10.63	1.02	77791.27
19	1.36	8.66	51.11	1.20	15.44	10.99	0.99	75446.63
20	1.96	7.45	49.84	1.16	16.28	10.59	1.00	80358.83
21	2.28	3.13	47.78	1.40	14.93	10.99	1.01	77293.36
22	1.98	4.35	55.35	1.32	15.88	11.12	0.99	75325.43
23	2.67	5.16	54.20	1.24	16.07	11.06	0.99	76251.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.18	5.87	51.41	1.73	15.43	10.78	1.02	78024.90
最大值	9.75	12.75	65.98	3.05	16.90	11.40	1.06	84587.40
發生時間	8	10	11	3	16	5		2
最小值	1.36	2.73	30.94	1.16	13.50	9.03	0.98	72543.66
發生時間	19	0	2	14	10	2		10
零點偏移(率)	-0.01 %	-0.05 %	-0.03 %	-0.03 %		0.01		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.33 %	0.14 %		-0.02		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								