

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月04日

報表日期: 114年05月04日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 5.50     | 2.31     | 63.54    | 1.33     | 18.44    | 11.48    | 1.31     | 77404.99  |
| 1                 | 5.15     | 3.82     | 47.55    | 1.64     | 19.46    | 10.62    | 1.33     | 83338.60  |
| 2                 | 7.95     | 0.84     | 41.32    | 2.21     | 17.91    | 10.48    | 1.34     | 83896.51  |
| 3                 | 8.52     | 1.50     | 56.48    | 1.85     | 17.58    | 10.91    | 1.34     | 79599.06  |
| 4                 | 10.06    | 1.62     | 51.72    | 2.52     | 16.87    | 10.88    | 1.34     | 80837.24  |
| 5                 | 12.36    | 3.72     | 54.14    | 3.12     | 15.85    | 11.36    | 1.31     | 77233.28  |
| 6                 | 7.22     | 2.47     | 65.03    | 2.04     | 17.61    | 11.48    | 1.31     | 77257.95  |
| 7                 | 10.96    | 3.39     | 44.05    | 1.68     | 19.49    | 10.41    | 1.33     | 86128.90  |
| 8                 | 10.31    | 3.88     | 51.95    | 2.65     | 17.33    | 10.78    | 1.30     | 84625.78  |
| 9                 | 7.62     | 2.72     | 55.57    | 2.55     | 16.44    | 10.91    | 1.29     | 83513.09  |
| 10                | 7.25     | 4.94     | 54.04    | 2.38     | 17.24    | 10.83    | 1.31     | 84124.17  |
| 11                | 7.53     | 5.14     | 54.04    | 1.17     | 18.74    | 10.83    | 1.31     | 82645.51  |
| 12                | 8.14     | 2.82     | 56.18    | 1.84     | 17.31    | 10.88    | 1.32     | 83672.14  |
| 13                | 8.69     | 4.75     | 54.61    | 1.36     | 18.94    | 10.62    | 1.31     | 84964.91  |
| 14                | 10.31    | 2.84     | 55.89    | 1.32     | 18.71    | 10.33    | 1.31     | 84813.99  |
| 15                | 9.15     | 2.66     | 62.26    | 1.24     | 18.17    | 10.39    | 1.30     | 83857.88  |
| 16                | 10.05    | 2.65     | 68.45    | 1.25     | 18.15    | 10.51    | 1.29     | 84603.01  |
| 17                | 7.96     | 2.88     | 45.81    | 1.48     | 17.31    | 10.54    | 1.29     | 83024.60  |
| 18                | 8.79     | 5.35     | 42.21    | 1.98     | 16.91    | 10.72    | 1.31     | 84911.80  |
| 19                | 10.56    | 10.52    | 43.43    | 1.97     | 18.27    | 10.30    | 1.32     | 82362.29  |
| 20                | 7.49     | 3.87     | 24.47    | 3.10     | 17.33    | 9.96     | 1.31     | 80800.34  |
| 21                | 5.52     | 1.38     | 66.10    | 1.92     | 15.86    | 11.87    | 1.31     | 73610.73  |
| 22                | 3.97     | 2.17     | 58.77    | 1.20     | 17.36    | 11.88    | 1.32     | 76142.49  |
| 23                | 6.38     | 3.11     | 54.06    | 1.39     | 17.12    | 11.43    | 1.31     | 80085.92  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.23     | 3.39     | 52.99    | 1.88     | 17.68    | 10.85    | 1.31     | 81810.63  |
| 最 大 值             | 12.36    | 10.52    | 68.45    | 3.12     | 19.49    | 11.88    | 1.34     | 86128.90  |
| 發生時間              | 5        | 19       | 16       | 5        | 7        | 22       |          | 7         |
| 最 小 值             | 3.97     | 0.84     | 24.47    | 1.17     | 15.85    | 9.96     | 1.29     | 73610.73  |
| 發生時間              | 22       | 2        | 20       | 11       | 5        | 20       |          | 21        |
| 零點偏移(率)           | -0.05 %  | 0.00 %   | -0.11 %  | 0.00 %   |          | -0.04    |          | 0.20 %    |
| 全幅偏移(率)           | 0.00 %   | 0.35 %   | -0.50 %  | 0.07 %   |          | 0.02     |          | 0.20 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月04日

| 項目<br>單位<br>小時\限標 | #2-HCl_C<br>ppm | #2-CO_C<br>ppm | #2-NOx_C<br>ppm | #2-SO2_C<br>ppm | #2-H2O<br>% | #2-O2_C<br>% | #2-OPAC<br>% | #2-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 6.71            | 2.18           | 60.28           | 2.21            | 16.03       | 11.79        | 1.06         | 76212.14             |
| 1                 | 9.69            | 4.66           | 43.84           | 3.13            | 16.19       | 11.42        | 1.06         | 79320.90             |
| 2                 | 14.56           | 7.24           | 46.96           | 4.47            | 15.05       | 10.90        | 1.06         | 84995.13             |
| 3                 | 14.46           | 2.00           | 54.99           | 4.07            | 15.61       | 10.97        | 1.06         | 84160.48             |
| 4                 | 10.05           | 6.13           | 54.27           | 4.24            | 14.10       | 11.56        | 1.05         | 78339.93             |
| 5                 | 10.03           | 8.95           | 58.11           | 4.60            | 14.17       | 11.41        | 1.04         | 78905.55             |
| 6                 | 10.32           | 7.26           | 51.77           | 3.06            | 17.43       | 11.01        | 1.03         | 80004.00             |
| 7                 | 10.94           | 5.99           | 46.68           | 3.69            | 16.23       | 10.86        | 1.04         | 80572.97             |
| 8                 | 15.38           | 3.47           | 56.35           | 3.68            | 15.75       | 10.87        | 1.05         | 84150.90             |
| 9                 | 10.76           | 4.64           | 54.98           | 3.33            | 16.02       | 10.83        | 1.04         | 84805.36             |
| 10                | 11.48           | 1.92           | 58.22           | 3.29            | 16.25       | 10.88        | 1.03         | 83791.48             |
| 11                | 12.99           | 3.64           | 57.36           | 2.49            | 18.35       | 10.34        | 1.03         | 87283.43             |
| 12                | 10.57           | 4.57           | 59.15           | 3.31            | 15.96       | 11.30        | 1.02         | 79624.22             |
| 13                | 8.04            | 2.25           | 60.80           | 2.17            | 16.61       | 11.64        | 1.03         | 77034.17             |
| 14                | 9.91            | 2.77           | 52.19           | 2.76            | 16.80       | 11.09        | 1.04         | 80905.65             |
| 15                | 10.16           | 3.83           | 55.24           | 2.11            | 19.21       | 9.66         | 1.04         | 88194.28             |
| 16                | 8.64            | 1.35           | 59.68           | 2.67            | 15.74       | 10.92        | 1.04         | 81050.25             |
| 17                | 10.73           | 4.39           | 49.95           | 2.72            | 16.35       | 10.85        | 1.04         | 79810.75             |
| 18                | 11.35           | 5.23           | 49.53           | 3.52            | 15.75       | 10.64        | 1.04         | 82598.08             |
| 19                | 14.06           | 2.51           | 57.95           | 3.62            | 16.34       | 10.70        | 1.03         | 84631.53             |
| 20                | 6.57            | 8.38           | 56.92           | 4.43            | 15.50       | 11.25        | 1.03         | 78709.96             |
| 21                | 8.68            | 2.33           | 50.99           | 4.07            | 16.26       | 10.83        | 1.04         | 82495.29             |
| 22                | 8.99            | 1.18           | 52.65           | 1.56            | 17.60       | 10.54        | 1.05         | 85003.03             |
| 23                | 9.70            | 4.28           | 51.72           | 2.91            | 16.60       | 10.72        | 1.05         | 83449.68             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 10.62           | 4.21           | 54.19           | 3.25            | 16.25       | 10.96        | 1.04         | 81918.71             |
| 最 大 值             | 15.38           | 8.95           | 60.80           | 4.60            | 19.21       | 11.79        | 1.07         | 88194.28             |
| 發生時間              | 8               | 5              | 13              | 5               | 15          | 0            |              | 15                   |
| 最 小 值             | 6.57            | 1.18           | 43.84           | 1.56            | 14.10       | 9.66         | 1.02         | 76212.14             |
| 發生時間              | 20              | 22             | 1               | 22              | 4           | 15           |              | 0                    |
| 零點偏移(率)           | -0.06 %         | -0.01 %        | -0.02 %         | -0.00 %         |             | -0.07        |              | -0.20 %              |
| 全幅偏移(率)           | 0.14 %          | 0.14 %         | 0.04 %          | -0.03 %         |             | -0.16        |              | -0.20 %              |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月04日

報表日期: 114年05月04日

| 項目<br>單位<br>小時\限標 | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 4.45     | 3.21     | 53.63    | 1.84     | 19.38    | 9.77     | 1.48     | 79010.86  |
| 1                 | 1.26     | 6.15     | 48.98    | 3.93     | 20.85    | 9.11     | 1.47     | 83807.70  |
| 2                 | 1.24     | 1.84     | 54.62    | 1.89     | 16.69    | 9.84     | 1.48     | 81230.41  |
| 3                 | 5.77     | 0.90     | 57.98    | 2.30     | 16.39    | 10.23    | 1.46     | 70752.76  |
| 4                 | 6.30     | 1.96     | 56.37    | 2.50     | 16.10    | 9.99     | 1.48     | 73394.59  |
| 5                 | 5.43     | 5.45     | 52.22    | 2.15     | 16.54    | 9.47     | 1.48     | 78309.97  |
| 6                 | 7.50     | 1.66     | 58.63    | 2.29     | 16.72    | 9.84     | 1.49     | 80316.86  |
| 7                 | 9.62     | 2.97     | 51.42    | 3.02     | 19.55    | 9.56     | 1.49     | 86810.66  |
| 8                 | 8.45     | 5.08     | 59.91    | 2.71     | 16.86    | 9.79     | 1.50     | 82318.12  |
| 9                 | 10.12    | 3.70     | 59.69    | 2.90     | 16.70    | 9.91     | 1.52     | 80440.49  |
| 10                | 8.92     | 2.42     | 62.43    | 3.19     | 15.47    | 10.60    | 1.51     | 75431.78  |
| 11                | 10.82    | 3.02     | 57.33    | 3.53     | 19.39    | 9.11     | 1.51     | 85959.92  |
| 12                | 9.05     | 3.83     | 62.74    | 3.05     | 18.17    | 9.29     | 1.51     | 82264.48  |
| 13                | 8.15     | 6.05     | 58.61    | 2.91     | 19.02    | 9.33     | 1.51     | 83365.81  |
| 14                | 6.20     | 3.88     | 57.24    | 2.58     | 17.91    | 9.45     | 1.49     | 80651.97  |
| 15                | 4.64     | 5.23     | 48.77    | 2.50     | 19.05    | 8.86     | 1.48     | 81210.90  |
| 16                | 5.66     | 6.08     | 51.53    | 2.29     | 17.20    | 9.35     | 1.48     | 80077.99  |
| 17                | 5.74     | 3.06     | 57.33    | 2.49     | 16.79    | 10.06    | 1.46     | 77399.81  |
| 18                | 8.93     | 7.00     | 59.81    | 2.83     | 16.75    | 9.93     | 1.47     | 78189.67  |
| 19                | 5.95     | 2.75     | 70.00    | 2.53     | 17.09    | 9.92     | 1.48     | 74858.90  |
| 20                | 4.05     | 4.34     | 55.16    | 2.38     | 16.46    | 9.54     | 1.48     | 74499.18  |
| 21                | 5.09     | 6.67     | 56.02    | 2.09     | 17.88    | 9.71     | 1.48     | 75537.38  |
| 22                | 7.18     | 5.79     | 49.76    | 2.41     | 17.89    | 9.09     | 1.48     | 81653.79  |
| 23                | 5.38     | 5.92     | 55.52    | 2.28     | 17.10    | 9.91     | 1.47     | 76763.92  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 6.50     | 4.12     | 56.49    | 2.61     | 17.58    | 9.65     | 1.48     | 79344.08  |
| 最 大 值             | 10.82    | 7.00     | 70.00    | 3.93     | 20.85    | 10.60    | 1.52     | 86810.66  |
| 發生時間              | 11       | 18       | 19       | 1        | 1        | 10       |          | 7         |
| 最 小 值             | 1.24     | 0.90     | 48.77    | 1.84     | 15.47    | 8.86     | 1.46     | 70752.76  |
| 發生時間              | 2        | 3        | 15       | 0        | 10       | 15       |          | 3         |
| 零點偏移(率)           | 0.00 %   | 0.00 %   | -0.02 %  | 0.00 %   |          | 0.00     |          | -0.10 %   |
| 全幅偏移(率)           | 0.02 %   | -0.11 %  | -0.20 %  | 0.05 %   |          | 0.04     |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |