

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.70	12.36	58.64	1.15	19.80	10.88	1.05	83348.36
1	9.68	12.97	58.88	1.47	19.69	11.08	1.05	82136.37
2	9.35	13.14	61.56	1.26	19.79	11.30	1.05	80644.01
3	10.73	12.80	53.58	1.67	19.12	10.99	1.05	83221.01
4	9.70	21.13	52.50	2.79	16.34	11.65	1.05	80202.97
5	11.82	15.34	52.98	3.10	16.15	11.80	1.03	88393.98
6	9.34	14.80	52.14	3.19	17.34	11.37	1.04	80657.37
7	9.79	13.86	54.56	1.98	18.07	11.26	1.03	81442.57
8	9.65	12.65	52.20	1.93	17.74	11.45	1.02	79922.36
9	9.83	12.32	50.57	1.80	17.56	11.44	1.05	79442.14
10	8.56	13.43	55.95	1.59	17.94	11.57	1.04	78274.66
11	9.67	12.41	53.44	1.61	18.35	11.21	1.04	81347.15
12	9.19	15.02	51.21	1.66	17.44	11.70	1.04	78311.83
13	10.16	13.99	51.45	1.99	18.00	11.11	1.02	82082.37
14	9.93	12.94	55.97	2.08	17.74	11.52	1.03	79175.47
15	9.46	16.26	56.81	2.90	15.23	12.44	1.03	73052.14
16	9.83	10.77	59.07	2.10	17.21	11.52	1.03	80512.41
17	10.55	13.02	56.53	1.68	18.50	10.93	1.05	83439.39
18	8.91	7.65	48.93	2.72	15.74	11.74	1.05	77788.92
19	10.29	6.91	53.06	1.77	18.93	11.13	1.04	81996.00
20	11.17	15.14	46.86	2.67	16.02	11.63	1.05	79124.18
21	8.87	13.72	45.44	2.90	15.41	11.75	1.05	78128.52
22	8.47	8.81	59.17	1.24	18.62	11.29	1.05	81451.19
23	9.89	11.82	56.34	1.24	19.48	10.83	1.06	83827.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.77	13.05	54.08	2.02	17.76	11.40	1.04	80746.78
最大值	11.82	21.13	61.56	3.19	19.80	12.44	1.07	88393.98
發生時間	5	4	2	6	0	15		5
最小值	8.47	6.91	45.44	1.15	15.23	10.83	1.00	73052.14
發生時間	22	19	21	0	15	23		15
零點偏移(率)	-0.21 %	-0.02 %	-0.02 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	0.04 %	0.43 %	-0.39 %	0.23 %		0.20		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.17	7.88	54.90	1.73	19.12	9.78	1.21	83228.86
1	5.96	7.24	52.95	1.28	20.18	9.94	1.22	83589.05
2	7.66	8.27	50.76	2.03	19.45	9.97	1.23	82047.72
3	7.46	16.96	51.22	2.18	18.41	10.05	1.23	84561.85
4	7.11	7.57	62.54	2.51	17.61	10.68	1.23	79951.00
5	8.74	7.99	49.12	3.63	15.78	11.11	1.21	80702.79
6	3.56	7.85	45.53	3.15	16.87	10.03	1.24	85749.30
7	8.54	9.85	58.11	3.38	16.24	10.63	1.25	78538.32
8	10.37	7.71	54.48	2.89	17.83	10.25	1.24	83190.78
9	9.36	6.16	61.92	2.60	17.40	10.29	1.24	83243.78
10	7.22	6.26	57.21	2.40	17.61	10.26	1.25	82846.10
11	8.71	14.03	56.18	2.25	18.26	10.11	1.26	84155.98
12	7.48	6.59	52.19	2.41	17.67	10.15	1.25	81716.67
13	9.83	6.29	55.00	2.47	17.43	10.19	1.24	83178.67
14	9.75	7.13	60.50	2.86	16.61	10.50	1.23	81435.81
15	8.83	7.05	62.03	2.29	17.14	10.84	1.23	76465.52
16	9.91	13.71	55.00	2.95	17.15	10.16	1.23	83972.68
17	7.11	7.85	53.33	2.12	17.35	10.11	1.24	78076.83
18	9.70	13.06	46.43	2.69	16.84	9.82	1.23	77488.16
19	9.84	11.21	53.94	1.99	17.57	9.31	1.23	85084.05
20	9.31	13.55	59.11	1.97	17.03	10.04	1.25	79985.34
21	9.27	8.67	44.44	1.87	17.88	9.73	1.24	82667.90
22	7.27	11.32	49.48	1.80	17.58	10.09	1.25	80887.30
23	7.04	14.69	51.62	1.62	17.84	10.15	1.24	78466.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.30	9.54	54.08	2.38	17.62	10.17	1.24	81717.94
最大值	10.37	16.96	62.54	3.63	20.18	11.11	1.27	85749.30
發生時間	8	3	4	5	1	5		6
最小值	3.56	6.16	44.44	1.28	15.78	9.31	1.20	76465.52
發生時間	6	9	21	1	5	19		15
零點偏移(率)	0.00 %	-0.06 %	-0.01 %	-0.01 %		0.04		0.00 %
全幅偏移(率)	0.04 %	0.69 %	-0.69 %	0.29 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.75	12.95	55.19	1.07	18.19	10.26	1.01	83254.83
1	2.76	12.16	47.18	1.35	17.93	10.80	1.02	81676.59
2	1.15	10.59	58.01	1.15	18.14	10.64	1.02	81080.97
3	2.53	10.92	62.21	1.38	17.19	10.97	1.02	80653.99
4	0.52	14.18	62.68	1.55	15.58	11.63	1.02	76400.79
5	0.90	23.40	60.97	2.01	14.58	11.75	1.02	73448.55
6	4.12	8.42	61.45	2.22	14.55	11.39	1.02	76571.52
7	3.72	16.99	54.14	1.70	15.52	10.89	1.02	67411.71
8	2.23	12.36	57.44	1.69	15.54	11.14	1.04	78096.87
9	9.00	13.48	56.87	1.92	16.06	10.87	1.03	80634.74
10	8.10	12.47	58.20	1.61	16.32	10.98	1.06	80692.68
11	6.35	13.42	59.89	1.30	16.79	11.07	1.05	79248.89
12	2.61	12.05	59.37	1.18	16.92	11.04	1.05	82416.44
13	3.32	12.18	57.23	1.55	15.84	11.03	1.06	79807.19
14	3.88	14.58	57.95	2.01	15.04	11.16	1.03	77251.97
15	3.06	13.34	56.62	1.52	16.86	11.02	1.01	77549.08
16	4.21	7.72	55.29	1.46	16.61	10.91	0.99	78200.55
17	3.88	7.46	54.44	1.24	17.90	10.46	1.00	82818.72
18	4.84	16.94	57.51	2.13	14.63	11.46	1.01	74291.71
19	1.50	16.26	50.25	1.95	14.97	10.85	1.00	77461.39
20	2.65	5.95	49.10	1.77	15.30	10.92	1.00	76610.33
21	4.64	11.14	51.07	1.84	15.08	10.99	1.02	75961.14
22	10.38	15.82	51.43	1.69	16.11	10.90	1.01	76560.79
23	4.77	12.54	50.59	1.15	17.67	10.48	1.01	77717.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.87	12.81	56.04	1.60	16.22	10.98	1.02	78159.14
最大值	10.38	23.40	62.68	2.22	18.19	11.75	1.08	83254.83
發生時間	22	5	4	6	0	5		0
最小值	0.52	5.95	47.18	1.07	14.55	10.26	0.98	67411.71
發生時間	4	20	1	0	6	0		7
零點偏移(率)	0.00 %	0.00 %	-0.26 %	-0.08 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.84 %	-0.59 %	0.34 %		0.34		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								