

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.81	5.33	61.98	1.52	19.98	11.05	1.12	75712.58
1	2.84	5.79	57.42	0.95	22.40	10.50	1.10	77636.96
2	4.60	7.43	49.91	2.27	20.14	10.70	1.10	77857.92
3	6.55	9.15	65.34	2.41	18.53	11.08	1.10	77132.67
4	4.05	11.45	60.12	2.85	16.53	11.71	1.10	73198.68
5	9.51	10.57	47.75	1.89	17.01	11.41	1.10	77030.14
6	8.13	13.17	50.72	2.00	15.63	11.86	1.10	73133.96
7	5.16	11.64	62.37	0.91	18.67	11.55	1.10	73190.31
8	3.91	11.25	63.33	0.95	18.18	11.92	1.10	71240.20
9	4.20	6.14	52.83	0.68	19.50	11.15	1.08	75655.78
10	9.03	5.75	31.73	1.60	18.55	10.84	1.07	78524.27
11	8.64	5.65	48.70	1.34	19.08	10.93	1.10	77049.85
12	9.37	5.48	52.48	1.41	18.38	11.05	1.11	76755.32
13	9.38	5.67	53.56	1.87	17.49	11.47	1.10	75290.01
14	8.45	5.06	59.13	1.25	18.16	11.37	1.10	75369.72
15	9.29	5.16	50.60	1.25	18.79	11.04	1.11	77567.34
16	9.61	5.38	43.99	1.86	17.48	11.18	1.10	76851.92
17	9.51	5.46	43.47	1.80	17.43	11.26	1.08	76640.69
18	9.46	5.73	49.92	1.97	16.71	11.55	1.07	75189.71
19	9.44	5.79	50.63	2.06	15.61	11.77	1.07	74273.47
20	9.91	8.43	48.48	2.33	15.55	11.63	1.07	75384.28
21	9.52	9.21	45.75	2.27	15.99	11.47	1.07	75791.10
22	9.10	10.11	54.32	1.37	17.70	11.47	1.08	74358.15
23	8.85	8.54	51.41	1.60	16.76	11.63	1.10	73976.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.47	7.64	52.33	1.68	17.93	11.32	1.09	75617.13
最大值	9.91	13.17	65.34	2.85	22.40	11.92	1.12	78524.27
發生時間	20	6	3	4	1	8		10
最小值	0.81	5.06	31.73	0.68	15.55	10.50	1.07	71240.20
發生時間	0	14	10	9	20	1		8
零點偏移(率)	-0.12 %	-0.01 %	-0.83 %	-0.59 %		0.00		0.00 %
全幅偏移(率)	-0.84 %	1.59 %	0.44 %	0.09 %		-0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.91	3.85	49.10	1.51	18.17	9.92	1.02	86539.19
1	2.89	4.92	58.70	1.41	19.54	9.88	1.02	85706.91
2	2.42	3.78	66.21	2.50	16.31	10.64	1.01	83482.05
3	2.06	8.10	57.17	2.71	15.79	10.36	1.01	85894.19
4	3.76	8.35	57.71	2.56	16.78	10.26	1.02	85487.50
5	7.95	7.77	58.86	2.12	17.69	9.79	1.01	88282.92
6	6.95	6.80	62.92	3.32	15.51	10.81	1.02	86458.05
7	3.85	7.39	51.27	1.76	17.41	10.40	1.02	84014.97
8	4.41	5.68	55.75	1.50	18.37	9.87	1.02	86873.16
9	2.16	1.07	56.56	2.40	16.89	10.26	1.02	84931.33
10	1.85	2.85	30.10	2.84	15.55	10.64	1.03	83296.39
11	2.31	4.73	41.26	2.46	16.41	10.78	1.06	81015.89
12	7.26	1.57	57.27	2.82	16.41	10.33	1.05	84895.77
13	9.57	1.32	53.90	2.59	16.95	10.19	1.04	85464.74
14	7.11	3.14	55.48	2.47	16.71	10.33	1.05	84682.60
15	2.97	4.73	51.21	2.33	16.04	10.62	1.06	83415.36
16	9.46	4.50	55.80	2.20	17.16	10.09	1.05	86425.80
17	9.67	3.91	61.42	2.24	16.13	10.39	1.05	85146.65
18	9.00	5.35	53.15	2.61	15.26	10.55	1.03	84953.87
19	9.15	4.30	57.99	2.91	14.63	10.76	1.03	83760.29
20	8.14	7.23	62.00	2.35	15.07	10.71	1.04	83645.82
21	9.78	6.03	49.05	1.96	15.90	10.41	1.04	85208.29
22	9.49	6.68	49.80	2.05	16.32	10.45	1.05	83768.83
23	9.07	6.98	59.33	2.20	16.25	10.48	1.05	83950.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.17	5.04	54.67	2.33	16.55	10.37	1.03	84887.54
最大值	9.78	8.35	66.21	3.32	19.54	10.81	1.07	88282.92
發生時間	21	4	2	6	1	6		5
最小值	1.85	1.07	30.10	1.41	14.63	9.79	0.99	81015.89
發生時間	10	9	10	1	19	5		11
零點偏移(率)	-0.02 %	-0.01 %	-0.18 %	-0.07 %		0.05		-0.20 %
全幅偏移(率)	0.04 %	0.18 %	0.00 %	0.02 %		-0.13		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.54	4.86	49.76	1.75	15.19	11.05	1.03	77541.17
1	6.61	5.23	51.55	1.49	17.32	10.74	1.05	80414.65
2	6.92	8.49	50.95	1.61	17.26	10.50	1.05	83589.00
3	7.63	4.80	55.09	2.05	15.50	11.02	1.05	79894.16
4	4.82	11.37	54.08	1.77	15.50	11.12	1.05	76651.92
5	6.81	6.30	46.41	2.00	16.65	10.26	1.05	81690.70
6	7.09	8.19	48.27	2.00	15.29	10.90	1.05	76507.06
7	5.42	10.67	52.21	1.16	17.69	10.52	1.05	78524.11
8	5.93	8.82	49.87	1.39	17.77	10.53	1.05	79273.21
9	6.13	7.42	47.79	1.45	16.83	10.60	1.05	80395.69
10	5.50	3.38	41.20	1.47	16.47	10.42	1.05	79766.45
11	5.51	3.86	43.86	1.61	16.59	10.49	1.03	76422.71
12	5.64	1.58	46.88	1.53	17.71	10.00	1.02	78329.49
13	2.82	1.62	51.39	1.20	16.71	10.44	1.02	75387.90
14	5.11	11.99	57.82	1.69	16.38	10.52	1.03	77851.30
15	7.81	3.78	52.13	1.55	16.47	10.74	1.04	81461.33
16	9.13	3.71	53.79	1.76	15.86	10.79	1.05	80455.63
17	10.56	5.59	50.03	2.50	14.19	10.98	1.04	77537.60
18	10.23	7.92	53.66	2.71	13.86	11.15	1.05	76098.68
19	10.38	6.95	50.72	3.12	12.86	11.32	1.05	74376.16
20	8.57	3.67	47.62	1.96	14.33	10.88	1.05	77079.79
21	9.10	2.94	55.44	1.58	15.91	10.27	1.05	78414.51
22	9.67	4.02	61.03	1.91	15.65	10.38	1.05	78027.76
23	8.87	2.98	52.60	1.93	15.23	10.64	1.05	76150.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.16	5.84	51.01	1.80	15.97	10.68	1.04	78410.05
最大值	10.56	11.99	61.03	3.12	17.77	11.32	1.06	83589.00
發生時間	17	14	22	19	8	19		2
最小值	2.82	1.58	41.20	1.16	12.86	10.00	1.02	74376.16
發生時間	13	12	10	7	19	12		19
零點偏移(率)	-0.05 %	0.00 %	-0.02 %	-0.05 %		0.02		0.00 %
全幅偏移(率)	0.04 %	-0.10 %	-0.29 %	0.15 %		0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								