

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年09月04日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.55	4.54	60.84	0.26	19.27	11.91	0.92	77271.77
1	2.41	5.18	41.74	1.00	19.95	10.91	0.92	84979.50
2	7.70	7.30	34.10	1.62	17.14	11.68	0.92	80771.00
3	7.77	8.00	42.01	2.46	15.19	12.07	0.90	75903.64
4	8.44	7.15	53.19	2.05	16.92	11.81	0.90	79203.39
5	8.94	8.09	35.32	2.47	15.63	12.02	0.91	80189.56
6	7.62	3.99	34.76	2.39	16.06	11.93	0.92	76968.58
7	5.92	2.77	41.65	1.14	17.75	11.67	0.92	79190.58
8	6.54	2.92	40.15	1.00	18.49	11.59	0.95	79945.02
9	5.90	2.70	42.19	0.90	18.33	11.42	0.95	81539.37
10	5.70	2.85	40.91	0.97	17.15	11.64	0.92	78387.16
11	1.81	3.49	33.13	0.83	17.03	11.68	0.92	78328.96
12	0.19	2.87	46.19	0.40	18.64	11.41	0.94	81037.71
13	0.46	2.87	53.00	0.52	18.36	11.71	0.94	78904.87
14	3.51	3.98	41.42	0.69	18.17	11.65	0.94	78792.74
15	2.79	4.99	52.94	0.54	18.47	11.63	0.95	79576.95
16	7.72	5.69	45.71	1.10	17.46	11.57	0.93	80907.06
17	8.79	5.02	49.17	1.40	17.31	11.77	0.92	79576.94
18	8.19	4.64	52.57	1.05	17.89	11.39	0.94	82441.20
19	8.89	4.42	52.57	0.94	17.95	11.33	0.95	82935.67
20	7.12	4.13	55.21	1.46	17.49	11.55	0.96	81716.53
21	6.31	3.00	52.95	1.75	17.85	11.39	0.95	82389.91
22	4.96	3.04	53.00	0.78	17.18	11.55	0.96	80643.51
23	3.41	3.52	44.84	0.96	16.47	11.76	0.96	79442.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.48	4.46	45.81	1.20	17.59	11.63	0.93	80043.49
最 大 值	8.94	8.09	60.84	2.47	19.95	12.07	0.97	84979.50
發生時間	5	5	0	5	1	3		1
最 小 值	0.19	2.70	33.13	0.26	15.19	10.91	0.90	75903.64
發生時間	12	9	11	0	3	1		3
零點偏移(率)	-0.13 %	-0.00 %	-0.07 %	0.00 %		-0.09		0.00 %
全幅偏移(率)	0.00 %	0.03 %	0.58 %	0.48 %		-0.19		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年09月04日

[illegible]