

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月11日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.14	6.80	60.80	1.08	16.08	11.63	1.02	82875.19
1	8.64	9.41	49.86	2.08	15.57	12.03	1.02	80001.08
2	10.40	7.69	43.61	1.98	15.97	11.49	1.02	84970.64
3	10.35	9.99	45.04	1.68	15.67	11.67	1.02	83459.18
4	9.97	8.40	47.82	2.12	14.96	12.02	1.02	81268.29
5	12.07	9.43	46.21	2.16	14.89	11.69	1.02	81098.63
6	9.88	9.40	42.42	2.42	14.31	11.90	1.02	82375.42
7	10.07	8.04	41.48	2.15	15.11	11.58	1.02	84260.55
8	9.58	7.29	43.72	1.85	15.20	11.61	1.02	84492.72
9	9.38	9.20	54.67	1.85	15.14	12.06	1.00	80133.31
10	9.29	7.51	50.21	1.29	15.81	11.56	0.98	84466.81
11	7.55	8.14	50.22	2.05	14.99	12.08	1.02	81383.29
12	9.06	7.04	46.59	3.05	14.10	12.03	0.98	84312.40
13	8.78	6.15	45.29	3.33	13.54	12.04	0.97	81724.48
14	9.58	6.69	51.67	0.98	15.42	11.79	0.97	83157.58
15	8.67	9.13	54.86	1.18	14.96	11.63	0.97	84718.24
16	6.91	11.32	62.22	0.82	15.23	12.02	0.98	80772.34
17	8.84	13.86	53.30	0.70	16.64	11.37	1.02	85317.48
18	8.45	12.83	67.89	0.59	16.71	11.69	1.02	82191.93
19	8.59	10.18	53.25	0.41	16.77	11.54	1.01	83766.32
20	10.23	6.97	37.68	1.27	16.97	11.33	0.99	84963.47
21	8.78	7.72	35.24	1.74	15.27	11.92	0.98	80915.49
22	9.58	6.24	43.35	1.63	15.41	11.80	0.98	82072.50
23	9.71	6.96	55.63	0.89	16.59	11.25	0.97	85760.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.31	8.60	49.29	1.64	15.47	11.74	1.00	82935.74
最 大 值	12.07	13.86	67.89	3.33	16.97	12.08	1.04	85760.51
發生時間	5	17	18	13	20	11		23
最 小 值	6.91	6.15	35.24	0.41	13.54	11.25	0.95	80001.08
發生時間	16	13	21	19	13	23		1
零點偏移(率)	-0.37 %	-0.01 %	-0.01 %	-0.01 %		-0.02		0.20 %
全幅偏移(率)	0.02 %	0.16 %	0.15 %	-0.16 %		0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.21	11.58	38.35	1.74	16.97	9.66	1.08	80645.71
1	3.27	5.14	41.18	1.25	15.49	10.33	1.05	74835.76
2	1.90	7.02	49.00	1.95	13.47	10.50	1.04	73946.64
3	6.37	4.76	55.11	2.29	14.02	10.31	1.05	77399.64
4	8.03	3.41	54.22	2.45	14.07	10.28	1.06	78138.95
5	2.81	3.90	56.18	2.39	12.63	10.78	1.05	74296.53
6	1.48	3.95	58.42	1.87	13.91	10.49	1.05	75681.75
7	1.90	3.49	47.80	1.84	13.42	10.89	1.06	76054.82
8	8.84	3.68	50.19	2.24	14.06	10.39	1.08	76562.94
9	9.74	3.84	55.09	2.64	13.20	11.14	1.06	73371.87
10	8.95	3.09	54.73	3.56	13.84	10.77	1.08	79529.70
11	5.66	3.46	48.69	2.58	13.88	10.66	1.07	76725.53
12	1.88	3.94	53.09	0.76	15.52	10.21	1.04	75994.65
13	2.33	4.11	49.94	1.57	13.56	10.53	1.06	75445.49
14	9.90	4.44	53.12	2.70	13.41	10.60	1.07	74628.87
15	4.21	3.60	55.89	2.34	12.42	11.05	1.06	73886.99
16	0.47	3.29	52.24	1.10	14.79	10.53	1.06	74952.11
17	2.31	4.84	59.15	0.61	16.17	10.19	1.07	85081.18
18	4.25	7.01	56.16	1.04	14.74	10.73	1.09	81164.51
19	9.03	2.83	62.35	1.13	17.01	9.96	1.09	83666.57
20	7.05	3.72	49.78	1.74	14.39	10.49	1.09	79211.24
21	1.53	3.50	65.21	1.01	14.64	11.12	1.09	74280.20
22	10.81	3.76	48.14	1.93	15.73	9.94	1.09	81474.73
23	9.81	6.72	58.79	1.68	14.97	10.46	1.08	81860.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.74	4.55	53.03	1.85	14.43	10.50	1.07	77451.54
最 大 值	15.21	11.58	65.21	3.56	17.01	11.14	1.10	85081.18
發生時間	0	0	21	10	19	9		17
最 小 值	0.47	2.83	38.35	0.61	12.42	9.66	1.04	73371.87
發生時間	16	19	0	17	15	0		9
零點偏移(率)	-0.01 %	-0.00 %	-0.33 %	-0.04 %		0.04		0.30 %
全幅偏移(率)	0.02 %	-1.15 %	0.23 %	-0.06 %		0.29		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								