

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.32	13.19	48.74	2.18	18.31	11.12	1.20	74166.47
1	6.58	11.44	61.32	2.42	19.24	10.90	1.20	74930.05
2	6.22	11.57	51.50	2.91	17.82	11.17	1.20	74102.67
3	11.02	12.24	60.35	3.45	16.40	11.94	1.21	69637.70
4	13.57	11.70	54.74	3.21	17.89	11.32	1.20	72733.54
5	7.75	11.59	49.67	2.13	16.94	11.19	1.18	75658.95
6	10.10	11.98	55.70	2.20	15.92	11.65	1.17	71680.17
7	12.04	11.92	55.76	1.97	16.29	11.73	1.18	71178.34
8	6.50	12.74	59.61	1.73	15.94	11.91	1.18	69789.72
9	2.22	11.73	56.48	0.94	17.44	11.39	1.14	72251.64
10	7.67	11.87	55.43	1.58	16.77	11.53	1.16	71727.01
11	12.29	12.55	55.94	3.75	16.83	12.06	1.17	67545.57
12	1.62	12.58	66.55	2.00	17.88	11.97	1.15	67671.12
13	10.04	11.57	53.79	2.96	17.43	11.24	1.13	73755.90
14	16.65	11.88	51.55	4.38	17.23	11.49	1.16	71821.55
15	3.99	12.15	57.63	5.76	17.42	11.65	1.16	70095.78
16	2.48	14.02	59.13	2.35	17.43	12.22	1.15	64879.25
17	3.74	14.17	53.99	2.47	18.06	10.74	1.15	75632.66
18	9.87	12.48	58.99	3.59	18.02	11.33	1.15	72141.72
19	1.61	11.72	57.79	1.97	18.21	11.22	1.15	72709.04
20	1.48	12.58	59.11	1.96	16.87	12.00	1.17	67802.64
21	5.28	12.40	52.03	1.69	17.65	11.55	1.16	71168.61
22	5.14	12.26	64.42	1.14	18.71	11.14	1.13	73063.62
23	5.03	12.92	41.00	1.42	18.22	11.02	1.13	74383.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.18	12.30	55.88	2.51	17.45	11.48	1.17	71688.62
最大值	16.65	14.17	66.55	5.76	19.24	12.22	1.21	75658.95
發生時間	14	17	12	15	1	16		5
最小值	1.48	11.44	41.00	0.94	15.92	10.74	1.13	64879.25
發生時間	20	1	23	9	6	17		16
零點偏移(率)	-0.20 %	0.01 %	-0.04 %	-0.06 %		-0.12	-0.01	0.20 %
全幅偏移(率)	0.69 %	-1.95 %	-0.27 %	-1.61 %		-0.06	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.45	13.40	61.62	1.42	19.20	10.41	1.06	82043.98
1	13.29	11.93	53.83	2.02	19.38	10.39	1.06	81390.38
2	4.34	11.92	55.10	1.23	19.50	10.36	1.06	80602.86
3	10.19	12.25	51.07	0.89	20.55	9.80	1.06	82076.31
4	17.58	11.45	57.28	1.29	20.02	9.85	1.06	81440.89
5	10.85	11.59	50.28	1.50	19.55	10.01	1.06	82031.69
6	7.17	11.84	54.05	0.87	18.97	10.10	1.02	82784.39
7	12.25	11.52	58.57	1.29	18.86	10.12	1.02	78733.57
8	11.42	11.44	60.86	0.84	19.80	9.89	1.02	81160.23
9	9.74	12.31	58.84	1.18	19.11	10.55	1.03	73958.31
10	12.33	12.50	51.63	0.96	18.79	10.30	1.02	75929.78
11	11.84	11.91	52.32	0.89	19.34	9.90	1.02	78754.35
12	11.42	11.40	55.74	0.68	20.58	9.48	1.02	80114.25
13	12.48	11.96	39.06	1.48	20.21	9.50	1.02	79727.40
14	9.18	12.04	48.11	1.07	19.61	10.20	1.02	74107.85
15	6.45	11.71	54.72	0.58	19.94	10.09	1.03	76954.05
16	9.29	11.81	67.62	0.54	20.23	10.19	1.04	77421.78
17	8.76	12.09	49.29	0.76	20.18	10.41	1.04	79244.86
18	12.37	12.60	64.46	1.48	19.07	10.33	1.04	84210.84
19	8.54	12.27	51.62	0.92	19.01	10.62	1.02	75633.68
20	4.96	11.86	61.19	0.56	21.23	9.38	1.02	79075.31
21	6.85	14.16	48.64	0.77	19.97	10.44	1.02	74142.80
22	10.24	13.80	38.72	0.74	20.81	9.86	1.02	82519.85
23	7.39	12.70	52.92	0.42	20.38	10.30	1.03	75959.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.02	12.19	54.06	1.02	19.76	10.10	1.03	79167.44
最大值	17.58	14.16	67.62	2.02	21.23	10.62	1.06	84210.84
發生時間	4	21	16	1	20	19		18
最小值	4.34	11.40	38.72	0.42	18.79	9.38	1.02	73958.31
發生時間	2	12	22	23	10	20		9
零點偏移(率)	-0.06 %	0.00 %	-0.04 %	-0.00 %		-0.10	-0.01	0.00 %
全幅偏移(率)	1.76 %	1.23 %	-0.04 %	1.70 %		-0.07	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.20	12.69	60.22	2.91	17.92	9.92	1.36	74084.68
1	8.29	11.46	64.87	3.10	19.16	9.95	1.36	74482.90
2	7.93	11.44	65.94	2.87	18.15	9.90	1.36	75410.04
3	7.92	11.43	62.69	2.92	16.46	10.23	1.36	74778.75
4	9.44	11.18	62.65	3.10	16.56	9.87	1.36	74027.18
5	9.07	11.55	54.64	2.89	17.73	9.49	1.36	74630.70
6	8.86	11.43	52.59	3.02	18.74	9.35	1.37	75838.21
7	9.01	10.93	52.96	3.17	16.41	9.76	1.39	77290.57
8	6.46	11.09	57.18	3.01	16.13	9.95	1.37	72975.40
9	5.71	11.23	56.89	2.80	16.73	9.86	1.38	72780.51
10	6.89	11.59	53.10	2.96	17.81	9.53	1.38	75731.84
11	6.38	11.02	56.39	2.75	17.11	9.78	1.39	72805.61
12	6.15	10.99	54.20	2.63	18.14	9.43	1.39	73595.25
13	5.81	10.99	54.26	2.71	17.63	9.63	1.38	73672.74
14	5.72	11.57	54.44	2.66	17.87	9.91	1.36	73628.41
15	5.78	11.79	50.98	2.72	18.86	9.72	1.36	74219.56
16	5.70	11.35	51.56	2.77	19.79	9.38	1.39	74702.13
17	5.12	11.39	49.02	2.50	17.43	9.78	1.39	74149.85
18	5.36	11.59	49.34	2.59	18.24	9.64	1.37	73120.64
19	5.28	12.15	48.01	2.67	17.09	9.62	1.35	71129.78
20	5.53	14.70	37.64	2.76	18.91	8.99	1.35	71747.58
21	4.96	13.20	35.75	2.27	17.93	9.46	1.38	65830.99
22	5.26	11.92	38.31	2.40	18.05	9.61	1.37	66645.53
23	5.40	11.41	48.17	2.67	18.35	9.57	1.34	71007.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.68	11.67	52.99	2.79	17.80	9.68	1.37	73261.95
最大值	9.44	14.70	65.94	3.17	19.79	10.23	1.42	77290.57
發生時間	4	20	2	7	16	3		7
最小值	4.96	10.93	35.75	2.27	16.13	8.99	1.34	65830.99
發生時間	21	7	21	21	8	20		21
零點偏移(率)	-0.04 %	0.01 %	-0.04 %	0.00 %		-0.11	-0.01	0.00 %
全幅偏移(率)	-1.19 %	-2.64 %	-0.25 %	-1.65 %		0.27	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								