

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.13	7.22	57.99	0.40	20.78	10.89	1.10	75487.56
1	9.17	8.27	49.33	0.70	20.52	11.19	1.08	73116.90
2	8.13	7.91	45.39	0.45	20.98	10.68	1.05	76847.57
3	9.53	8.55	37.87	0.92	19.75	10.85	1.04	76878.11
4	9.32	7.78	41.74	0.90	19.87	10.78	1.03	76976.56
5	8.69	11.63	51.70	0.61	19.86	10.74	1.04	77949.88
6	9.54	11.46	49.01	1.02	19.54	10.91	1.03	76444.25
7	9.30	9.40	53.38	0.89	19.68	11.06	1.05	74986.87
8	9.46	8.50	45.96	1.01	19.36	10.86	1.05	76636.79
9	校正	校正	校正	校正	替代	校正	1.09	79156.62
10	6.83	9.25	51.90	1.12	18.48	11.38	1.07	72989.61
11	9.03	7.44	51.04	1.04	19.64	10.93	1.09	75119.02
12	9.75	7.31	53.79	0.86	20.08	10.85	1.06	76315.06
13	8.15	7.88	48.22	0.65	20.21	10.85	1.07	76347.48
14	10.38	8.70	34.16	1.82	19.30	10.78	1.06	77540.45
15	8.07	10.15	37.87	1.88	18.85	11.22	1.05	74708.04
16	7.61	7.26	43.31	1.48	18.95	11.00	1.07	76053.23
17	9.33	7.27	55.18	1.25	18.97	11.07	1.08	75541.48
18	7.16	8.46	62.43	0.54	20.50	10.97	1.09	74920.56
19	7.50	8.80	55.40	0.61	20.64	10.70	1.08	77097.30
20	9.71	13.11	50.67	0.91	20.57	10.49	1.06	78324.88
21	9.51	6.94	39.70	1.66	19.33	10.58	1.06	78237.35
22	8.53	5.78	52.13	0.76	20.22	10.62	1.07	77800.66
23	9.75	5.97	45.42	1.06	19.24	10.75	1.07	77865.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平均值	8.59	8.48	48.42	0.98	19.80	10.88	1.06	76389.24
最大值	10.38	13.11	62.43	1.88	20.98	11.38	1.10	79156.62
發生時間	14	20	18	15	2	10		9
最小值	3.13	5.78	34.16	0.40	18.48	10.49	1.02	72989.61
發生時間	0	22	14	0	10	20		10
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.01 %	-1.61 %	0.56 %	0.00 %		0.04		0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.37	4.42	66.72	1.79	17.11	11.58	1.03	75793.93
1	4.31	4.16	50.59	1.37	18.99	10.72	1.05	81698.39
2	8.85	4.80	57.24	2.34	17.48	10.64	1.05	83900.79
3	7.54	2.86	54.45	2.61	16.89	10.54	1.05	84816.60
4	7.08	7.91	58.85	2.70	16.17	10.72	1.05	83550.33
5	9.39	6.95	59.75	2.60	16.23	10.82	1.05	82604.30
6	7.97	5.72	50.59	2.01	16.27	10.80	1.05	84793.01
7	7.53	3.60	54.00	2.54	16.59	10.61	1.06	84156.19
8	7.54	3.18	59.03	2.32	16.78	10.97	1.08	80667.99
9	2.04	3.74	50.35	2.43	16.83	10.47	1.06	84681.29
10	3.46	7.64	55.59	1.90	17.43	10.49	1.09	83700.28
11	5.41	14.81	60.23	1.62	18.26	10.41	1.10	83537.54
12	6.23	19.08	60.13	1.94	17.23	10.57	1.08	82751.12
13	4.85	13.84	63.10	1.47	18.29	11.03	1.08	79700.37
14	7.16	13.08	54.71	0.96	20.50	9.52	1.07	88506.94
15	6.03	13.97	51.50	1.92	18.10	10.17	1.07	85285.34
16	3.14	7.18	64.25	1.24	18.44	10.15	1.09	85042.71
17	4.29	1.58	36.42	1.78	17.13	10.25	1.10	85710.21
18	4.54	4.46	54.98	2.41	17.20	10.46	1.07	83787.08
19	0.55	3.98	31.52	1.30	18.55	10.66	1.07	81406.88
20	3.26	5.70	34.54	2.52	18.12	9.93	1.08	87786.18
21	7.49	7.33	59.93	3.20	16.37	10.54	1.08	84364.68
22	6.84	3.88	53.31	3.22	16.71	10.51	1.06	84380.24
23	8.77	4.41	50.21	2.43	18.08	10.15	1.05	85692.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.69	7.01	53.83	2.11	17.49	10.53	1.07	83679.80
最大值	9.39	19.08	66.72	3.22	20.50	11.58	1.12	88506.94
發生時間	5	12	0	22	14	0		14
最小值	0.55	1.58	31.52	0.96	16.17	9.52	1.02	75793.93
發生時間	19	17	19	14	4	14		0
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	-0.07 %		0.03		-0.20 %
全幅偏移(率)	0.90 %	0.56 %	-0.70 %	0.09 %		-0.30		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.08	2.58	45.10	1.08	16.62	10.86	0.96	78563.84
1	7.34	3.13	59.75	1.04	18.46	10.34	0.94	82629.90
2	9.50	5.77	45.58	1.32	15.53	11.10	0.95	79251.67
3	7.77	3.10	51.73	1.20	16.61	10.76	0.95	79973.88
4	5.55	4.36	48.89	1.53	15.08	11.05	0.94	77208.82
5	4.54	3.30	55.86	1.23	15.68	11.00	0.94	77850.47
6	5.47	5.55	48.02	1.26	16.32	10.60	0.95	79908.93
7	8.55	4.14	47.57	1.83	15.75	10.80	0.94	79768.81
8	8.06	4.82	44.96	1.62	15.08	10.99	0.95	76831.19
9	8.05	4.17	48.81	1.33	15.48	10.90	0.96	78321.07
10	5.04	3.52	49.16	1.19	15.21	10.96	0.95	76705.25
11	4.40	3.44	50.92	1.01	15.97	10.90	0.95	77537.74
12	6.06	6.17	43.13	1.12	16.01	10.54	0.94	79366.35
13	8.72	9.23	46.51	1.88	14.71	11.01	0.95	72709.92
14	8.25	2.12	46.81	0.97	15.95	10.64	0.94	75632.49
15	5.47	2.59	43.87	1.21	15.67	10.80	0.93	74557.85
16	5.92	5.11	47.31	1.03	15.77	10.69	0.95	77748.41
17	6.21	8.21	47.81	1.38	14.97	10.95	0.94	76496.91
18	7.21	4.20	49.91	0.84	17.44	10.37	0.94	79649.66
19	8.07	2.09	48.66	1.23	16.89	10.60	0.92	78188.57
20	8.80	2.39	44.01	1.24	16.64	10.64	0.93	79504.03
21	6.60	6.35	44.09	1.10	16.39	10.30	0.93	75728.83
22	8.34	8.56	38.95	1.06	16.33	10.11	0.92	75566.09
23	9.05	7.95	43.29	1.80	14.70	10.62	0.94	72873.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.09	4.70	47.53	1.27	15.97	10.73	0.94	77607.28
最大值	9.50	9.23	59.75	1.88	18.46	11.10	0.98	82629.90
發生時間	2	13	1	13	1	2		1
最小值	4.40	2.09	38.95	0.84	14.70	10.11	0.91	72709.92
發生時間	11	19	22	18	23	22		13
零點偏移(率)	-0.02 %	-0.08 %	-0.03 %	-0.04 %		0.00		0.00 %
全幅偏移(率)	0.02 %	-0.10 %	-0.36 %	0.04 %		0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								