

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月17日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.75	4.38	58.55	1.02	16.81	11.68	1.10	77681.57
1	3.59	4.86	57.56	1.10	17.17	11.72	1.10	79804.23
2	7.85	7.01	31.79	1.46	18.68	10.83	1.07	85822.83
3	8.60	4.74	30.53	2.08	16.09	11.36	1.06	82741.29
4	9.56	4.17	37.65	2.02	16.11	11.78	1.06	80378.70
5	10.08	7.03	45.39	3.00	16.12	11.60	1.02	84169.64
6	9.47	5.52	37.87	1.42	17.18	11.46	1.02	81887.77
7	10.38	5.24	42.62	1.82	16.64	11.84	1.02	79274.92
8	9.82	6.26	42.46	1.94	16.52	11.49	1.02	81465.05
9	9.70	8.24	60.09	1.60	16.48	11.59	1.05	81436.05
10	9.52	7.84	53.40	2.40	15.54	11.59	1.03	80760.21
11	9.42	7.68	52.98	1.84	16.23	11.53	1.06	80105.55
12	8.98	9.44	60.09	2.01	15.72	11.97	1.04	76651.56
13	8.59	8.11	61.11	1.90	15.82	11.93	1.04	78091.13
14	7.07	7.94	58.56	1.80	15.76	11.82	1.05	78067.04
15	9.58	7.76	62.83	1.50	16.79	11.57	1.04	80449.45
16	9.45	6.00	50.99	1.62	15.90	11.60	1.06	80609.57
17	9.46	5.88	54.33	1.13	17.22	11.34	1.06	82535.45
18	8.75	6.04	60.33	0.89	17.67	11.37	1.05	82359.30
19	9.93	5.95	51.60	1.55	16.60	11.43	1.02	82244.14
20	10.28	6.44	60.06	1.27	16.86	11.57	1.05	81305.81
21	9.17	6.17	54.35	1.30	16.73	11.59	1.06	81306.08
22	8.57	6.33	55.54	1.20	16.84	11.59	1.04	81787.82
23	8.53	6.73	62.07	1.80	15.71	12.29	1.02	76740.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.92	6.49	51.78	1.65	16.55	11.61	1.05	80736.47
最 大 值	10.38	9.44	62.83	3.00	18.68	12.29	1.13	85822.83
發生時間	7	12	15	5	2	23		2
最 小 值	3.59	4.17	30.53	0.89	15.54	10.83	1.02	76651.56
發生時間	1	4	3	18	10	2		12
零點偏移(率)	0.00 %	-0.09 %	-0.07 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.01 %	0.00 %		0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月17日

報表日期: 113年03月17日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.74	3.38	43.27	0.79	17.13	10.62	1.13	80282.06
1	6.48	3.53	44.59	0.74	17.09	10.80	1.13	78740.47
2	9.08	3.84	42.20	1.07	18.18	10.49	1.13	81207.17
3	9.86	3.56	41.19	1.58	16.61	10.65	1.13	81494.46
4	8.75	3.93	40.69	1.18	16.73	10.82	1.13	80154.97
5	8.70	6.46	35.90	1.40	17.26	10.37	1.13	82356.55
6	9.65	4.81	41.50	1.14	17.60	10.31	1.13	81775.84
7	10.90	6.55	66.79	1.53	16.94	10.82	1.10	78072.40
8	10.34	5.34	62.06	1.47	16.61	10.72	1.10	79805.63
9	10.18	5.20	53.69	1.82	15.78	10.60	1.10	80823.52
10	8.54	8.71	56.40	1.72	15.60	10.67	1.10	79830.53
11	10.01	6.58	59.61	1.54	17.73	10.45	1.10	81641.49
12	10.69	10.07	50.41	2.40	16.05	10.47	1.10	81062.97
13	8.06	4.39	54.30	2.08	14.60	10.90	1.09	75700.25
14	12.11	3.98	56.85	2.73	15.04	10.81	1.10	75227.79
15	8.03	3.89	63.34	1.25	16.69	10.52	1.08	75744.27
16	9.71	5.68	56.16	1.73	15.30	10.70	1.09	75351.45
17	8.48	5.94	54.26	1.30	16.66	10.42	1.09	77799.96
18	8.68	6.05	57.70	1.38	16.34	10.50	1.09	77435.09
19	12.58	9.14	54.73	1.76	16.22	10.76	1.09	78594.01
20	8.45	6.02	54.11	1.04	16.99	10.66	1.09	80540.96
21	9.72	6.54	54.49	1.57	15.45	10.91	1.08	79751.17
22	6.40	7.33	57.68	1.55	15.19	11.29	1.09	77073.35
23	4.25	6.48	47.39	1.57	15.80	11.39	1.09	75158.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.06	5.73	52.05	1.51	16.40	10.69	1.10	78984.38
最 大 值	12.58	10.07	66.79	2.73	18.18	11.39	1.14	82356.55
發生時間	19	12	7	14	2	23		5
最 小 值	4.25	3.38	35.90	0.74	14.60	10.31	1.06	75158.77
發生時間	23	0	5	1	13	6		23
零點偏移(率)	-0.07 %	-0.05 %	-0.02 %	0.01 %		-0.02		0.00 %
全幅偏移(率)	0.02 %	0.11 %	-0.25 %	-0.03 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								