

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月09日

報表日期: 114年03月09日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 7.24     | 4.85     | 55.56    | 0.86     | 18.19    | 11.43    | 1.29     | 81495.80  |
| 1                 | 7.99     | 5.13     | 56.80    | 1.08     | 18.39    | 11.26    | 1.29     | 82617.46  |
| 2                 | 11.32    | 4.96     | 59.11    | 1.19     | 18.96    | 11.12    | 1.29     | 83073.92  |
| 3                 | 10.04    | 4.66     | 59.06    | 1.18     | 18.95    | 10.95    | 1.29     | 84695.31  |
| 4                 | 8.30     | 4.84     | 56.68    | 0.99     | 18.93    | 10.97    | 1.29     | 85093.24  |
| 5                 | 14.42    | 5.61     | 56.73    | 1.38     | 19.02    | 10.53    | 1.29     | 90378.87  |
| 6                 | 9.09     | 3.04     | 56.82    | 1.66     | 17.62    | 11.43    | 1.29     | 82053.72  |
| 7                 | 9.35     | 2.56     | 51.77    | 1.94     | 16.56    | 11.57    | 1.29     | 82097.23  |
| 8                 | 8.46     | 3.14     | 57.00    | 2.23     | 15.59    | 11.79    | 1.30     | 80177.66  |
| 9                 | 7.09     | 4.56     | 56.54    | 1.29     | 17.95    | 11.52    | 1.33     | 79961.24  |
| 10                | 8.85     | 6.52     | 50.87    | 1.59     | 17.76    | 11.15    | 1.32     | 83450.50  |
| 11                | 9.47     | 6.84     | 57.47    | 0.96     | 18.73    | 11.12    | 1.29     | 83370.92  |
| 12                | 12.63    | 7.78     | 49.27    | 1.94     | 17.24    | 11.32    | 1.29     | 83063.00  |
| 13                | 6.55     | 4.44     | 53.09    | 1.50     | 17.17    | 11.45    | 1.29     | 82404.72  |
| 14                | 11.34    | 4.34     | 56.42    | 1.60     | 16.85    | 11.58    | 1.29     | 81511.61  |
| 15                | 6.11     | 6.94     | 61.49    | 1.52     | 16.90    | 11.83    | 1.29     | 79361.19  |
| 16                | 11.67    | 6.75     | 55.00    | 0.93     | 19.72    | 10.87    | 1.30     | 85015.27  |
| 17                | 5.49     | 3.21     | 54.69    | 1.25     | 18.08    | 11.40    | 1.33     | 81876.58  |
| 18                | 11.47    | 3.33     | 54.59    | 1.38     | 17.45    | 11.51    | 1.34     | 81631.33  |
| 19                | 7.87     | 3.66     | 53.47    | 1.71     | 17.09    | 11.40    | 1.34     | 81552.95  |
| 20                | 10.44    | 2.86     | 53.97    | 1.75     | 17.11    | 11.49    | 1.34     | 78574.13  |
| 21                | 11.07    | 3.31     | 54.24    | 1.70     | 17.19    | 11.56    | 1.34     | 78510.50  |
| 22                | 7.31     | 6.00     | 50.00    | 1.49     | 17.31    | 11.28    | 1.34     | 81349.28  |
| 23                | 11.46    | 3.05     | 45.41    | 1.74     | 16.47    | 11.49    | 1.32     | 81738.74  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 9.38     | 4.68     | 54.84    | 1.45     | 17.72    | 11.33    | 1.31     | 82293.97  |
| 最 大 值             | 14.42    | 7.78     | 61.49    | 2.23     | 19.72    | 11.83    | 1.34     | 90378.87  |
| 發生時間              | 5        | 12       | 15       | 8        | 16       | 15       |          | 5         |
| 最 小 值             | 5.49     | 2.56     | 45.41    | 0.86     | 15.59    | 10.53    | 1.28     | 78510.50  |
| 發生時間              | 17       | 7        | 23       | 0        | 8        | 5        |          | 21        |
| 零點偏移(率)           | -0.09 %  | 0.01 %   | -0.02 %  | 0.00 %   |          | -0.12    |          | 0.30 %    |
| 全幅偏移(率)           | -0.25 %  | 0.89 %   | 0.16 %   | -0.19 %  |          | -0.35    |          | 0.40 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月09日

| 項目<br>單位<br>小時\限標 | #2-HCl_C<br>ppm | #2-CO_C<br>ppm | #2-NOx_C<br>ppm | #2-SO2_C<br>ppm | #2-H2O<br>% | #2-O2_C<br>% | #2-OPAC<br>% | #2-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 9.44            | 2.57           | 56.01           | 1.60            | 16.75       | 10.88        | 1.10         | 80749.01             |
| 1                 | 8.76            | 3.26           | 51.39           | 2.57            | 15.74       | 10.96        | 1.10         | 80967.67             |
| 2                 | 8.52            | 2.39           | 62.06           | 2.27            | 16.81       | 11.17        | 1.10         | 80509.07             |
| 3                 | 8.65            | 2.67           | 58.71           | 2.14            | 16.79       | 11.11        | 1.11         | 80367.10             |
| 4                 | 10.40           | 6.53           | 58.85           | 1.75            | 18.08       | 10.54        | 1.12         | 84522.39             |
| 5                 | 8.71            | 6.65           | 53.73           | 2.48            | 17.75       | 10.42        | 1.13         | 86434.93             |
| 6                 | 0.13            | 2.26           | 59.62           | 3.17            | 15.05       | 11.19        | 1.11         | 83136.58             |
| 7                 | 1.39            | 2.01           | 59.82           | 2.76            | 14.75       | 11.17        | 1.11         | 80149.78             |
| 8                 | 9.69            | 2.15           | 60.13           | 2.51            | 16.11       | 11.10        | 1.13         | 78453.26             |
| 9                 | 10.15           | 2.18           | 60.66           | 2.27            | 16.32       | 10.95        | 1.14         | 80575.64             |
| 10                | 9.86            | 2.32           | 65.46           | 1.95            | 17.25       | 10.71        | 1.12         | 83474.69             |
| 11                | 9.45            | 2.79           | 57.36           | 2.34            | 17.04       | 10.62        | 1.10         | 85447.64             |
| 12                | 9.20            | 2.88           | 62.79           | 2.17            | 16.79       | 11.14        | 1.10         | 81314.45             |
| 13                | 9.90            | 2.88           | 55.94           | 2.11            | 17.34       | 10.69        | 1.10         | 84200.27             |
| 14                | 8.11            | 6.46           | 56.93           | 2.91            | 15.81       | 10.83        | 1.09         | 83811.28             |
| 15                | 7.87            | 2.38           | 55.44           | 2.74            | 15.61       | 11.13        | 1.09         | 79083.13             |
| 16                | 10.15           | 2.10           | 58.39           | 2.11            | 16.24       | 11.27        | 1.10         | 79917.98             |
| 17                | 9.56            | 2.68           | 59.80           | 2.18            | 16.41       | 11.40        | 1.11         | 79119.16             |
| 18                | 10.12           | 3.79           | 53.93           | 2.09            | 17.59       | 10.50        | 1.13         | 84290.37             |
| 19                | 8.61            | 1.43           | 55.97           | 2.77            | 16.03       | 10.80        | 1.13         | 83091.63             |
| 20                | 6.58            | 1.86           | 58.17           | 2.64            | 14.99       | 11.41        | 1.13         | 78848.42             |
| 21                | 10.60           | 2.41           | 58.87           | 2.41            | 16.13       | 11.31        | 1.10         | 79537.02             |
| 22                | 9.77            | 2.97           | 54.57           | 2.35            | 16.62       | 10.72        | 1.10         | 82426.84             |
| 23                | 7.08            | 4.20           | 55.00           | 2.66            | 15.26       | 11.01        | 1.10         | 79388.03             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 8.45            | 3.08           | 57.90           | 2.37            | 16.39       | 10.96        | 1.11         | 81659.01             |
| 最 大 值             | 10.60           | 6.65           | 65.46           | 3.17            | 18.08       | 11.41        | 1.16         | 86434.93             |
| 發生時間              | 21              | 5              | 10              | 6               | 4           | 20           |              | 5                    |
| 最 小 值             | 0.13            | 1.43           | 51.39           | 1.60            | 14.75       | 10.42        | 1.09         | 78453.26             |
| 發生時間              | 6               | 19             | 1               | 0               | 7           | 5            |              | 8                    |
| 零點偏移(率)           | -0.02 %         | -0.00 %        | -0.01 %         | -0.02 %         |             | -0.05        |              | 0.10 %               |
| 全幅偏移(率)           | 0.14 %          | -0.14 %        | -0.09 %         | 0.04 %          |             | 0.02         |              | 0.10 %               |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |

## P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月09日

| 項目<br>單位<br>小時\限標 | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 6.16     | 1.71     | 62.45    | 0.61     | 16.30    | 11.07    | 1.54     | 79976.29  |
| 1                 | 9.23     | 3.77     | 48.84    | 3.30     | 18.91    | 10.13    | 1.54     | 82977.19  |
| 2                 | 2.74     | 1.63     | 49.88    | 0.36     | 17.14    | 11.01    | 1.53     | 75921.16  |
| 3                 | 10.83    | 4.63     | 53.62    | 0.84     | 17.17    | 10.90    | 1.55     | 78950.40  |
| 4                 | 12.09    | 6.05     | 49.53    | 0.78     | 16.53    | 10.55    | 1.55     | 81201.15  |
| 5                 | 8.27     | 6.95     | 44.47    | 0.49     | 18.24    | 10.12    | 1.55     | 82010.84  |
| 6                 | 12.87    | 4.06     | 48.50    | 0.89     | 16.06    | 10.63    | 1.55     | 78911.29  |
| 7                 | 4.22     | 2.77     | 52.21    | 0.70     | 15.53    | 10.88    | 1.53     | 83470.37  |
| 8                 | 12.76    | 4.67     | 50.65    | 0.93     | 16.01    | 10.65    | 1.51     | 80032.69  |
| 9                 | 10.29    | 5.65     | 47.98    | 0.96     | 16.56    | 10.49    | 1.52     | 81128.57  |
| 10                | 11.26    | 3.24     | 58.66    | 0.50     | 18.24    | 10.46    | 1.52     | 82875.06  |
| 11                | 11.84    | 2.02     | 60.71    | 0.53     | 17.58    | 10.78    | 1.52     | 80806.18  |
| 12                | 5.28     | 3.20     | 56.71    | 0.77     | 16.30    | 10.95    | 1.52     | 80400.84  |
| 13                | 10.30    | 5.94     | 61.19    | 0.83     | 17.01    | 10.99    | 1.52     | 80430.70  |
| 14                | 10.49    | 3.28     | 61.67    | 0.86     | 16.40    | 11.21    | 1.52     | 79105.30  |
| 15                | 9.56     | 5.93     | 61.06    | 1.21     | 15.53    | 11.37    | 1.52     | 78325.26  |
| 16                | 9.79     | 2.04     | 60.08    | 0.45     | 18.59    | 10.75    | 1.52     | 80078.82  |
| 17                | 8.25     | 2.59     | 61.45    | 0.68     | 16.56    | 11.21    | 1.52     | 78695.76  |
| 18                | 10.80    | 8.03     | 55.00    | 1.21     | 16.20    | 11.07    | 1.52     | 79119.14  |
| 19                | 10.38    | 3.27     | 58.13    | 0.85     | 16.13    | 11.42    | 1.52     | 76471.22  |
| 20                | 7.05     | 4.41     | 58.52    | 0.63     | 15.66    | 11.52    | 1.52     | 76888.53  |
| 21                | 11.25    | 5.01     | 58.38    | 0.82     | 16.42    | 11.30    | 1.52     | 77713.87  |
| 22                | 7.77     | 3.06     | 62.03    | 0.67     | 16.63    | 11.37    | 1.52     | 76969.27  |
| 23                | 11.40    | 3.58     | 55.20    | 0.66     | 16.13    | 11.25    | 1.52     | 76061.86  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 9.37     | 4.06     | 55.71    | 0.86     | 16.74    | 10.92    | 1.53     | 79521.74  |
| 最 大 值             | 12.87    | 8.03     | 62.45    | 3.30     | 18.91    | 11.52    | 1.59     | 83470.37  |
| 發生時間              | 6        | 18       | 0        | 1        | 1        | 20       |          | 7         |
| 最 小 值             | 2.74     | 1.63     | 44.47    | 0.36     | 15.53    | 10.12    | 1.50     | 75921.16  |
| 發生時間              | 2        | 2        | 5        | 2        | 7        | 5        |          | 2         |
| 零點偏移(率)           | -0.05 %  | -0.01 %  | -0.04 %  | -0.00 %  |          | -0.14    |          | -0.10 %   |
| 全幅偏移(率)           | 0.48 %   | 0.31 %   | 0.31 %   | -0.49 %  |          | -0.18    |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |