

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月17日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月17日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.59	3.72	53.74	2.11	15.87	10.72	1.06	81324.84
1	9.23	6.02	50.66	2.07	17.49	10.24	1.06	83664.10
2	9.79	3.99	42.40	2.35	15.43	10.35	1.07	81447.23
3	9.02	2.38	54.28	2.01	15.69	10.58	1.09	82637.63
4	8.77	1.92	58.27	1.79	16.00	10.40	1.09	83428.31
5	9.06	3.45	55.80	1.59	17.05	10.05	1.07	84819.85
6	7.27	1.55	54.83	1.37	15.99	10.97	1.10	87424.31
7	4.97	2.73	46.57	2.42	14.88	11.45	1.10	80970.20
8	6.72	2.62	68.41	1.43	16.58	11.05	1.10	82751.50
9	6.48	2.51	62.41	2.45	15.51	11.21	1.07	80653.46
10	6.67	9.44	63.66	2.15	15.98	11.04	1.10	87316.70
11	8.16	11.61	63.21	2.80	15.80	10.91	1.10	85847.64
12	8.78	13.35	66.74	2.49	15.94	11.10	1.10	81180.62
13	8.42	8.67	58.13	1.74	16.17	10.95	1.10	80718.24
14	9.45	8.99	62.66	2.02	15.96	10.91	1.10	80704.94
15	8.98	4.32	62.56	1.74	16.55	10.36	1.10	84609.65
16	8.99	5.60	41.16	1.88	17.18	9.97	1.10	84525.09
17	7.98	1.46	40.53	1.48	16.78	10.23	1.09	84818.99
18	9.09	1.82	45.90	2.26	16.54	10.44	1.10	84110.42
19	10.01	6.94	50.79	1.86	18.33	9.80	1.10	89987.30
20	9.72	8.37	51.45	2.43	17.51	9.79	1.10	88062.81
21	9.39	4.94	53.96	3.65	16.17	10.54	1.10	83272.12
22	9.06	4.79	49.74	2.54	17.31	10.23	1.10	83956.83
23	8.58	7.97	53.47	1.35	19.18	9.51	1.10	84801.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.47	5.38	54.64	2.08	16.50	10.53	1.09	83876.41
最 大 值	10.01	13.35	68.41	3.65	19.18	11.45	1.11	89987.30
發生時間	19	12	8	21	23	7		19
最 小 值	4.97	1.46	40.53	1.35	14.88	9.51	1.06	80653.46
發生時間	7	17	17	23	7	23		9
零點偏移(率)	-0.05 %	-0.00 %	-0.07 %	-0.00 %		0.01		0.10 %
全幅偏移(率)	0.14 %	0.58 %	-0.84 %	0.44 %		-0.04		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月17日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.47	5.11	59.82	1.32	17.41	9.81	1.58	81497.01
1	9.24	6.16	63.47	1.83	18.36	9.86	1.59	83383.42
2	6.01	4.18	53.34	1.92	16.96	8.93	1.60	77362.85
3	10.24	5.17	53.96	2.46	15.73	9.43	1.60	77704.18
4	11.69	8.89	52.16	1.84	18.69	9.09	1.58	83999.84
5	8.41	4.66	55.02	1.85	16.64	9.67	1.57	83368.82
6	5.47	3.57	44.85	1.20	15.80	10.25	1.58	77857.31
7	7.11	3.70	54.19	1.58	16.70	9.95	1.55	80296.18
8	7.50	4.10	56.63	1.74	17.17	9.51	1.57	79822.87
9	8.25	7.46	47.46	1.80	15.67	9.82	1.56	77741.17
10	7.04	4.50	55.89	1.61	17.14	9.82	1.53	79566.28
11	6.15	8.79	50.19	2.27	14.23	10.23	1.58	77759.84
12	2.30	1.90	54.75	1.38	15.90	10.07	1.53	77145.09
13	0.91	2.92	60.66	1.45	15.39	10.47	1.53	74117.55
14	0.87	9.70	54.23	1.06	17.73	9.45	1.52	79434.10
15	6.38	11.53	56.18	1.98	15.49	9.91	1.52	80088.27
16	10.11	2.92	50.76	1.80	16.90	9.38	1.52	80133.96
17	5.32	2.93	44.55	1.43	16.51	9.38	1.52	79752.23
18	2.06	2.79	49.15	1.13	16.59	9.54	1.58	78273.77
19	0.81	1.37	51.88	0.80	17.37	9.64	1.58	81236.38
20	4.06	4.22	49.03	1.50	16.92	9.18	1.55	83335.47
21	7.74	5.83	53.78	1.96	17.30	9.14	1.52	82518.37
22	8.74	1.44	56.89	2.02	17.54	9.48	1.53	77427.62
23	6.18	2.20	59.34	1.48	18.15	9.42	1.56	80661.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.21	4.84	53.67	1.64	16.76	9.64	1.56	79770.16
最 大 值	11.69	11.53	63.47	2.46	18.69	10.47	1.62	83999.84
發生時間	4	15	1	3	4	13		4
最 小 值	0.81	1.37	44.55	0.80	14.23	8.93	1.52	74117.55
發生時間	19	19	17	19	11	2		13
零點偏移(率)	-0.02 %	-0.04 %	-0.02 %	0.00 %		0.03		-0.10 %
全幅偏移(率)	0.02 %	0.27 %	-0.31 %	0.14 %		0.46		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								