

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.64	12.57	53.51	1.85	18.74	11.09	1.25	72824.34
1	10.97	12.89	56.02	2.03	19.11	11.30	1.25	71685.48
2	10.67	12.90	58.30	2.60	17.33	11.24	1.25	73857.49
3	13.60	13.44	53.36	1.98	18.19	11.44	1.25	71891.45
4	12.95	12.91	56.24	2.35	18.00	11.10	1.25	74332.44
5	7.84	11.96	51.78	2.65	17.91	11.10	1.25	77170.24
6	8.83	12.16	59.88	2.51	17.74	11.19	1.25	73874.49
7	8.93	11.94	56.35	2.42	17.61	11.28	1.25	73071.57
8	8.84	11.68	58.64	2.05	18.43	11.13	1.25	73349.76
9	8.72	11.60	57.18	2.14	18.63	10.94	1.23	74112.77
10	10.04	11.63	57.47	1.83	19.54	10.84	1.24	74303.68
11	10.29	12.23	53.33	2.70	18.58	10.92	1.23	74401.07
12	9.23	11.77	53.88	3.28	16.61	11.60	1.21	71224.27
13	6.86	12.08	53.57	2.23	16.42	11.64	1.21	71601.32
14	8.27	13.29	51.27	2.30	16.10	11.65	1.23	71598.92
15	8.81	13.37	52.88	2.61	14.74	12.13	1.23	69122.65
16	6.72	12.93	49.98	1.54	18.29	11.12	1.23	74139.36
17	6.48	12.00	42.82	1.59	18.09	11.11	1.23	73736.98
18	6.29	12.30	42.78	1.69	18.08	11.01	1.22	74982.36
19	6.36	13.27	44.45	2.19	16.52	11.31	1.23	73609.03
20	6.77	12.42	45.50	2.23	16.37	11.38	1.23	73677.39
21	6.81	13.41	50.67	2.43	15.97	11.34	1.24	73938.20
22	7.79	13.60	52.21	2.33	16.83	11.36	1.25	73058.89
23	9.01	11.95	47.82	2.07	19.01	11.18	1.25	73133.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.74	12.51	52.50	2.23	17.62	11.27	1.24	73279.06
最大值	13.60	13.60	59.88	3.28	19.54	12.13	1.26	77170.24
發生時間	3	22	6	12	10	15		5
最小值	6.29	11.60	42.78	1.54	14.74	10.84	1.20	69122.65
發生時間	18	9	18	16	15	10		15
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	-0.00 %		-0.10	-0.01	0.20 %
全幅偏移(率)	-0.17 %	0.86 %	-0.13 %	0.25 %		-0.03	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.34	11.98	45.55	0.96	17.96	9.92	0.94	72073.19
1	9.47	13.65	60.47	1.44	17.85	11.56	0.94	63605.42
2	8.52	12.74	58.50	0.86	18.15	10.64	0.94	75189.34
3	11.28	12.69	61.33	0.98	17.63	10.73	0.94	77531.06
4	10.74	12.28	52.13	0.94	17.33	10.64	0.94	76604.18
5	10.76	13.01	61.52	1.28	17.72	10.64	0.94	80166.60
6	7.40	12.24	59.21	0.58	18.21	10.74	0.94	81258.47
7	7.63	12.46	56.48	1.44	17.65	10.96	0.94	79818.98
8	7.58	12.67	60.05	1.48	18.11	10.49	0.95	80663.56
9	7.40	11.69	50.47	1.33	17.47	10.49	0.96	77742.01
10	7.85	12.08	62.22	1.10	17.23	10.78	0.99	79260.92
11	7.41	12.33	55.24	1.55	16.79	10.78	0.98	78245.55
12	7.37	12.20	49.63	1.38	16.44	10.53	0.97	72976.62
13	6.96	12.45	41.43	1.43	16.80	10.28	0.96	74404.37
14	6.78	11.37	42.40	1.69	16.56	10.17	0.98	72976.52
15	6.86	11.52	39.81	1.40	16.83	10.28	0.96	70524.60
16	6.73	12.02	38.91	1.54	16.57	10.12	0.95	73106.14
17	6.70	11.48	45.70	1.06	17.01	9.99	0.94	73738.48
18	6.73	11.60	33.48	1.36	17.49	9.82	0.94	75162.50
19	7.08	11.78	42.63	1.04	17.92	10.27	0.95	74374.65
20	6.92	11.52	49.18	1.11	16.92	10.27	0.95	78069.90
21	6.95	11.46	47.24	0.89	16.57	10.36	0.94	76155.15
22	6.99	12.32	51.04	2.16	17.35	10.32	0.94	77755.00
23	7.54	13.23	50.27	1.76	18.32	9.98	0.94	81358.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.83	12.20	50.62	1.28	17.37	10.45	0.95	75948.42
最大值	11.28	13.65	62.22	2.16	18.32	11.56	1.01	81358.98
發生時間	3	1	10	22	23	1		23
最小值	6.70	11.37	33.48	0.58	16.44	9.82	0.93	63605.42
發生時間	17	14	18	6	12	18		1
零點偏移(率)	-0.11 %	-0.01 %	-0.03 %	-0.00 %		-0.10	-0.01	-0.10 %
全幅偏移(率)	1.16 %	-0.51 %	0.50 %	0.10 %		-0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.94	11.64	53.95	2.99	18.64	9.22	1.33	72345.25
1	6.96	11.98	54.48	2.01	20.70	9.08	1.35	73300.88
2	9.04	11.99	60.01	2.10	20.06	9.23	1.36	74346.62
3	11.33	13.53	61.07	3.19	19.16	9.68	1.36	72714.09
4	10.25	13.54	52.29	3.03	18.07	9.34	1.39	73196.22
5	9.92	12.75	41.33	2.48	20.13	8.36	1.37	69913.69
6	6.52	11.33	52.24	1.87	18.33	9.28	1.39	74102.29
7	2.20	11.23	50.29	3.30	18.87	9.06	1.37	74508.05
8	2.55	11.42	49.55	2.76	19.18	8.83	1.35	71330.59
9	3.67	12.66	41.66	2.57	20.01	8.36	1.36	71843.48
10	3.23	10.65	54.34	3.08	19.57	8.95	1.34	72808.21
11	3.33	10.80	59.54	3.14	19.10	9.27	1.38	73610.03
12	3.04	10.85	58.93	3.10	18.38	9.44	1.37	72210.05
13	4.90	10.90	59.32	2.25	17.57	9.47	1.37	71641.59
14	8.95	11.07	56.16	2.53	17.72	9.31	1.36	71586.40
15	10.27	11.13	57.36	2.44	17.01	9.68	1.32	72208.88
16	7.99	11.36	53.90	2.33	16.51	9.63	1.36	73391.91
17	8.16	11.52	50.80	2.25	17.04	9.49	1.36	72092.79
18	7.09	11.49	45.26	2.17	17.69	9.11	1.36	71843.58
19	7.49	11.21	42.27	2.28	18.57	8.91	1.33	73316.87
20	7.98	12.27	40.41	2.42	17.94	8.93	1.32	73375.14
21	7.94	12.35	47.07	3.11	16.82	9.33	1.36	74244.15
22	9.92	10.85	56.79	2.48	17.60	9.45	1.37	74042.25
23	6.35	10.93	53.11	3.11	19.84	9.06	1.38	74987.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.08	11.64	52.17	2.62	18.52	9.19	1.36	72873.36
最大值	11.33	13.54	61.07	3.30	20.70	9.68	1.40	74987.55
發生時間	3	4	3	7	1	3		23
最小值	2.20	10.65	40.41	1.87	16.51	8.36	1.31	69913.69
發生時間	7	10	20	6	16	5		5
零點偏移(率)	-0.09 %	0.00 %	-0.01 %	0.00 %		-0.12	-0.01	0.00 %
全幅偏移(率)	1.60 %	-0.21 %	-0.23 %	0.09 %		0.26	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								