

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.70	6.48	67.74	1.52	16.18	11.74	1.03	81123.84
1	7.66	7.27	67.93	0.98	18.36	11.24	1.03	82968.69
2	8.38	6.57	44.12	1.68	16.48	11.23	1.04	85109.73
3	10.37	8.42	60.77	3.31	14.91	11.55	1.03	83765.06
4	9.48	7.41	69.60	1.31	17.10	11.68	1.02	81036.54
5	8.72	8.66	60.15	2.49	14.56	11.63	1.02	87435.66
6	10.24	7.63	57.55	2.62	15.24	11.71	1.03	82000.81
7	10.81	6.19	57.24	2.00	16.00	11.49	1.03	83125.16
8	5.06	7.29	53.50	0.81	16.41	12.00	1.05	78311.70
9	8.71	8.08	50.47	1.19	16.50	11.06	1.06	86118.55
10	5.13	9.79	43.76	2.36	14.68	11.71	1.04	82234.48
11	2.01	7.70	44.58	1.55	15.42	11.80	1.05	81333.99
12	5.68	10.35	42.79	1.77	15.45	11.95	1.04	79936.97
13	2.55	7.02	47.31	1.13	15.48	11.89	1.04	80215.60
14	6.13	9.48	45.96	2.15	15.10	11.65	1.02	82056.87
15	7.07	4.70	51.64	3.19	14.39	12.28	1.06	77537.25
16	5.77	8.28	61.69	2.06	15.17	12.55	1.05	74935.40
17	1.70	9.06	64.15	1.68	14.85	13.09	1.05	70562.94
18	2.81	6.72	54.74	0.61	16.64	12.19	1.06	76861.61
19	5.66	5.22	39.35	0.75	17.07	11.10	1.06	85958.87
20	8.59	4.86	36.45	1.03	16.98	11.10	1.06	85968.76
21	7.40	5.30	68.48	0.89	16.24	12.03	1.06	78318.15
22	4.23	10.31	68.06	1.58	14.58	13.77	1.14	65160.47
23	3.19	7.40	60.26	0.91	15.73	13.16	1.08	69537.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.50	7.51	54.93	1.65	15.81	11.90	1.05	80067.28
最大值	10.81	10.35	69.60	3.31	18.36	13.77	1.21	87435.66
發生時間	7	12	4	3	1	22		5
最小值	1.70	4.70	36.45	0.61	14.39	11.06	1.01	65160.47
發生時間	17	15	20	18	15	9		22
零點偏移(率)	-0.03 %	-0.01 %	-0.03 %	0.00 %		-0.04		0.10 %
全幅偏移(率)	0.00 %	-0.34 %	-0.50 %	-0.02 %		0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.61	6.47	71.16	3.54	13.91	12.40	1.06	70779.57
1	3.94	1.39	54.87	2.84	15.94	11.48	1.05	77790.70
2	7.75	3.34	58.78	3.22	14.52	11.56	1.04	78047.34
3	10.33	7.81	65.64	2.32	15.93	11.29	1.05	78910.27
4	15.68	9.35	42.08	4.28	14.30	11.49	1.05	78557.46
5	12.13	8.90	48.24	3.77	13.91	11.72	1.04	76864.89
6	6.47	6.75	50.55	1.69	16.37	11.18	1.05	78226.23
7	9.42	3.27	63.93	2.80	14.20	12.03	1.05	74423.63
8	9.95	8.52	41.99	2.01	16.31	11.26	1.06	78106.36
9	8.91	8.38	41.75	1.96	15.87	11.00	1.07	79653.26
10	6.98	10.59	39.42	2.82	13.34	11.58	1.09	75479.03
11	3.20	9.14	38.84	2.25	14.36	11.52	1.06	75647.49
12	4.40	8.71	38.95	2.22	14.05	11.62	1.06	74568.65
13	4.31	9.14	41.95	2.18	14.29	11.83	1.06	75541.75
14	7.25	9.06	55.82	2.89	14.16	11.73	1.06	76320.25
15	3.94	10.60	67.81	1.77	14.41	12.23	1.06	72131.79
16	5.46	10.72	57.42	1.72	15.14	11.64	1.06	76830.34
17	4.72	9.75	46.27	1.77	15.57	11.28	1.06	79532.65
18	2.03	9.55	59.94	1.65	15.40	12.10	1.04	73253.69
19	0.44	11.19	55.51	1.13	16.45	11.34	1.04	78651.65
20	3.93	11.73	42.18	1.98	14.93	11.46	1.05	78143.64
21	0.91	9.19	59.62	1.15	16.27	11.72	1.05	74718.50
22	0.20	10.51	53.93	1.27	16.35	11.64	1.04	75760.20
23	2.49	8.80	44.11	1.22	17.14	10.92	1.06	81265.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.85	8.45	51.70	2.27	15.13	11.58	1.05	76633.55
最大值	15.68	11.73	71.16	4.28	17.14	12.40	1.10	81265.89
發生時間	4	20	0	4	23	0		23
最小值	0.20	1.39	38.84	1.13	13.34	10.92	1.03	70779.57
發生時間	22	1	11	19	10	23		0
零點偏移(率)	-0.06 %	-0.00 %	-0.04 %	-0.01 %		-0.01		-0.10 %
全幅偏移(率)	0.14 %	0.13 %	0.13 %	0.05 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.87	4.20	63.56	1.03	15.90	10.51	1.03	75625.78
1	4.23	4.10	64.12	0.77	16.65	10.76	1.04	73853.95
2	0.92	3.82	64.39	1.00	14.98	10.78	1.04	74767.61
3	2.46	3.21	65.44	0.94	14.87	10.79	1.04	76705.79
4	0.08	3.09	71.32	1.18	14.53	10.84	1.01	75842.35
5	2.02	3.38	64.31	1.61	13.73	11.08	1.02	75181.16
6	3.55	5.32	56.77	1.91	13.51	10.93	1.02	75729.14
7	3.48	5.82	56.94	1.13	14.27	11.21	1.03	74991.24
8	4.94	5.38	51.62	2.01	13.24	11.22	1.04	73873.35
9	9.05	5.50	50.59	1.72	14.50	10.88	1.04	76122.50
10	2.90	5.55	56.68	0.96	14.81	10.91	1.07	76864.08
11	1.29	6.66	46.62	1.19	14.26	10.90	1.08	75278.99
12	3.94	7.92	47.52	0.65	15.58	10.85	1.07	76771.09
13	3.92	5.84	46.61	0.91	14.85	11.01	1.06	77822.23
14	3.67	5.53	54.92	0.58	15.73	11.22	1.04	76581.02
15	3.57	5.27	53.11	1.01	14.89	11.11	1.04	78857.81
16	3.79	6.87	53.61	0.82	15.78	10.89	1.02	79167.94
17	3.73	6.86	56.32	0.86	15.12	11.35	1.04	75142.37
18	3.81	7.57	58.15	0.69	15.58	11.61	1.04	74687.05
19	3.38	7.82	54.77	0.43	17.61	10.13	1.04	83871.71
20	4.53	4.31	48.32	0.64	15.96	10.66	1.04	81315.42
21	5.82	5.22	51.65	0.67	16.13	10.83	1.04	79255.01
22	3.99	4.59	54.50	0.44	16.52	11.00	1.04	78208.21
23	5.21	5.13	58.33	0.84	15.61	11.33	1.04	76458.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.71	5.37	56.26	1.00	15.19	10.95	1.04	76790.60
最大值	9.05	7.92	71.32	2.01	17.61	11.61	1.11	83871.71
發生時間	9	12	4	8	19	18		19
最小值	0.08	3.09	46.61	0.43	13.24	10.13	0.99	73853.95
發生時間	4	4	13	19	8	19		1
零點偏移(率)	-0.06 %	-0.01 %	-0.06 %	0.00 %		-0.04		0.20 %
全幅偏移(率)	0.00 %	0.03 %	-0.18 %	0.44 %		0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								