

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.63	7.85	64.31	0.98	15.71	12.39	1.06	76328.09
1	7.19	7.52	45.28	0.85	18.21	11.45	1.06	82256.41
2	9.73	6.93	36.90	1.86	15.37	11.57	1.04	83838.26
3	12.87	6.98	48.52	2.43	15.02	11.77	1.04	82595.60
4	11.16	7.18	53.57	2.15	15.36	11.79	1.04	81782.13
5	10.61	4.10	55.90	1.73	15.71	11.38	1.02	83450.83
6	9.82	5.11	47.26	1.57	16.06	11.55	1.02	82782.98
7	8.59	5.06	48.55	1.43	16.29	11.50	1.02	83964.84
8	6.56	5.96	69.81	1.10	15.60	12.34	1.04	77068.83
9	8.10	5.76	35.50	0.96	16.28	12.08	1.02	78486.13
10	6.43	9.36	54.65	1.68	14.57	13.34	1.02	68432.98
11	8.60	5.34	42.59	1.45	15.52	12.38	1.04	76397.34
12	9.44	7.79	50.73	1.46	14.96	12.78	1.05	73335.67
13	9.70	4.98	50.11	1.15	15.58	12.06	1.06	79293.82
14	9.73	5.46	36.71	2.04	14.71	12.01	1.06	80164.19
15	8.93	6.98	66.03	1.41	15.79	12.11	1.07	78795.98
16	9.82	6.88	46.46	1.46	16.28	11.59	1.08	82609.50
17	9.94	8.62	57.70	1.22	16.77	11.24	1.06	85104.25
18	7.86	7.49	60.87	1.43	15.48	11.69	1.06	82497.32
19	10.49	6.88	59.10	1.64	15.64	11.51	1.06	83654.09
20	9.58	8.02	51.70	1.88	15.27	11.66	1.04	82434.46
21	9.42	6.58	54.36	1.95	15.65	11.50	1.04	83608.51
22	9.43	7.12	50.57	2.14	14.69	11.82	1.02	81508.62
23	8.09	7.37	61.11	1.46	15.40	11.98	1.02	79831.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.11	6.72	52.01	1.56	15.66	11.90	1.04	80425.91
最大值	12.87	9.36	69.81	2.43	18.21	13.34	1.09	85104.25
發生時間	3	10	8	3	1	10		17
最小值	6.43	4.10	35.50	0.85	14.57	11.24	1.02	68432.98
發生時間	10	5	9	1	10	17		10
零點偏移(率)	-0.09 %	-0.03 %	-0.03 %	-0.03 %		-0.05		0.10 %
全幅偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.55	4.28	43.87	1.73	16.01	11.53	1.02	77188.10
1	2.60	5.81	41.65	2.04	16.63	10.97	1.00	80865.21
2	5.45	2.66	58.73	3.05	13.89	11.64	1.00	78130.20
3	8.06	1.85	43.42	2.85	15.00	11.49	1.02	78843.07
4	6.08	1.63	43.31	2.80	14.12	11.83	1.02	76441.28
5	5.84	5.44	54.34	3.51	14.24	11.80	1.01	76360.66
6	5.03	5.82	54.20	3.26	15.05	11.51	0.95	77467.92
7	5.43	3.89	48.26	2.71	15.85	11.25	0.97	79333.79
8	7.22	3.59	48.55	2.44	15.83	11.42	0.98	78401.22
9	6.64	4.25	52.31	2.54	15.01	11.63	0.97	77386.36
10	4.86	5.41	52.27	2.34	15.88	11.88	0.98	74701.13
11	1.32	3.90	62.85	1.39	16.98	12.21	1.02	71118.01
12	0.16	4.06	42.66	0.95	18.58	10.81	1.02	79969.08
13	0.32	3.97	38.72	1.95	16.38	11.11	1.02	79667.91
14	2.26	3.29	42.25	2.01	16.36	11.11	1.02	79143.42
15	5.46	7.76	49.73	1.80	17.20	10.93	1.02	80387.89
16	11.09	4.57	50.87	2.94	15.86	10.83	1.02	82146.33
17	6.29	2.45	63.70	1.75	17.07	11.00	1.02	79585.27
18	9.72	3.47	45.28	2.40	17.32	10.28	1.00	85862.28
19	6.30	5.90	49.41	1.94	17.84	10.37	0.99	84072.03
20	9.60	4.67	50.24	2.24	17.27	10.49	0.99	83773.33
21	9.20	3.62	50.35	2.34	16.96	10.68	0.99	82629.57
22	4.31	2.33	52.46	2.38	14.99	11.37	0.99	78775.12
23	6.09	4.41	58.40	2.04	16.94	10.93	1.00	80420.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.50	4.13	49.91	2.31	16.14	11.21	1.00	79277.89
最大值	11.09	7.76	63.70	3.51	18.58	12.21	1.02	85862.28
發生時間	16	15	17	5	12	11		18
最小值	0.16	1.63	38.72	0.95	13.89	10.28	0.94	71118.01
發生時間	12	4	13	12	2	18		11
零點偏移(率)	-0.12 %	-0.06 %	-0.03 %	0.00 %		-0.01		-0.10 %
全幅偏移(率)	0.14 %	-0.01 %	0.12 %	0.12 %		-0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.40	2.02	57.98	0.79	15.86	11.27	1.10	77005.95
1	1.31	1.95	49.83	0.84	15.85	11.73	1.10	73274.80
2	3.09	3.02	46.48	2.33	12.93	11.88	1.10	73998.66
3	6.58	2.62	48.21	1.94	14.26	11.52	1.10	75955.30
4	4.63	5.06	40.53	1.23	16.02	10.78	1.09	80573.58
5	6.10	2.68	40.57	1.00	16.56	10.61	1.09	81324.22
6	6.43	2.02	42.01	0.82	17.29	10.39	1.09	82276.07
7	8.54	6.02	54.08	0.84	16.96	10.67	1.09	81510.74
8	6.01	9.17	44.19	0.82	16.98	10.45	1.09	80295.25
9	9.78	5.93	50.45	0.81	17.93	10.46	1.09	79570.10
10	2.37	6.48	44.51	0.33	17.28	10.83	1.09	77790.53
11	0.88	10.32	52.91	0.48	16.54	11.85	1.09	71465.05
12	1.30	8.95	57.64	0.31	18.42	11.43	1.10	72949.76
13	2.72	7.02	40.39	0.75	16.27	10.40	1.09	80661.49
14	6.48	8.12	45.09	1.61	14.05	11.19	1.09	73226.02
15	5.77	7.08	54.08	1.50	15.12	10.83	1.09	74559.63
16	6.47	5.24	59.02	0.83	16.96	10.18	1.09	79383.91
17	7.26	5.04	43.10	1.20	15.68	10.33	1.09	77890.46
18	6.83	4.50	45.75	0.86	15.97	10.29	1.09	78166.17
19	8.04	4.78	46.37	0.88	16.07	10.21	1.09	78176.70
20	4.46	4.59	47.34	0.49	16.83	10.20	1.10	77918.43
21	3.68	4.78	47.11	0.39	17.72	9.95	1.10	79745.44
22	3.03	2.70	43.11	0.59	16.07	10.27	1.10	77489.81
23	2.24	4.46	46.88	0.51	16.15	10.61	1.09	73396.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.81	5.19	47.82	0.92	16.24	10.76	1.09	77441.86
最大值	9.78	10.32	59.02	2.33	18.42	11.88	1.12	82276.07
發生時間	9	11	16	2	12	2		6
最小值	0.88	1.95	40.39	0.31	12.93	9.95	1.08	71465.05
發生時間	11	1	13	12	2	21		11
零點偏移(率)	-0.05 %	0.01 %	-0.02 %	-0.01 %		-0.05		0.20 %
全幅偏移(率)	0.40 %	0.10 %	-0.21 %	0.21 %		-0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								