

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.22	13.23	55.31	1.15	17.90	11.38	1.19	73148.81
1	2.38	13.20	62.19	0.81	18.52	11.48	1.20	72023.13
2	6.01	12.80	46.78	1.93	17.67	11.24	1.18	74664.69
3	6.97	12.81	57.74	2.42	17.22	11.34	1.18	74477.81
4	9.67	12.89	59.78	3.20	16.80	11.41	1.18	74011.65
5	7.25	12.68	54.93	2.32	18.42	11.03	1.18	76141.69
6	11.08	12.80	59.70	2.80	18.90	11.11	1.18	74966.32
7	15.08	12.85	58.03	2.78	18.00	11.27	1.18	74639.83
8	14.14	12.71	57.84	3.06	17.63	11.23	1.20	75640.97
9	14.84	12.72	58.83	2.91	17.71	11.22	1.23	75247.77
10	13.59	12.87	59.42	3.91	16.96	11.42	1.23	74294.73
11	8.25	12.90	50.75	2.18	17.76	11.21	1.23	75207.51
12	5.00	13.09	56.90	2.09	17.46	11.29	1.22	74748.85
13	12.00	13.24	60.09	3.17	16.95	11.36	1.20	74540.68
14	13.60	11.70	59.19	3.18	17.18	11.44	1.20	73746.03
15	13.72	12.21	54.19	3.67	16.40	11.82	1.19	72926.59
16	12.85	11.64	59.51	3.70	18.03	11.29	1.19	74841.63
17	2.51	11.77	48.56	1.57	16.04	11.51	1.18	74497.06
18	3.96	11.94	60.86	1.04	18.31	10.92	1.18	76856.89
19	3.05	11.71	60.79	1.40	17.12	11.46	1.20	73744.92
20	2.18	11.48	59.32	3.37	17.43	11.11	1.20	75620.20
21	3.15	11.68	67.00	2.75	18.07	11.32	1.20	73200.48
22	4.14	14.24	48.02	4.06	16.24	11.56	1.20	72820.54
23	6.07	14.81	53.55	3.38	17.41	11.67	1.21	70569.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.32	12.67	57.05	2.62	17.51	11.34	1.20	74274.11
最大值	15.08	14.81	67.00	4.06	18.90	11.82	1.23	76856.89
發生時間	7	23	21	22	6	15		18
最小值	2.18	11.48	46.78	0.81	16.04	10.92	1.18	70569.96
發生時間	20	20	2	1	17	18		23
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	-0.00 %		-0.10	-0.01	0.20 %
全幅偏移(率)	1.49 %	-1.05 %	-0.24 %	-1.68 %		-0.16	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.15	12.41	67.48	1.01	18.89	10.87	1.06	78387.87
1	6.90	12.09	56.12	1.70	18.98	10.45	1.05	82185.84
2	7.43	12.70	59.92	1.03	17.84	11.23	1.06	75575.04
3	6.45	11.92	49.16	1.40	18.10	10.55	1.04	78768.42
4	9.04	11.81	58.64	1.34	18.26	10.44	1.04	79837.11
5	9.47	12.31	61.73	1.96	17.63	10.70	1.05	81483.59
6	12.72	12.21	57.15	1.02	17.31	10.92	1.06	77359.34
7	13.40	12.25	53.13	0.88	18.20	10.50	1.06	82817.44
8	10.25	13.22	62.70	1.24	17.63	10.90	1.06	81425.09
9	8.64	13.32	48.96	1.42	17.16	10.89	1.06	80404.11
10	10.76	13.57	49.15	1.08	16.98	11.07	1.06	78308.76
11	11.21	13.23	60.26	1.31	17.25	10.79	1.06	79395.46
12	10.34	13.77	57.21	1.27	17.01	11.22	1.06	78426.02
13	10.63	13.15	43.65	1.61	17.14	10.70	1.04	78851.14
14	7.71	13.56	54.80	1.16	17.83	10.74	1.04	80568.67
15	12.02	12.72	51.44	2.20	16.80	11.08	1.03	79977.08
16	11.16	12.35	50.96	0.84	19.06	10.49	1.03	82083.52
17	9.77	12.01	52.45	0.71	20.54	10.04	1.04	83407.89
18	10.23	12.91	59.42	1.45	19.52	10.13	1.04	83836.85
19	11.20	12.04	52.52	1.26	21.12	9.65	1.04	85009.40
20	8.73	12.95	37.99	1.63	18.93	10.27	1.04	81172.10
21	10.65	12.21	61.77	1.92	17.52	10.83	1.04	79890.16
22	9.49	14.29	54.57	1.28	18.94	10.42	1.06	79571.90
23	8.34	15.06	50.98	2.09	18.03	10.61	1.06	79445.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.82	12.84	54.67	1.37	18.19	10.65	1.05	80341.19
最大值	13.40	15.06	67.48	2.20	21.12	11.23	1.07	85009.40
發生時間	7	23	0	15	19	2		19
最小值	6.45	11.81	37.99	0.71	16.80	9.65	1.02	75575.04
發生時間	3	4	20	17	15	19		2
零點偏移(率)	-0.11 %	0.01 %	-0.06 %	-0.00 %		-0.09	-0.01	0.10 %
全幅偏移(率)	0.02 %	1.61 %	0.01 %	1.66 %		-0.03	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.51	11.65	52.21	2.89	18.26	9.95	1.36	76372.24
1	8.88	12.21	64.67	3.17	21.03	9.43	1.36	77426.93
2	8.33	11.04	58.48	3.08	18.85	9.58	1.36	76451.78
3	8.41	11.06	58.39	3.12	19.08	9.63	1.36	77017.70
4	8.13	11.54	56.91	2.98	17.66	9.87	1.36	76160.23
5	8.49	11.23	56.32	3.05	18.43	9.70	1.36	75316.37
6	8.66	11.44	54.72	3.16	18.33	9.73	1.36	75480.94
7	7.42	11.30	60.35	3.22	17.67	9.95	1.37	80667.45
8	9.62	11.91	56.15	3.18	16.87	9.97	1.38	76741.73
9	9.82	11.56	59.32	3.23	16.41	10.15	1.36	76432.05
10	9.01	11.40	60.25	3.03	16.38	10.25	1.36	75858.23
11	9.03	11.40	63.06	2.92	17.57	10.13	1.36	75898.41
12	9.44	11.52	61.46	2.88	17.47	9.99	1.39	76202.87
13	10.48	12.45	62.14	2.94	18.16	9.99	1.39	75977.94
14	8.74	11.71	55.64	3.02	18.65	9.77	1.37	77633.78
15	7.92	11.33	60.30	2.96	18.52	9.92	1.37	77044.47
16	8.23	11.26	58.69	2.91	18.42	9.67	1.36	77168.49
17	8.10	11.20	59.84	2.84	17.24	9.70	1.36	75767.54
18	8.02	11.37	65.10	2.89	17.80	9.93	1.37	75626.14
19	8.10	11.42	59.02	2.97	17.84	9.79	1.36	76683.86
20	8.31	11.48	61.35	3.01	18.29	9.85	1.36	76514.87
21	8.91	11.71	62.15	3.11	17.35	10.26	1.36	75869.51
22	8.15	13.62	59.59	2.87	17.67	9.65	1.37	73696.85
23	9.56	13.50	50.91	2.97	18.85	9.01	1.36	73777.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.68	11.68	59.04	3.02	18.03	9.83	1.37	76324.49
最大值	10.48	13.62	65.10	3.23	21.03	10.26	1.40	80667.45
發生時間	13	22	18	9	1	21		7
最小值	7.42	11.04	50.91	2.84	16.38	9.01	1.35	73696.85
發生時間	7	2	23	17	10	23		22
零點偏移(率)	-0.02 %	-0.02 %	-0.01 %	-0.00 %		-0.10	-0.01	0.00 %
全幅偏移(率)	-1.28 %	-0.15 %	0.13 %	-1.64 %		0.28	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								