

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.90	5.79	61.99	1.94	18.47	11.88	1.43	71062.94
1	7.98	5.56	49.10	2.15	17.88	11.83	1.41	71871.68
2	10.94	8.73	46.58	2.68	16.38	12.10	1.42	70880.88
3	9.94	6.40	52.13	2.47	16.85	12.00	1.41	71890.62
4	10.14	6.54	51.86	2.62	16.31	12.09	1.42	71270.52
5	6.52	4.88	45.18	2.54	16.29	12.04	1.40	71310.15
6	10.24	3.95	58.15	2.38	17.72	12.03	1.41	70798.36
7	10.25	8.92	51.66	2.44	17.39	12.01	1.41	71219.10
8	5.44	3.79	56.11	2.30	17.39	12.19	1.41	70855.54
9	10.19	4.56	50.60	2.32	17.67	12.05	1.41	71183.81
10	11.06	7.06	51.05	2.68	16.68	12.28	1.43	70096.28
11	8.46	6.44	51.31	2.38	17.38	12.11	1.45	70510.89
12	6.42	3.90	56.93	2.34	17.54	12.35	1.48	68705.42
13	3.94	3.41	52.35	2.10	18.02	11.84	1.46	72437.61
14	3.96	5.36	49.78	2.37	16.49	12.04	1.46	71564.22
15	1.22	7.54	52.66	2.63	15.79	12.39	1.47	69962.16
16	0.08	5.23	63.41	2.41	16.88	12.60	1.47	67603.49
17	0.06	4.54	58.80	2.11	17.12	12.01	1.42	72035.68
18	0.92	6.45	48.73	2.36	16.50	12.13	1.41	71032.36
19	0.56	2.26	60.83	2.06	17.90	12.16	1.42	70008.79
20	1.18	0.69	51.63	2.07	17.76	11.87	1.41	72212.59
21	0.95	1.30	51.74	1.97	18.35	11.66	1.43	73214.63
22	1.47	0.87	48.92	2.13	17.63	12.00	1.45	71562.39
23	2.69	0.84	57.20	2.13	17.97	12.12	1.45	70767.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.35	4.79	53.28	2.32	17.27	12.07	1.43	71002.42
最大值	11.06	8.92	63.41	2.68	18.47	12.60	1.54	73214.63
發生時間	10	7	16	2	0	16		21
最小值	0.06	0.69	45.18	1.94	15.79	11.66	1.38	67603.49
發生時間	17	20	5	0	15	21		16
零點偏移(率)	-0.01 %	-0.05 %	-0.01 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.89 %	0.03 %	-0.35 %	0.03 %		0.12	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.41	2.75	50.02	2.11	15.67	10.98	1.41	64612.18
1	10.05	3.26	48.35	2.07	16.23	10.68	1.41	63840.10
2	10.20	8.09	49.76	2.43	14.79	10.83	1.41	63932.09
3	10.55	2.57	48.54	2.57	15.03	10.89	1.41	62191.71
4	8.39	4.60	47.94	2.33	14.71	10.67	1.41	60978.80
5	10.48	3.20	46.74	2.33	15.58	10.27	1.41	62399.72
6	4.01	7.31	41.67	2.32	14.20	10.64	1.41	56621.46
7	11.27	4.03	43.09	2.34	15.19	10.47	1.40	62358.47
8	10.24	4.06	45.02	2.12	15.93	10.62	1.41	62793.11
9	10.53	3.03	47.04	2.16	15.91	10.78	1.42	64012.57
10	10.14	3.36	47.84	2.22	15.24	10.77	1.43	62760.68
11	7.65	1.64	52.72	1.70	17.36	10.76	1.44	60255.81
12	8.55	1.81	48.59	1.65	17.51	10.41	1.45	62980.48
13	5.92	3.41	47.40	1.77	16.26	10.76	1.44	63062.88
14	1.76	4.96	51.98	2.04	13.78	10.95	1.44	60960.88
15	1.31	3.29	58.97	2.12	13.52	11.16	1.44	61499.02
16	1.35	2.28	57.48	2.02	14.27	11.11	1.41	62275.83
17	1.74	2.50	56.19	1.99	13.97	10.84	1.38	62015.11
18	2.39	3.69	53.60	1.85	15.19	10.67	1.39	62358.04
19	0.44	0.79	53.70	1.75	15.36	10.78	1.39	61527.23
20	2.94	0.42	49.85	1.76	16.31	10.81	1.38	62604.68
21	2.21	0.52	57.70	1.62	16.51	10.89	1.38	64118.62
22	6.45	0.55	54.97	1.99	15.70	10.95	1.39	64051.56
23	10.32	0.55	60.86	1.98	16.05	10.63	1.43	65385.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.64	3.03	50.83	2.05	15.43	10.76	1.41	62483.19
最大值	11.27	8.09	60.86	2.57	17.51	11.16	1.46	65385.47
發生時間	7	2	23	3	12	15		23
最小值	0.44	0.42	41.67	1.62	13.52	10.27	1.38	56621.46
發生時間	19	20	6	21	15	5		6
零點偏移(率)	-0.01 %	-0.04 %	-0.10 %	-0.04 %		-0.06	0.00	0.00 %
全幅偏移(率)	2.04 %	0.98 %	-0.01 %	0.40 %		0.12	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

