

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.92	3.48	72.17	2.69	16.97	12.22	1.38	67862.86
1	6.31	3.51	43.56	2.57	18.48	11.65	1.41	71384.96
2	9.97	3.68	45.99	3.14	17.35	11.83	1.41	70643.52
3	8.14	3.51	71.89	3.63	15.42	12.29	1.40	69464.80
4	3.41	4.38	55.06	2.63	17.04	12.05	1.41	69838.46
5	7.84	3.61	63.82	2.84	17.18	11.65	1.41	72525.02
6	5.51	3.19	61.37	2.91	16.72	11.86	1.41	71405.43
7	7.81	3.39	50.46	3.18	16.90	11.85	1.42	71587.65
8	9.50	3.30	63.46	3.18	17.00	11.84	1.45	71202.31
9	9.66	3.31	48.76	3.37	17.10	11.91	1.41	70717.58
10	7.79	3.55	61.28	3.40	16.95	12.01	1.40	69978.31
11	7.44	3.40	56.46	3.12	16.59	12.02	1.45	70299.60
12	8.25	3.22	55.25	3.47	16.58	12.02	1.44	69911.28
13	5.66	3.58	70.61	2.75	17.58	11.67	1.44	71649.39
14	12.37	5.88	46.45	4.44	16.01	11.69	1.43	73265.95
15	5.00	4.32	73.12	3.22	16.89	12.34	1.43	67561.23
16	2.12	3.37	55.76	2.72	17.01	11.74	1.46	72433.10
17	5.75	3.88	58.57	3.08	16.65	12.03	1.40	70610.72
18	9.41	6.36	53.58	4.07	15.14	12.30	1.42	69849.56
19	4.96	3.83	60.46	3.18	16.26	12.50	1.45	67294.87
20	1.03	3.44	62.02	2.49	17.79	11.95	1.45	70698.55
21	8.88	4.23	47.12	2.81	18.11	11.51	1.43	73562.73
22	3.03	4.08	64.39	2.91	16.95	12.66	1.48	65593.65
23	0.10	4.40	56.25	3.05	16.75	12.79	1.48	64844.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.54	3.87	58.24	3.12	16.89	12.02	1.43	70174.40
最大值	12.37	6.36	73.12	4.44	18.48	12.79	1.58	73562.73
發生時間	14	18	15	14	1	23		21
最小值	0.10	3.19	43.56	2.49	15.14	11.51	1.36	64844.12
發生時間	23	6	1	20	18	21		23
零點偏移(率)	0.00 %	-0.09 %	-0.01 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.02 %	0.81 %	-0.74 %	0.13 %		0.09	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.93	2.08	52.04	1.64	17.85	10.57	1.33	79065.99
1	8.51	3.44	45.68	2.21	18.27	10.43	1.35	79218.58
2	10.56	5.39	45.33	3.24	17.31	10.15	1.37	79420.59
3	5.47	2.57	46.80	2.03	18.36	9.99	1.38	81331.89
4	9.68	3.35	45.78	2.60	18.77	9.90	1.38	83510.69
5	6.76	4.65	50.15	2.41	17.30	10.45	1.39	80997.44
6	7.61	3.45	45.99	2.82	18.00	9.98	1.41	80145.82
7	7.79	2.47	46.46	2.48	18.18	10.09	1.43	80493.45
8	8.38	6.62	45.27	3.31	18.15	9.83	1.39	78051.42
9	9.53	7.55	42.09	3.23	17.97	9.84	1.37	77415.43
10	9.25	3.46	46.97	3.26	18.72	9.67	1.39	80138.22
11	7.70	11.47	43.23	2.19	20.75	9.31	1.39	83502.04
12	7.29	4.65	54.38	1.72	20.97	9.91	1.37	81504.81
13	7.79	5.01	39.87	2.13	20.92	9.70	1.38	86293.26
14	8.45	4.00	43.08	2.56	19.93	9.76	1.38	87752.26
15	6.83	4.25	44.89	2.11	19.65	10.19	1.37	82742.63
16	4.45	3.97	46.52	1.80	19.30	9.98	1.37	82962.68
17	9.24	3.89	56.03	2.79	18.54	9.94	1.38	83286.07
18	8.95	2.19	41.17	3.05	16.60	10.19	1.36	79854.22
19	8.76	2.41	44.41	2.51	17.94	9.94	1.40	80738.48
20	8.99	3.00	51.22	2.10	19.16	9.90	1.41	85378.77
21	6.46	4.42	44.99	1.79	19.35	9.83	1.41	82983.77
22	5.47	4.62	45.53	1.85	19.42	9.88	1.41	82348.33
23	6.07	4.98	40.55	2.11	18.58	9.79	1.40	80891.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.71	4.33	46.18	2.41	18.75	9.97	1.38	81667.85
最大值	10.56	11.47	56.03	3.31	20.97	10.57	1.43	87752.26
發生時間	2	11	17	8	12	0		14
最小值	4.45	2.08	39.87	1.64	16.60	9.31	1.33	77415.43
發生時間	16	0	13	0	18	11		9
零點偏移(率)	-0.03 %	-0.03 %	-0.01 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	1.22 %	0.57 %	-0.21 %	0.25 %		-0.07	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.76	1.66	61.93	2.15	15.93	11.40	1.46	82227.00
1	5.69	2.54	55.60	1.91	16.95	11.07	1.44	82673.66
2	6.65	6.71	57.34	4.84	15.39	11.18	1.44	79525.85
3	4.10	1.75	58.32	2.30	16.69	10.71	1.43	81054.53
4	5.87	2.42	53.66	2.28	16.72	10.50	1.43	82796.73
5	7.13	3.41	53.60	2.42	16.59	10.65	1.43	82173.98
6	7.90	5.16	51.68	3.71	15.30	11.02	1.43	79555.31
7	9.36	3.88	49.04	3.00	16.76	10.42	1.48	87619.31
8	9.93	4.04	55.27	2.90	16.48	10.88	1.48	81589.76
9	10.43	3.55	60.16	3.13	16.26	10.95	1.48	82540.61
10	6.74	7.60	53.29	4.05	16.26	11.10	1.47	78450.18
11	6.42	1.93	66.25	2.76	18.71	10.84	1.47	80059.09
12	11.36	3.48	47.38	3.02	18.55	9.96	1.49	87448.45
13	6.05	2.72	48.68	2.73	17.16	10.36	1.48	82529.86
14	10.76	3.24	51.40	3.86	17.24	10.33	1.45	83408.96
15	8.11	3.06	57.65	2.63	17.31	10.38	1.47	83554.42
16	7.14	5.38	40.22	3.22	16.47	10.27	1.44	77559.73
17	8.99	3.03	43.01	2.86	17.47	10.12	1.43	81223.31
18	10.01	1.50	49.88	2.54	15.97	10.85	1.45	78622.96
19	6.24	1.14	51.62	2.24	16.95	10.65	1.45	80350.02
20	4.68	2.27	57.85	2.10	18.02	10.39	1.47	86171.73
21	5.91	2.42	55.91	2.20	18.03	10.68	1.47	83344.10
22	4.25	4.59	45.15	1.85	16.98	10.44	1.48	81191.60
23	2.77	2.78	57.07	1.99	17.30	10.68	1.49	81248.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.26	3.34	53.41	2.78	16.90	10.66	1.46	81954.99
最大值	11.36	7.60	66.25	4.84	18.71	11.40	1.50	87619.31
發生時間	12	10	11	2	11	0		7
最小值	2.77	1.14	40.22	1.85	15.30	9.96	1.43	77559.73
發生時間	23	19	16	22	6	12		16
零點偏移(率)	-0.01 %	-0.05 %	-0.07 %	-0.02 %		-0.03	0.00	0.00 %
全幅偏移(率)	1.84 %	0.64 %	-0.47 %	0.27 %		0.08	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								