

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.50	1.21	41.91	1.29	18.96	11.11	1.41	77717.15
1	8.51	0.55	47.74	0.78	21.08	10.79	1.41	78548.86
2	8.40	0.76	53.11	1.10	20.05	11.55	1.42	73570.75
3	3.51	0.95	59.11	0.85	20.11	11.71	1.42	72820.18
4	4.40	1.42	49.30	0.51	20.98	10.77	1.42	78725.68
5	7.98	5.05	50.48	1.24	20.15	11.40	1.39	76431.56
6	8.98	2.72	49.84	0.82	20.68	10.59	1.38	79771.49
7	10.49	1.67	42.77	1.25	19.34	11.36	1.38	75480.25
8	9.52	4.15	46.69	0.95	20.54	10.89	1.37	78003.02
9	6.39	5.98	73.67	1.23	19.46	12.42	1.44	66710.82
10	0.75	2.33	58.00	0.98	20.23	11.85	1.37	70698.94
11	0.98	1.40	54.74	0.94	19.63	11.27	1.35	75735.71
12	2.13	2.88	51.25	1.08	18.37	11.52	1.36	75323.84
13	4.44	2.80	56.53	0.83	20.32	11.14	1.36	76344.50
14	5.31	5.89	53.42	1.79	16.53	12.30	1.37	69950.62
15	4.73	1.54	57.52	0.62	21.06	11.45	1.39	73437.30
16	9.63	2.63	52.14	0.70	20.78	10.98	1.36	77420.00
17	7.31	13.83	57.16	1.43	18.52	12.50	1.38	67651.88
18	9.10	4.72	61.69	1.17	19.40	12.58	1.45	66675.49
19	6.53	7.90	72.70	1.45	18.14	13.29	1.43	62184.30
20	1.77	11.46	60.03	2.92	18.10	14.24	1.59	54802.15
21	9.15	0.61	43.14	1.02	20.40	11.34	1.39	75782.96
22	10.90	1.58	46.85	0.83	20.43	10.78	1.40	79735.30
23	10.95	6.25	56.25	0.74	20.88	10.76	1.40	79713.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.72	3.76	54.00	1.10	19.76	11.61	1.40	73468.17
最大值	10.95	13.83	73.67	2.92	21.08	14.24	1.93	79771.49
發生時間	23	17	9	20	1	20		6
最小值	0.75	0.55	41.91	0.51	16.53	10.59	1.35	54802.15
發生時間	10	1	0	4	14	6		20
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.52 %	-0.05 %	-0.11 %	0.08 %		0.19	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.04	4.33	51.67	2.28	18.27	10.29	1.46	66688.45
1	10.48	2.99	57.05	2.35	18.41	10.29	1.46	68581.98
2	8.85	1.66	55.00	3.11	17.98	10.09	1.46	66719.83
3	9.45	1.43	56.66	2.80	18.01	10.30	1.46	68342.37
4	8.38	0.29	55.70	2.18	18.39	10.41	1.46	67807.56
5	9.00	1.01	61.11	2.36	18.83	9.87	1.46	70303.27
6	7.71	3.42	64.61	2.59	15.63	11.07	1.46	69593.39
7	6.41	1.95	51.68	2.49	16.28	11.33	1.46	61763.70
8	8.87	0.79	64.34	1.95	19.40	10.34	1.46	67579.84
9	9.79	0.27	58.11	2.23	17.77	10.45	1.47	67006.43
10	10.05	2.11	59.65	2.15	18.01	10.27	1.49	67158.99
11	9.42	0.86	57.56	2.55	15.64	11.03	1.49	62683.89
12	10.67	1.01	65.40	2.18	17.19	10.81	1.50	64768.49
13	8.32	0.96	59.97	2.22	16.05	11.06	1.51	63544.85
14	7.72	0.59	63.90	1.95	17.46	10.72	1.51	65693.23
15	9.97	1.67	60.01	2.38	15.70	11.21	1.51	63727.78
16	8.95	0.94	60.71	2.44	15.81	11.12	1.49	64248.22
17	7.31	1.02	68.73	2.07	16.70	11.48	1.49	61077.34
18	3.97	1.37	69.69	1.98	16.63	12.23	1.49	56728.44
19	4.85	2.49	62.03	1.51	18.23	10.71	1.47	65966.09
20	8.56	2.32	39.05	1.88	17.63	10.91	1.49	65097.71
21	11.22	3.57	42.16	1.94	16.83	10.73	1.46	66857.69
22	10.15	2.09	58.28	1.80	18.46	10.44	1.46	67526.79
23	10.67	0.53	61.66	1.96	18.44	10.49	1.45	67085.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.78	1.65	58.53	2.22	17.41	10.74	1.47	65689.65
最大值	11.22	4.33	69.69	3.11	19.40	12.23	1.56	70303.27
發生時間	21	0	18	2	8	18		5
最小值	3.97	0.27	39.05	1.51	15.63	9.87	1.43	56728.44
發生時間	18	9	20	19	6	5		18
零點偏移(率)	-0.02 %	0.00 %	-0.07 %	-0.02 %		-0.04	0.00	0.00 %
全幅偏移(率)	1.69 %	0.34 %	0.15 %	0.28 %		0.15	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.21	11.57	35.89	3.11	16.59	9.57	1.25	89316.52
1	10.78	0.80	47.29	3.13	15.33	10.31	1.25	78908.19
2	9.01	2.96	54.79	3.31	14.60	10.39	1.25	78450.07
3	11.06	3.31	42.18	3.15	16.41	9.47	1.26	88123.52
4	8.60	0.57	55.31	2.71	14.60	11.18	1.28	78837.99
5	5.52	0.51	62.12	2.16	15.64	11.24	1.28	82154.98
6	7.80	2.23	55.53	2.80	14.28	11.13	1.28	82192.08
7	11.31	6.11	54.89	2.63	16.58	10.26	1.30	87784.02
8	11.02	2.42	53.00	3.07	14.97	10.27	1.29	81965.79
9	8.85	1.63	56.71	1.96	16.38	10.72	1.30	80571.16
10	6.58	1.06	52.56	1.93	15.86	10.57	1.31	84476.56
11	8.36	4.80	51.24	1.91	16.03	10.44	1.33	85536.44
12	6.75	1.31	55.70	1.95	15.53	10.91	1.33	82250.72
13	8.25	3.37	50.42	1.78	16.31	10.56	1.33	84390.57
14	5.91	4.66	61.94	2.14	15.12	11.86	1.32	74880.32
15	5.19	5.00	56.72	1.79	16.95	10.91	1.31	85595.89
16	6.97	1.65	51.40	1.75	15.72	10.81	1.31	83327.11
17	4.54	3.95	57.42	2.47	14.16	11.28	1.32	79866.40
18	4.43	3.15	58.80	1.71	17.30	10.57	1.32	87169.94
19	7.79	6.18	53.95	2.00	16.80	10.51	1.31	90150.79
20	8.44	0.48	51.76	2.31	15.26	10.66	1.30	83601.61
21	9.20	1.49	60.19	2.08	16.04	10.81	1.30	87140.17
22	9.45	2.61	63.86	1.84	17.09	10.93	1.30	87424.68
23	6.21	6.91	62.87	1.71	17.57	10.89	1.30	87186.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.13	3.28	54.44	2.31	15.88	10.68	1.30	83804.24
最大值	13.21	11.57	63.86	3.31	17.57	11.86	1.33	90150.79
發生時間	0	0	22	2	23	14		19
最小值	4.43	0.48	35.89	1.71	14.16	9.47	1.24	74880.32
發生時間	18	20	0	18	17	3		14
零點偏移(率)	0.00 %	-0.00 %	-0.01 %	-0.02 %		0.00	0.00	0.00 %
全幅偏移(率)	0.61 %	-0.35 %	-0.43 %	-0.00 %		0.36	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								