

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.97	14.31	51.81	1.65	20.33	10.68	0.99	71986.62
1	7.26	14.04	56.48	1.43	20.26	10.36	1.01	74300.68
2	2.85	11.93	47.04	2.62	16.26	11.10	1.01	72505.47
3	8.41	13.06	61.75	2.17	17.48	11.14	0.99	72394.00
4	7.37	13.76	55.76	1.98	18.76	10.82	0.99	73201.14
5	3.83	11.65	66.64	2.57	17.78	11.08	1.00	76723.19
6	4.16	12.71	67.06	2.75	18.23	11.55	1.02	68512.88
7	2.53	13.34	56.53	1.99	20.29	10.36	0.99	75425.25
8	2.18	16.48	42.54	2.45	18.46	10.81	1.02	73098.85
9	2.90	17.36	54.80	2.79	16.92	11.34	1.04	70157.56
10	3.86	17.22	50.94	3.01	16.24	11.49	1.01	68212.39
11	2.22	16.84	48.38	3.21	15.52	11.61	1.04	66508.19
12	8.02	15.20	52.67	3.50	15.27	11.78	1.02	65821.51
13	4.77	15.93	57.67	2.89	16.00	11.96	1.01	65385.81
14	7.46	14.52	54.97	1.27	15.37	12.58	1.02	61581.41
15	5.33	11.17	57.42	0.99	15.84	12.18	1.01	65316.85
16	1.97	12.11	53.50	0.38	17.27	11.43	1.00	69069.73
17	4.00	11.83	56.38	0.51	17.89	11.14	1.01	72318.21
18	4.57	11.96	58.95	0.58	18.03	10.97	1.01	73136.19
19	2.43	13.55	64.13	0.44	18.56	11.20	0.99	71475.08
20	1.76	11.61	50.84	0.37	18.72	10.82	1.00	73228.70
21	9.62	11.84	52.81	0.77	17.53	10.87	0.99	73932.82
22	8.56	14.16	50.96	0.93	17.15	11.08	0.99	72316.97
23	6.55	11.41	57.57	0.25	18.03	11.15	1.02	71604.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.94	13.67	55.32	1.73	17.59	11.23	1.01	70758.90
最大值	9.62	17.36	67.06	3.50	20.33	12.58	1.17	76723.19
發生時間	21	9	6	12	0	14		5
最小值	1.76	11.17	42.54	0.25	15.27	10.36	0.99	61581.41
發生時間	20	15	8	23	12	1		14
零點偏移(率)	-0.08 %	-0.04 %	-0.05 %	-0.01 %		0.05		0.00 %
全幅偏移(率)	0.02 %	-2.38 %	-1.15 %	-0.67 %		0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.16	13.71	55.72	1.00	17.91	10.47	1.13	77490.89
1	1.34	18.33	53.03	1.00	18.91	10.60	1.14	73357.79
2	0.47	11.34	48.60	1.11	17.23	10.39	1.12	72614.30
3	0.19	11.52	68.50	0.61	19.47	10.67	1.13	70402.33
4	0.94	11.00	62.66	0.93	18.42	10.53	1.12	74719.80
5	3.48	11.84	48.03	1.31	17.35	10.36	1.12	76027.05
6	0.10	12.56	59.34	0.65	19.08	10.51	1.14	41156.33
7	0.11	14.02	63.67	0.59	19.50	10.56	1.15	74910.00
8	0.09	13.01	43.69	0.93	18.48	10.43	1.16	76125.36
9	0.04	12.99	69.28	0.86	18.68	10.47	1.17	72770.38
10	0.08	22.61	71.36	1.08	17.21	10.28	1.17	65975.52
11	保養	保養	保養	保養	替代	保養	1.16	71351.06
12	保養	保養	保養	保養	替代	保養	1.17	79080.35
13	保養	保養	保養	保養	替代	保養	1.18	74963.95
14	0.37	9.28	50.85	1.65	15.61	10.02	1.15	70147.61
15	1.62	6.37	59.03	0.89	15.91	9.66	1.15	78863.22
16	1.81	12.38	59.83	0.76	16.18	9.29	1.15	82265.55
17	1.61	5.13	58.22	0.93	16.20	9.58	1.15	83429.01
18	3.26	4.77	59.12	1.34	15.43	10.04	1.16	82798.78
19	3.40	5.93	62.40	1.24	16.30	10.08	1.17	85581.54
20	6.14	14.83	59.14	0.68	17.41	9.68	1.15	87873.66
21	9.61	6.15	57.32	0.96	17.05	9.91	1.15	87032.20
22	6.71	5.87	61.43	0.76	17.27	9.92	1.15	84764.48
23	8.56	6.65	59.73	1.07	16.72	9.95	1.17	84687.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	21	21	21	21	21	21	24	24
平均值	2.43	10.97	58.62	0.97	17.44	10.16	1.15	76182.88
最大值	9.61	22.61	71.36	1.65	19.50	10.67	1.19	87873.66
發生時間	21	10	10	14	7	3		20
最小值	0.04	4.77	43.69	0.59	15.43	9.29	1.12	41156.33
發生時間	9	18	8	7	18	16		6
零點偏移(率)	-1.04 %	-0.01 %	-0.03 %	-0.13 %		0.03		-0.10 %
全幅偏移(率)	0.02 %	-0.40 %	-0.01 %	-0.06 %		-0.25		0.00 %
有效比率	87.50 %	87.50 %	87.50 %	87.50 %	87.50 %	87.50 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.45	13.91	56.81	2.14	16.73	10.82	1.00	82690.74
1	6.21	15.32	66.24	2.36	16.97	11.33	1.04	78755.59
2	2.23	15.01	64.53	2.44	15.60	11.80	1.05	75484.84
3	1.12	12.48	59.62	2.11	16.41	10.92	1.05	81002.70
4	2.10	15.14	67.49	2.19	16.72	11.40	1.05	78189.75
5	2.40	13.59	64.79	2.14	16.77	11.15	1.05	82586.96
6	3.08	12.06	60.27	2.07	17.04	10.80	1.05	83100.55
7	0.89	14.56	64.86	2.88	18.07	10.38	1.05	83736.03
8	0.99	13.54	62.26	2.81	17.99	10.69	1.04	83415.50
9	0.48	13.48	58.85	2.79	16.64	10.80	1.05	80965.17
10	0.98	19.99	55.68	3.20	14.97	10.85	1.00	74535.91
11	0.41	13.79	54.35	3.91	13.14	11.00	1.01	70041.00
12	0.14	9.90	61.35	3.19	16.00	10.96	1.05	72096.95
13	0.57	7.61	42.37	2.18	15.76	10.55	1.05	73797.52
14	0.92	9.13	43.99	1.70	16.72	10.71	0.99	70678.37
15	1.21	13.00	42.52	1.77	15.64	10.79	1.00	72993.34
16	2.49	9.93	45.67	1.67	16.14	10.73	1.03	79483.43
17	1.66	9.12	50.41	1.56	16.50	10.73	1.01	79467.22
18	1.83	8.70	50.71	1.69	16.23	10.65	0.99	82377.44
19	1.41	9.40	54.24	1.56	16.75	10.77	0.99	80397.26
20	2.64	9.25	47.90	1.70	17.38	10.40	1.01	85560.58
21	4.55	9.67	54.49	2.05	15.66	10.95	1.00	80963.74
22	6.67	15.86	48.33	2.18	15.46	10.80	1.00	81166.04
23	4.85	8.40	53.90	1.74	16.70	10.81	1.02	80046.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.43	12.20	55.48	2.25	16.33	10.87	1.02	78897.20
最大值	8.45	19.99	67.49	3.91	18.07	11.80	1.07	85560.58
發生時間	0	10	4	11	7	2		20
最小值	0.14	7.61	42.37	1.56	13.14	10.38	0.96	70041.00
發生時間	12	13	13	17	11	7		11
零點偏移(率)	-0.08 %	-0.06 %	-0.03 %	-0.01 %		0.04		0.00 %
全幅偏移(率)	-1.32 %	-2.78 %	-1.01 %	-2.92 %		0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								