

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月10日

報表日期: 114年07月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.43	9.34	65.84	1.87	17.26	11.49	1.25	80889.12
1	0.14	9.71	57.32	1.90	18.51	11.73	1.26	77992.15
2	0.12	12.17	57.76	1.40	18.81	11.01	1.27	83119.27
3	2.22	10.41	49.80	1.98	17.80	10.64	1.27	82516.21
4	3.97	7.86	56.51	2.21	16.41	11.29	1.26	81589.41
5	0.15	11.52	49.77	1.21	16.09	12.09	1.25	77400.21
6	2.58	7.27	53.40	2.03	16.30	11.91	1.25	78350.03
7	2.80	6.61	61.06	1.82	16.66	11.92	1.25	77999.80
8	2.68	6.08	57.21	1.87	17.85	11.06	1.26	84173.48
9	3.22	6.30	56.79	1.90	17.49	11.31	1.27	82557.47
10	3.16	7.76	54.55	2.16	17.10	11.10	1.26	84902.75
11	3.07	8.78	57.70	1.85	17.39	11.31	1.25	82365.75
12	3.30	9.14	61.32	2.59	15.95	11.85	1.26	79060.39
13	4.42	9.25	62.36	2.06	16.44	11.65	1.27	80468.92
14	2.72	8.81	58.21	1.87	16.17	11.53	1.26	81788.37
15	1.84	9.23	56.06	2.58	15.85	11.68	1.26	80824.39
16	1.46	9.03	58.47	1.37	17.36	11.77	1.26	78496.81
17	1.45	9.13	58.98	2.12	16.75	11.74	1.27	79339.78
18	1.31	10.22	53.23	1.40	18.54	10.60	1.26	87524.84
19	1.84	10.14	48.01	2.16	16.29	11.21	1.27	84668.28
20	3.86	9.76	57.80	2.48	16.00	11.44	1.27	82905.58
21	4.06	10.72	56.64	1.15	17.72	11.58	1.28	80008.09
22	3.89	9.83	54.95	1.94	16.81	11.35	1.26	82731.01
23	4.03	10.21	55.11	1.72	16.73	11.70	1.26	79953.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.45	9.14	56.62	1.90	17.01	11.46	1.26	81317.73
最 大 值	4.42	12.17	65.84	2.59	18.81	12.09	1.29	87524.84
發生時間	13	2	0	12	2	5		18
最 小 值	0.12	6.08	48.01	1.15	15.85	10.60	1.25	77400.21
發生時間	2	8	19	21	15	18		5
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.00 %		0.01		0.20 %
全幅偏移(率)	0.00 %	0.37 %	-0.31 %	-0.48 %		0.23		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月10日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.97	8.95	60.19	1.65	18.16	9.27	1.39	75169.44
1	0.65	11.06	58.40	1.43	20.59	8.92	1.39	78188.37
2	0.24	9.93	58.97	1.56	18.66	9.22	1.40	77560.18
3	2.02	8.45	62.56	1.79	18.57	9.39	1.42	75752.58
4	1.49	9.13	53.31	1.83	17.93	9.16	1.40	76758.84
5	2.33	9.01	45.50	1.85	17.31	9.37	1.39	75382.38
6	0.68	8.50	47.66	1.65	17.99	9.47	1.40	75524.60
7	1.96	11.92	55.73	1.70	18.94	8.98	1.42	78163.05
8	4.15	7.48	62.69	1.74	18.10	9.84	1.42	80280.15
9	8.56	11.04	63.55	2.88	18.69	9.77	1.42	81313.28
10	4.48	8.77	58.93	2.35	17.36	10.05	1.43	77462.71
11	7.92	9.91	52.96	2.71	17.48	9.73	1.45	80958.47
12	6.87	12.64	51.09	2.48	16.95	9.84	1.43	79470.77
13	4.26	8.38	59.31	1.98	17.68	9.98	1.41	77793.23
14	3.16	7.55	50.59	2.23	16.79	10.10	1.41	79490.25
15	4.06	7.55	60.71	2.55	16.25	10.41	1.43	78006.76
16	1.61	11.01	51.47	1.75	17.69	9.39	1.42	72099.43
17	1.71	9.38	46.14	1.53	19.42	8.15	1.41	74097.48
18	0.21	9.99	48.30	1.44	20.14	8.13	1.43	77395.51
19	2.05	9.38	45.91	1.68	18.07	7.95	1.43	71478.47
20	3.04	10.67	53.91	1.36	18.12	8.84	1.43	75671.55
21	3.04	10.20	56.42	1.26	19.57	8.43	1.44	77923.74
22	3.72	9.33	53.83	1.44	21.60	7.80	1.44	85901.42
23	3.62	9.38	62.75	1.47	19.15	9.19	1.43	78364.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.07	9.57	55.04	1.85	18.38	9.22	1.42	77508.64
最 大 值	8.56	12.64	63.55	2.88	21.60	10.41	1.46	85901.42
發生時間	9	12	9	9	22	15		22
最 小 值	0.21	7.48	45.50	1.26	16.25	7.80	1.38	71478.47
發生時間	18	8	5	21	15	22		19
零點偏移(率)	-0.02 %	-0.01 %	-0.06 %	-0.05 %		-0.04		-0.20 %
全幅偏移(率)	0.02 %	0.84 %	-0.41 %	0.07 %		0.20		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								