

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月13日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.16	11.85	47.68	2.28	17.05	10.04	1.11	79455.12
1	10.84	11.52	39.79	1.49	17.90	9.99	1.13	77662.13
2	9.08	13.05	46.58	2.11	19.09	9.95	1.14	80354.10
3	6.73	11.87	53.49	2.45	16.62	10.61	1.15	78935.24
4	9.04	11.59	57.39	3.38	16.78	10.34	1.13	80818.21
5	8.31	11.82	58.65	3.06	16.10	10.67	1.12	78309.48
6	10.44	10.47	53.97	2.44	15.73	10.83	1.12	81093.52
7	8.16	11.99	53.35	2.75	15.45	10.83	1.11	75765.98
8	13.54	13.01	51.48	2.87	15.20	10.77	1.12	77007.89
9	8.37	12.43	50.70	3.11	14.76	11.15	1.15	75398.91
10	8.80	13.82	46.47	3.61	14.33	11.13	1.11	75101.95
11	8.57	13.29	57.94	2.95	15.59	11.41	1.14	74362.46
12	11.22	12.23	46.84	2.83	15.86	10.70	1.10	79244.68
13	11.40	13.78	60.57	3.46	14.10	11.52	1.12	77199.84
14	7.14	15.18	61.74	3.14	13.89	12.23	1.13	75063.97
15	7.69	14.81	61.34	3.67	14.85	11.00	1.10	76111.21
16	11.65	12.90	50.93	2.69	15.62	11.02	1.10	75576.85
17	11.94	11.73	42.15	1.83	18.05	9.98	1.10	81048.83
18	10.61	12.10	32.95	2.49	17.64	9.62	1.12	79291.25
19	11.66	11.93	37.50	2.31	18.34	9.38	1.13	80042.20
20	13.59	12.21	42.17	3.22	17.59	9.88	1.11	81680.15
21	12.11	11.61	44.50	2.10	16.65	10.42	1.11	80261.39
22	11.17	11.62	44.30	2.02	16.79	10.40	1.10	78466.09
23	12.44	11.72	38.09	1.26	19.09	9.45	1.10	80306.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.32	12.44	49.19	2.65	16.38	10.55	1.12	78273.24
最 大 值	13.59	15.18	61.74	3.67	19.09	12.23	1.18	81680.15
發生時間	20	14	14	15	2	14		20
最 小 值	6.73	10.47	32.95	1.26	13.89	9.38	1.10	74362.46
發生時間	3	6	18	23	14	19		11
零點偏移(率)	-0.03 %	-0.01 %	-0.03 %	0.00 %		-0.03	-0.01	0.00 %
全幅偏移(率)	-0.88 %	-0.94 %	-0.08 %	-0.97 %		-0.10	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

