

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.32	4.05	49.85	2.24	18.89	11.43	1.37	76210.60
1	10.68	7.25	47.20	2.26	18.84	11.22	1.36	77445.42
2	11.19	7.69	45.14	2.70	17.24	11.81	1.36	74434.04
3	10.79	6.03	57.50	2.65	18.57	11.21	1.36	78237.21
4	8.37	4.25	49.31	2.53	16.83	12.11	1.37	72130.58
5	7.03	2.60	54.87	2.00	19.35	11.39	1.34	77045.60
6	9.13	3.54	48.58	2.10	18.16	11.50	1.33	75526.11
7	5.42	4.38	54.26	2.00	18.10	11.72	1.33	73933.20
8	10.22	5.14	52.04	2.36	17.10	11.72	1.33	75347.68
9	10.58	4.66	49.78	2.38	17.16	11.83	1.34	74473.24
10	6.48	1.27	46.18	2.12	17.88	11.76	1.35	75142.58
11	8.11	1.49	46.02	2.32	17.27	11.89	1.34	74102.70
12	8.10	2.04	55.78	2.26	17.51	12.07	1.34	73569.36
13	12.40	4.56	45.27	2.39	17.39	11.72	1.33	74900.25
14	9.99	4.00	46.04	2.39	16.91	11.93	1.33	74017.71
15	8.26	2.35	63.27	2.09	18.58	11.97	1.33	72521.99
16	6.30	2.28	52.56	2.15	17.13	12.09	1.35	72427.36
17	5.02	2.75	52.51	2.02	18.03	11.87	1.38	73673.02
18	10.30	2.79	48.19	2.21	17.88	11.62	1.33	76213.37
19	7.56	2.31	55.04	2.25	17.50	12.15	1.34	71917.32
20	4.67	2.82	57.08	2.11	17.43	12.08	1.35	72773.09
21	9.73	2.84	48.84	2.19	17.74	11.71	1.34	74925.22
22	9.17	3.53	54.42	2.36	17.05	12.21	1.33	71398.23
23	8.88	3.27	54.40	2.17	17.50	11.91	1.34	73529.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.65	3.66	51.42	2.26	17.75	11.79	1.35	74412.32
最大值	12.40	7.69	63.27	2.70	19.35	12.21	1.40	78237.21
發生時間	13	2	15	2	5	22		3
最小值	4.67	1.27	45.14	2.00	16.83	11.21	1.33	71398.23
發生時間	20	10	2	5	4	3		22
零點偏移(率)	-0.11 %	-0.01 %	-0.03 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	-0.99 %	0.05 %	-0.01 %	-0.09 %		0.44	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.75	3.08	57.72	2.35	16.82	10.52	1.38	63555.63
1	9.44	5.16	58.61	2.25	17.89	10.41	1.40	66609.45
2	10.13	1.61	45.49	2.37	16.68	10.38	1.39	63490.05
3	11.02	2.45	49.89	2.37	16.21	10.35	1.39	64340.56
4	10.13	1.77	55.19	2.33	15.88	10.70	1.40	64930.46
5	10.63	1.48	54.75	2.45	15.48	10.74	1.38	65121.44
6	11.63	4.61	56.05	3.26	13.61	11.33	1.40	63694.21
7	11.50	3.21	45.27	3.24	14.57	10.81	1.38	61960.62
8	10.19	14.71	60.65	2.64	14.99	10.59	1.43	60892.73
9	9.63	6.22	41.63	2.52	15.84	10.04	1.43	60272.33
10	10.45	9.58	56.66	2.98	14.79	9.88	1.39	63361.63
11	11.51	5.18	59.26	2.82	12.75	10.82	1.38	60731.76
12	10.88	6.13	49.28	2.65	14.93	10.59	1.38	60145.50
13	10.45	3.21	43.82	2.70	15.32	10.13	1.42	59216.32
14	10.55	2.34	55.38	1.80	17.24	10.06	1.40	60479.33
15	10.28	4.21	47.86	1.96	16.93	9.78	1.41	66059.95
16	9.66	0.80	55.63	2.15	15.39	10.86	1.41	61080.54
17	10.94	0.96	56.61	2.14	16.16	10.85	1.41	62887.19
18	10.41	1.51	59.45	2.37	15.51	11.11	1.40	62165.45
19	8.27	0.88	61.65	1.89	16.58	10.96	1.39	63124.85
20	10.38	1.39	44.91	2.08	16.27	10.89	1.40	65498.76
21	11.28	1.11	57.87	1.92	16.59	10.56	1.41	66810.68
22	10.18	1.29	57.43	2.14	15.64	11.03	1.41	65389.05
23	11.06	1.66	56.36	2.19	15.97	10.95	1.41	66128.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.51	3.52	53.64	2.40	15.75	10.60	1.40	63247.81
最大值	11.75	14.71	61.65	3.26	17.89	11.33	1.52	66810.68
發生時間	0	8	19	6	1	6		21
最小值	8.27	0.80	41.63	1.80	12.75	9.78	1.38	59216.32
發生時間	19	16	9	14	11	15		13
零點偏移(率)	-0.05 %	-0.00 %	-0.28 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	-2.19 %	0.03 %	0.09 %	-0.03 %		0.36	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.08	2.23	55.48	2.41	16.08	10.61	1.69	86180.69
1	16.07	3.32	49.31	2.35	16.74	10.64	1.70	89689.48
2	16.67	3.48	57.61	3.14	14.44	11.11	1.70	85386.02
3	13.01	1.99	58.33	2.80	15.22	10.95	1.71	88212.12
4	10.76	2.46	60.73	2.87	14.80	10.98	1.72	89255.92
5	13.68	2.36	56.22	2.89	14.50	10.84	1.71	89216.09
6	11.23	6.15	57.86	3.14	13.55	11.41	1.71	83711.18
7	13.56	3.30	52.23	2.46	14.85	10.89	1.72	83454.77
8	15.47	4.04	52.07	2.79	13.50	11.38	1.73	83951.76
9	9.64	6.79	52.60	2.81	13.21	11.46	1.74	85068.70
10	9.67	8.06	53.79	3.32	12.58	11.75	1.74	83361.93
11	12.06	3.99	52.99	2.99	12.79	11.78	1.75	83253.26
12	13.21	2.78	50.46	2.08	14.50	11.10	1.74	84701.55
13	5.53	3.82	52.37	2.24	13.70	11.20	1.71	82367.84
14	8.00	7.03	50.49	2.24	14.16	11.01	1.71	83074.73
15	13.23	2.89	51.02	2.41	13.93	11.19	1.71	84053.67
16	10.80	3.59	53.19	2.25	14.16	11.07	1.72	82239.08
17	9.64	2.42	52.57	2.36	13.85	11.09	1.73	81683.31
18	8.09	2.00	51.18	1.78	14.83	10.95	1.74	81996.98
19	9.34	1.91	54.28	1.52	15.99	10.91	1.74	81686.53
20	12.21	5.50	51.36	1.67	15.63	10.82	1.73	86053.84
21	9.41	4.54	54.17	1.89	14.97	11.07	1.72	84828.92
22	10.73	1.41	54.43	2.06	14.53	11.24	1.72	83137.01
23	9.96	1.50	55.82	2.11	14.63	11.02	1.72	84873.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.50	3.65	53.77	2.44	14.46	11.10	1.72	84643.27
最大值	16.67	8.06	60.73	3.32	16.74	11.78	1.75	89689.48
發生時間	2	10	4	10	1	11		1
最小值	5.53	1.41	49.31	1.52	12.58	10.61	1.68	81683.31
發生時間	13	22	1	19	10	0		17
零點偏移(率)	-0.01 %	-0.04 %	-0.18 %	-0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	0.16 %	-0.26 %	0.07 %	0.09 %		0.42	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								