

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月30日

報表日期: 114年07月30日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.84	9.22	58.37	2.38	17.15	11.65	1.29	79511.74
1	7.40	10.08	64.20	2.06	18.16	11.82	1.29	76912.31
2	6.77	11.97	61.04	2.92	17.27	11.79	1.29	78097.02
3	6.67	12.13	65.04	2.68	16.68	12.07	1.29	76879.02
4	10.66	11.57	45.14	3.38	16.96	11.54	1.29	80822.20
5	5.08	9.61	65.34	2.20	17.59	11.74	1.27	77460.65
6	6.28	8.96	50.18	2.99	16.45	11.58	1.27	80595.66
7	8.58	8.81	61.41	2.64	17.18	11.32	1.28	82516.74
8	5.95	9.11	58.76	3.01	16.24	11.74	1.27	79289.86
9	6.01	9.36	59.21	2.39	16.88	12.01	1.26	76711.54
10	8.76	9.20	54.90	2.59	16.78	11.83	1.26	78109.98
11	7.46	9.33	59.83	2.40	16.66	11.95	1.25	77367.11
12	1.32	9.53	53.22	3.01	15.42	11.98	1.25	77136.18
13	1.86	11.26	52.93	3.19	14.98	12.15	1.25	72831.60
14	6.62	8.74	52.76	2.37	15.72	11.88	1.25	75218.49
15	10.71	8.94	54.80	3.86	14.45	12.07	1.25	74096.72
16	8.77	8.72	52.85	3.03	15.42	11.82	1.26	75714.53
17	9.18	8.88	66.75	1.58	18.06	11.68	1.26	77745.20
18	9.50	9.86	55.76	2.03	17.70	11.34	1.25	81478.60
19	7.80	10.17	49.56	3.43	15.10	12.11	1.25	76659.27
20	9.64	8.92	54.12	2.95	15.87	11.65	1.25	80805.95
21	11.65	8.80	59.65	2.75	16.57	11.65	1.25	80083.72
22	7.09	8.85	58.68	2.47	15.97	12.00	1.27	77416.19
23	9.36	8.65	54.58	2.64	16.21	11.85	1.28	78886.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.58	9.61	57.04	2.71	16.48	11.80	1.26	78014.46
最 大 值	11.65	12.13	66.75	3.86	18.16	12.15	1.29	82516.74
發生時間	21	3	17	15	1	13		7
最 小 值	1.32	8.65	45.14	1.58	14.45	11.32	1.25	72831.60
發生時間	12	23	4	17	15	7		13
零點偏移(率)	0.00 %	0.00 %	-0.00 %	0.01 %		0.02		0.20 %
全幅偏移(率)	0.00 %	0.29 %	-0.69 %	0.08 %		-0.23		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月30日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.89	7.38	66.17	1.88	18.68	9.62	1.46	80015.76
1	5.64	9.92	65.43	1.49	20.96	8.83	1.46	81440.84
2	4.39	9.06	57.11	1.67	19.54	8.82	1.45	80102.41
3	8.87	9.18	70.00	2.02	20.31	9.07	1.43	80098.32
4	3.72	10.20	64.43	1.73	20.17	9.12	1.44	82540.31
5	4.42	8.83	59.20	2.02	17.73	9.63	1.48	82379.69
6	3.49	7.37	66.76	1.81	18.17	9.75	1.46	80309.34
7	9.03	8.96	59.37	2.62	18.85	9.42	1.49	85079.65
8	4.31	10.99	51.00	2.56	19.06	9.16	1.47	81356.56
9	5.80	11.82	49.99	2.54	18.58	9.11	1.49	79018.57
10	6.38	11.07	48.28	2.70	19.12	9.01	1.46	78423.32
11	1.62	8.87	47.02	1.96	17.48	9.47	1.43	77274.37
12	5.16	10.47	48.58	2.59	16.79	9.68	1.45	76230.04
13	3.01	11.76	44.34	2.86	16.67	9.25	1.46	77105.51
14	3.97	8.24	46.33	4.44	14.29	9.62	1.47	73392.28
15	8.36	5.26	45.17	3.02	16.59	9.61	1.48	73424.13
16	14.84	8.71	43.23	5.52	17.40	8.54	1.48	73370.18
17	0.92	5.85	54.23	2.96	20.63	8.28	1.46	69207.75
18	0.76	10.47	45.07	3.05	21.55	7.68	1.45	74725.06
19	2.53	12.73	38.82	4.18	19.84	7.02	1.43	74775.19
20	2.03	11.11	40.98	3.31	18.40	7.27	1.42	70958.15
21	1.13	10.57	44.63	4.98	17.38	8.63	1.45	74400.11
22	2.71	5.02	59.81	1.59	18.97	9.11	1.45	79192.96
23	4.68	6.22	61.03	2.96	18.14	9.21	1.45	82097.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.90	9.17	53.21	2.77	18.55	8.95	1.46	77788.25
最 大 值	14.84	12.73	70.00	5.52	21.55	9.75	1.51	85079.65
發生時間	16	19	3	16	18	6		7
最 小 值	0.76	5.02	38.82	1.49	14.29	7.02	1.41	69207.75
發生時間	18	22	19	1	14	19		17
零點偏移(率)	-0.04 %	-0.03 %	-0.04 %	0.01 %		-0.09		-0.10 %
全幅偏移(率)	0.25 %	0.43 %	-0.74 %	0.11 %		-0.07		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								