

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.64	2.30	67.05	2.52	17.16	11.51	1.24	80172.01
1	0.68	2.20	55.82	3.24	16.73	11.71	1.25	78823.60
2	0.44	2.13	48.98	3.95	14.80	11.93	1.25	79089.11
3	5.48	2.75	53.05	3.51	14.10	12.02	1.25	78872.36
4	4.94	2.27	59.35	2.07	15.73	11.82	1.25	79249.91
5	2.79	3.21	64.04	2.83	17.32	11.30	1.28	79891.16
6	6.44	2.98	55.68	3.79	16.54	11.27	1.29	82819.63
7	6.64	6.88	56.03	3.44	14.64	11.68	1.29	80857.57
8	5.18	4.91	68.03	1.90	14.10	12.42	1.28	71086.46
9	2.51	2.08	65.42	0.99	16.47	11.31	1.29	81192.67
10	9.36	2.28	48.44	1.88	14.42	11.98	1.27	78170.07
11	3.69	2.69	63.87	1.10	15.38	11.95	1.26	78155.39
12	6.74	4.49	55.65	1.31	14.98	11.99	1.27	77720.02
13	6.78	2.95	58.40	1.29	15.45	11.92	1.27	78254.54
14	8.60	2.73	59.32	1.58	15.28	11.76	1.26	79480.00
15	5.63	2.96	61.06	1.63	15.62	11.82	1.27	77697.86
16	6.32	3.34	57.57	1.50	15.47	11.58	1.27	80033.14
17	4.74	2.60	61.71	0.99	16.97	11.30	1.27	81963.00
18	8.59	2.43	58.82	1.36	15.44	11.72	1.28	79549.95
19	8.86	4.99	56.23	0.84	17.76	11.16	1.27	82474.74
20	8.69	2.91	47.10	1.43	15.75	11.41	1.25	81710.57
21	8.39	2.72	45.87	1.09	16.65	11.43	1.27	81164.56
22	9.14	3.76	45.34	1.59	14.52	12.01	1.28	78316.58
23	9.46	2.66	47.81	1.30	15.64	11.74	1.29	79250.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.86	3.13	56.69	1.96	15.70	11.70	1.27	79416.48
最 大 值	9.46	6.88	68.03	3.95	17.76	12.42	1.32	82819.63
發生時間	23	7	8	2	19	8		6
最 小 值	0.44	2.08	45.34	0.84	14.10	11.16	1.23	71086.46
發生時間	2	9	22	19	3	19		8
零點偏移(率)	-0.14 %	-0.02 %	-0.01 %	-0.00 %		-0.02		0.10 %
全幅偏移(率)	0.00 %	0.04 %	0.03 %	0.18 %		0.08		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月26日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.07	1.49	64.57	1.98	17.32	9.60	1.47	74942.93
1	3.43	4.66	59.43	2.32	18.18	9.36	1.44	74888.45
2	2.89	3.35	60.55	2.15	16.78	9.44	1.43	74518.53
3	2.76	5.27	57.86	2.47	15.05	9.66	1.42	72374.74
4	2.15	4.18	60.03	2.58	14.61	9.84	1.42	71318.82
5	1.24	5.55	62.46	2.95	13.78	10.17	1.43	70043.84
6	1.18	10.46	59.31	2.88	14.15	9.85	1.43	72525.95
7	1.63	6.16	64.06	2.45	15.05	9.79	1.46	75765.96
8	0.42	1.07	61.54	2.05	16.08	9.81	1.45	72995.19
9	4.44	3.13	60.81	2.61	15.81	9.73	1.47	74864.99
10	11.65	3.21	63.78	3.03	17.17	9.47	1.43	75791.66
11	2.22	8.84	56.25	2.14	17.03	9.27	1.40	74600.17
12	2.50	5.62	68.46	2.30	18.90	8.98	1.41	77698.58
13	0.73	10.01	56.51	1.92	16.46	9.68	1.43	75244.36
14	1.05	3.15	60.65	2.02	16.40	9.81	1.41	75239.53
15	0.40	2.79	64.06	1.95	17.05	9.70	1.41	75665.78
16	0.66	6.93	56.89	1.92	17.53	9.20	1.41	76603.08
17	0.65	9.03	54.23	2.38	18.99	8.75	1.42	80136.25
18	0.13	2.57	52.89	1.95	16.74	9.31	1.41	77046.10
19	0.07	1.25	60.47	1.84	17.10	9.67	1.46	79190.84
20	3.70	5.42	60.34	2.36	15.89	9.83	1.44	76899.44
21	3.58	3.74	63.02	2.00	17.87	9.48	1.43	79134.04
22	1.66	1.90	60.93	1.97	17.27	9.60	1.41	74763.90
23	2.19	2.83	59.77	2.05	17.48	9.33	1.41	76481.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.18	4.69	60.37	2.26	16.61	9.56	1.43	75363.96
最 大 值	11.65	10.46	68.46	3.03	18.99	10.17	1.48	80136.25
發生時間	10	6	12	10	17	5		17
最 小 值	0.07	1.07	52.89	1.84	13.78	8.75	1.39	70043.84
發生時間	19	8	18	19	5	17		5
零點偏移(率)	-0.10 %	-0.00 %	-0.16 %	-0.02 %		-0.06		-0.10 %
全幅偏移(率)	0.02 %	-0.92 %	-0.64 %	-0.01 %		0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								