

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.32	2.47	61.54	3.72	17.18	11.43	1.40	66481.39
1	7.33	2.16	71.54	3.21	19.28	10.67	1.41	72792.53
2	8.79	2.65	50.68	3.91	16.93	11.50	1.41	68967.52
3	15.13	3.51	64.10	5.59	15.31	11.62	1.41	68514.80
4	1.46	9.07	53.86	4.98	13.54	12.34	1.40	63947.08
5	3.70	2.68	56.27	3.58	16.33	11.36	1.40	59239.68
6	5.00	1.43	52.78	3.58	18.22	11.01	1.39	70265.35
7	8.86	1.69	40.56	4.29	17.22	11.24	1.39	68304.45
8	8.13	1.74	46.17	4.18	16.98	11.06	1.35	70306.80
9	8.59	1.46	59.63	4.06	17.37	11.20	1.36	70095.79
10	5.05	2.64	44.88	4.14	16.08	11.47	1.39	67448.18
11	6.15	1.73	65.41	3.65	18.32	10.83	1.38	71623.71
12	7.40	2.13	55.22	4.24	16.39	11.47	1.36	66505.51
13	10.01	1.66	60.82	4.60	17.25	10.95	1.37	71273.92
14	9.09	7.66	52.60	5.90	14.90	11.41	1.36	67346.49
15	6.85	4.19	59.52	5.13	15.14	11.89	1.37	65917.01
16	7.31	2.29	64.39	4.07	16.54	11.42	1.40	69442.53
17	6.46	6.00	54.99	4.76	14.55	12.23	1.39	64782.64
18	10.27	2.34	59.04	4.41	15.49	11.23	1.39	72128.14
19	5.15	5.66	52.17	5.00	13.73	12.19	1.40	64994.92
20	7.63	3.49	64.56	4.35	15.28	11.62	1.40	69395.46
21	7.90	3.73	50.59	4.35	15.35	11.46	1.40	70097.50
22	7.43	2.20	55.45	4.97	15.63	11.33	1.40	70522.30
23	8.22	2.43	57.57	4.51	15.94	11.16	1.39	70424.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.38	3.21	56.43	4.38	16.21	11.42	1.39	68367.40
最大值	15.13	9.07	71.54	5.90	19.28	12.34	1.42	72792.53
發生時間	3	4	1	14	1	4		1
最小值	1.46	1.43	40.56	3.21	13.54	10.67	1.32	59239.68
發生時間	4	6	7	1	4	1		5
零點偏移(率)	-0.02 %	-0.02 %	-0.02 %	-0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	0.06 %	0.04 %	-0.65 %	0.36 %		0.19	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.53	2.35	47.48	1.12	18.89	9.51	1.45	76155.58
1	0.08	2.46	40.50	0.73	20.79	9.87	1.43	74788.30
2	2.35	6.24	35.01	1.28	19.71	8.97	1.43	81971.24
3	10.19	3.89	51.88	2.57	18.52	9.27	1.42	82187.49
4	10.06	6.31	41.31	4.02	17.80	9.21	1.42	78625.76
5	8.98	2.17	63.86	4.74	17.45	9.94	1.43	81466.17
6	11.10	2.55	54.29	1.44	20.27	9.26	1.42	86497.79
7	9.52	2.36	52.30	1.59	20.05	9.45	1.42	82305.28
8	9.97	1.77	49.81	1.49	20.22	9.26	1.43	84391.23
9	8.49	2.72	43.61	1.54	20.12	8.95	1.41	85909.60
10	4.83	1.87	56.91	1.51	18.71	10.22	1.40	78540.33
11	5.18	2.27	47.68	1.60	18.54	9.69	1.40	81619.87
12	7.62	3.47	46.52	2.03	17.87	9.49	1.39	82255.19
13	1.99	2.07	49.49	1.55	17.28	9.62	1.39	80894.35
14	6.95	2.14	53.66	2.19	17.12	9.94	1.38	83644.71
15	9.14	2.23	50.36	2.59	16.18	10.68	1.38	82857.19
16	9.60	2.04	51.31	2.64	16.35	10.56	1.39	82318.82
17	6.62	2.25	48.85	1.50	19.15	9.66	1.41	83013.73
18	8.64	2.44	47.88	1.39	19.72	9.54	1.41	83166.85
19	9.18	4.21	49.07	1.31	19.88	9.20	1.40	85600.05
20	9.09	5.01	41.23	1.99	17.39	9.52	1.38	80315.72
21	10.28	3.15	55.19	1.70	19.02	9.36	1.38	85261.08
22	9.52	2.15	54.93	1.92	17.11	9.99	1.38	83171.91
23	9.94	1.84	59.47	1.88	17.77	9.92	1.39	84301.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.54	2.92	49.69	1.93	18.58	9.63	1.40	82135.84
最大值	11.10	6.31	63.86	4.74	20.79	10.68	1.45	86497.79
發生時間	6	4	5	5	1	15		6
最小值	0.08	1.77	35.01	0.73	16.18	8.95	1.38	74788.30
發生時間	1	8	2	1	15	9		1
零點偏移(率)	-0.01 %	-0.04 %	-0.02 %	-0.03 %		0.01	0.00	-0.10 %
全幅偏移(率)	1.24 %	0.03 %	-0.30 %	0.41 %		0.09	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.65	2.66	60.13	2.58	17.46	10.71	1.33	77816.18
1	7.98	4.69	53.79	2.32	19.46	10.62	1.35	78398.12
2	6.71	2.85	60.64	2.42	17.89	10.71	1.37	78369.03
3	19.79	8.18	59.22	4.77	15.01	10.67	1.38	81789.57
4	3.29	1.76	59.23	4.18	15.07	11.08	1.38	79437.44
5	8.05	1.91	64.51	4.02	15.40	11.09	1.37	78243.11
6	3.42	3.21	58.36	2.88	17.92	10.46	1.38	82013.52
7	6.97	2.98	56.61	2.89	16.03	10.65	1.31	76586.26
8	8.90	2.51	57.24	2.83	17.65	10.34	1.31	78143.96
9	9.85	4.36	55.27	3.03	16.26	10.32	1.37	78203.34
10	7.06	10.81	58.66	3.67	15.56	10.53	1.30	79144.54
11	3.28	1.84	62.89	2.76	16.19	10.88	1.30	77493.87
12	4.48	3.38	56.03	2.82	16.53	10.31	1.30	79190.25
13	5.93	2.41	62.35	3.42	14.95	10.76	1.27	75705.46
14	5.32	4.89	54.73	3.82	14.28	10.90	1.24	76098.10
15	7.27	8.72	56.43	4.77	14.54	10.85	1.27	77505.52
16	9.58	7.96	60.45	3.62	15.68	10.58	1.25	76193.54
17	9.50	2.07	68.48	3.12	18.20	10.48	1.27	76875.84
18	10.34	6.18	54.52	3.06	17.31	10.15	1.27	80249.99
19	7.83	6.31	57.10	3.06	15.66	10.47	1.29	79586.07
20	6.33	3.58	62.69	2.82	17.46	10.54	1.30	79648.36
21	11.85	2.62	62.35	3.57	16.06	10.54	1.30	79616.04
22	9.26	2.02	57.04	3.12	16.72	10.43	1.30	78859.52
23	9.28	2.68	57.92	3.40	16.52	10.29	1.30	80009.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.91	4.19	59.03	3.29	16.41	10.60	1.31	78549.04
最大值	19.79	10.81	68.48	4.77	19.46	11.09	1.38	82013.52
發生時間	3	10	17	3	1	5		6
最小值	3.28	1.76	53.79	2.32	14.28	10.15	1.22	75705.46
發生時間	11	4	1	1	14	18		13
零點偏移(率)	-0.01 %	-0.02 %	-0.03 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	4.69 %	0.54 %	-1.01 %	0.68 %		0.43	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								