

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.03	3.78	48.05	1.22	18.54	11.57	1.13	71932.17
1	9.61	12.88	56.42	1.23	19.70	10.54	1.11	78426.34
2	9.40	11.99	48.91	1.49	18.94	10.66	1.11	76139.59
3	9.43	11.18	53.28	1.23	18.47	11.02	1.10	75037.62
4	8.32	11.43	61.23	1.20	18.24	11.44	1.11	73606.21
5	6.67	11.28	63.15	1.02	19.66	10.59	1.11	76017.89
6	9.11	9.24	44.70	1.03	20.20	10.05	1.10	80051.13
7	7.86	11.92	67.71	0.71	19.69	11.13	1.11	72331.03
8	9.39	11.53	52.76	0.80	19.97	10.45	1.12	79070.62
9	3.60	12.46	65.76	0.47	19.42	11.92	1.15	68255.04
10	0.14	8.69	61.29	0.72	18.41	12.37	1.35	65959.40
11	1.35	6.44	38.81	0.68	18.76	10.56	1.11	77522.94
12	8.18	4.58	53.11	1.31	16.63	10.91	1.10	76591.95
13	8.48	8.00	49.38	2.45	15.58	11.01	1.08	71866.25
14	7.18	6.55	48.06	1.62	17.08	11.04	1.10	74366.73
15	8.80	6.54	48.14	1.19	18.81	10.71	1.12	77464.35
16	7.96	8.45	55.21	1.22	18.40	11.31	1.12	74229.30
17	1.00	10.09	58.13	0.69	18.85	11.80	1.16	71012.04
18	8.23	8.02	49.54	1.12	18.48	10.87	1.10	78067.44
19	9.28	7.07	61.98	1.75	16.87	11.68	1.10	73096.36
20	9.58	6.25	56.67	1.44	18.66	10.89	1.10	77560.41
21	9.84	7.02	49.89	1.44	18.18	11.01	1.10	77080.85
22	9.04	8.75	51.32	1.54	17.13	11.66	1.12	73319.37
23	9.21	7.52	62.65	0.58	19.55	11.09	1.10	75272.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.53	8.82	54.42	1.17	18.51	11.09	1.12	74761.58
最大值	9.84	12.88	67.71	2.45	20.20	12.37	1.66	80051.13
發生時間	21	1	7	13	6	10		6
最小值	0.14	3.78	38.81	0.47	15.58	10.05	1.07	65959.40
發生時間	10	0	11	9	13	6		10
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.02 %		0.01		0.00 %
全幅偏移(率)	-0.63 %	0.51 %	0.24 %	0.06 %		0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.73	4.51	53.41	1.49	18.06	10.35	1.06	84011.88
1	7.44	6.51	52.93	1.80	18.55	10.06	1.05	86927.08
2	9.71	6.38	59.50	2.47	16.30	10.46	1.05	85061.15
3	8.42	5.01	63.39	1.46	17.62	10.58	1.06	83479.18
4	9.13	5.63	52.68	1.64	18.39	10.02	1.05	87153.08
5	7.19	6.60	60.67	1.54	17.86	10.51	1.06	83673.18
6	8.18	4.33	54.44	2.08	17.65	10.31	1.08	89916.42
7	7.19	4.53	51.05	1.71	17.50	10.55	1.08	83462.19
8	3.11	3.82	48.80	1.03	19.41	10.21	1.08	84453.75
9	1.05	3.87	59.34	1.20	19.09	10.51	1.06	81914.89
10	3.68	5.88	52.85	1.26	19.06	9.38	1.06	90691.23
11	7.27	5.23	64.90	2.94	15.46	10.38	1.07	86068.25
12	9.49	5.26	53.18	3.43	14.61	10.76	1.07	84120.26
13	7.78	7.26	43.16	2.68	16.37	10.34	1.10	86351.37
14	10.22	5.74	45.33	2.57	15.78	10.50	1.08	85715.36
15	9.76	8.05	52.21	1.92	16.75	10.33	1.05	85579.11
16	8.69	6.96	53.80	1.81	16.94	10.62	1.05	83804.82
17	9.04	9.24	48.14	2.33	16.07	10.51	1.06	85355.99
18	7.30	4.43	50.17	2.44	16.02	10.69	1.07	84222.53
19	9.40	9.91	52.08	3.26	15.20	10.61	1.07	85256.15
20	8.93	12.78	40.33	2.17	16.44	10.35	1.07	86681.95
21	9.07	5.66	54.34	2.17	16.62	10.27	1.07	86278.81
22	9.17	6.78	47.15	1.61	16.88	10.70	1.07	82602.38
23	8.77	4.17	39.57	1.74	17.53	10.09	1.07	87235.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.82	6.19	52.23	2.03	17.09	10.38	1.07	85417.37
最大值	10.22	12.78	64.90	3.43	19.41	10.76	1.11	90691.23
發生時間	14	20	11	12	8	12		10
最小值	1.05	3.82	39.57	1.03	14.61	9.38	1.05	81914.89
發生時間	9	8	23	8	12	10		9
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	-0.01 %		0.04		-0.20 %
全幅偏移(率)	-0.01 %	0.86 %	-0.73 %	-0.06 %		-0.08		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.06	5.80	51.11	0.84	16.60	10.69	0.98	76435.82
1	7.45	7.96	46.12	0.91	17.11	10.77	0.97	76586.56
2	5.60	8.33	57.37	1.10	15.70	11.27	0.97	73443.42
3	9.89	8.53	52.10	1.54	15.16	11.01	0.97	75677.69
4	8.76	7.75	54.29	1.61	15.15	11.17	0.97	74647.83
5	11.70	8.60	52.65	1.91	15.20	10.80	0.97	77644.83
6	11.58	5.23	54.93	1.87	14.73	10.80	0.97	75437.73
7	12.73	4.19	54.92	1.54	15.62	10.95	0.97	71326.58
8	8.87	4.48	50.15	1.60	15.25	10.69	0.99	83101.28
9	8.32	5.24	58.10	1.00	16.88	11.01	0.99	81705.69
10	9.08	6.75	48.68	0.73	18.15	10.20	1.01	89655.97
11	8.19	7.66	61.92	1.72	14.33	11.55	1.00	79012.52
12	9.20	6.14	48.60	4.18	13.11	11.11	0.98	73923.42
13	7.32	4.61	52.06	2.53	13.19	11.14	0.99	76143.25
14	11.16	3.82	51.52	2.37	14.32	10.98	0.98	79892.72
15	7.93	4.20	55.56	2.01	14.75	11.00	0.99	78675.22
16	9.96	4.93	60.49	1.71	14.75	11.14	1.01	77563.61
17	7.33	8.97	54.47	1.07	15.69	10.67	0.98	77594.21
18	8.50	4.35	46.01	1.21	15.93	10.58	0.97	76540.37
19	8.55	4.40	51.76	1.26	15.63	10.63	0.97	78602.35
20	7.90	4.69	48.77	1.52	14.70	10.93	0.97	72887.78
21	8.95	4.56	49.78	1.30	15.74	10.47	0.97	76332.84
22	8.48	2.21	53.64	1.38	15.87	10.55	0.97	77470.10
23	9.00	4.50	47.10	1.29	15.62	10.57	0.98	78974.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.98	5.75	52.59	1.59	15.38	10.86	0.98	77469.86
最大值	12.73	8.97	61.92	4.18	18.15	11.55	1.08	89655.97
發生時間	7	17	11	12	10	11		10
最小值	5.60	2.21	46.01	0.73	13.11	10.20	0.96	71326.58
發生時間	2	22	18	10	12	10		7
零點偏移(率)	-0.08 %	0.00 %	-0.04 %	0.00 %		0.03		0.00 %
全幅偏移(率)	0.04 %	-0.82 %	-0.86 %	0.01 %		0.22		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								