

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月24日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.58	7.37	45.32	0.91	14.90	11.88	1.08	81915.61
1	8.13	7.69	48.74	0.63	15.82	11.84	1.08	81357.36
2	4.56	6.96	47.39	0.49	16.07	11.19	1.09	86521.05
3	5.84	7.14	41.90	1.07	14.90	11.71	1.10	83453.28
4	7.54	9.03	44.43	0.54	15.77	11.64	1.10	82997.71
5	5.90	11.17	43.54	0.91	14.96	12.10	1.11	80788.74
6	8.22	10.67	51.62	0.86	15.43	12.19	1.11	78797.09
7	8.17	8.00	48.69	0.51	16.24	11.59	1.11	83094.33
8	4.35	8.39	66.66	0.54	16.18	12.03	1.14	79537.54
9	5.85	8.17	43.80	0.90	16.12	11.42	1.13	84874.37
10	6.45	8.80	37.58	1.08	16.53	11.34	1.13	85600.66
11	8.26	3.15	51.46	0.97	16.30	11.78	1.14	81814.86
12	8.28	2.23	56.71	0.24	18.09	10.93	1.15	87252.17
13	9.61	2.21	46.13	0.49	17.46	10.74	1.14	89068.69
14	9.41	2.51	28.67	0.50	17.43	11.13	1.13	85704.16
15	10.65	4.13	32.33	1.69	15.02	11.31	1.13	86533.67
16	8.14	2.22	36.20	1.12	15.99	11.44	1.13	84908.76
17	9.41	2.27	41.61	0.49	17.11	11.13	1.13	86768.93
18	9.42	2.30	40.06	0.92	15.99	11.50	1.13	84312.75
19	9.15	2.06	43.48	0.68	16.69	11.29	1.14	85451.50
20	7.67	2.12	41.57	1.05	15.23	11.54	1.14	85035.65
21	7.80	4.22	42.81	0.71	15.48	11.47	1.14	85069.70
22	7.73	7.14	46.05	1.20	15.00	11.95	1.14	80770.32
23	9.99	6.73	55.86	0.38	17.17	11.18	1.13	85634.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.92	5.69	45.11	0.79	16.08	11.51	1.12	84052.66
最 大 值	10.65	11.17	66.66	1.69	18.09	12.19	1.18	89068.69
發生時間	15	5	8	15	12	6		13
最 小 值	4.35	2.06	28.67	0.24	14.90	10.74	1.07	78797.09
發生時間	8	19	14	12	0	13		6
零點偏移(率)	-0.05 %	0.01 %	-0.01 %	0.00 %		0.01		0.30 %
全幅偏移(率)	0.02 %	-0.12 %	0.21 %	0.01 %		0.21		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月24日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	1.34	4.67	50.98	0.70	13.96	10.71	1.11	76209.72
1	0.94	4.02	48.35	0.37	15.28	10.27	1.14	79793.37
2	0.55	4.78	45.08	0.35	15.37	10.52	1.13	77725.41
3	1.18	9.05	55.66	0.43	16.30	10.59	1.11	80897.95
4	1.13	8.63	46.87	0.56	14.53	10.45	1.10	79149.13
5	1.66	7.12	56.05	0.99	14.02	11.07	1.12	79028.33
6	1.44	2.89	59.32	0.24	17.23	10.04	1.15	84910.10
7	0.09	9.80	44.31	0.24	16.16	10.15	1.11	84675.30
8	0.97	8.26	47.62	1.03	17.35	10.05	1.09	82587.04
9	5.13	3.90	34.82	1.85	15.33	9.68	1.06	75570.44
10	8.29	2.66	32.62	1.70	15.66	9.76	1.04	72867.68
11	4.96	1.52	42.33	0.44	16.51	10.12	1.08	77992.89
12	1.23	1.82	45.14	0.22	17.17	10.05	1.10	80162.41
13	2.88	1.80	55.09	0.12	17.88	10.16	1.10	76873.56
14	7.72	5.81	42.70	0.64	16.25	9.76	1.10	82979.40
15	8.01	3.69	38.27	0.86	14.65	10.57	1.10	75762.37
16	5.33	1.75	40.53	0.29	16.90	9.87	1.13	82597.26
17	3.96	1.85	46.56	0.46	16.07	10.25	1.12	82756.87
18	3.19	5.37	46.61	0.59	15.34	10.47	1.12	81286.69
19	4.26	4.78	47.34	1.08	14.21	10.72	1.12	79467.84
20	4.96	1.71	51.51	0.77	15.59	10.54	1.12	80804.70
21	15.27	5.59	40.55	1.27	16.51	9.90	1.14	84042.09
22	3.09	2.65	41.72	0.54	16.59	10.13	1.11	77648.01
23	0.97	4.99	45.50	0.17	16.67	10.20	1.11	78687.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.69	4.55	46.06	0.66	15.90	10.25	1.11	79769.85
最 大 值	15.27	9.80	59.32	1.85	17.88	11.07	1.15	84910.10
發生時間	21	7	6	9	13	5		6
最 小 值	0.09	1.52	32.62	0.12	13.96	9.68	1.04	72867.68
發生時間	7	11	10	13	0	9		10
零點偏移(率)	-0.13 %	-0.00 %	-0.02 %	-0.02 %		0.08		0.20 %
全幅偏移(率)	0.01 %	-0.13 %	0.04 %	-0.04 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								