

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月01日

報表日期: 113年03月01日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.53	6.67	57.38	0.97	18.16	11.40	1.02	81893.16
1	8.32	6.75	55.88	1.37	17.27	11.91	1.03	79195.71
2	9.63	6.40	48.53	2.02	15.79	11.59	0.99	83713.83
3	8.55	6.03	62.03	1.49	16.27	11.77	1.01	81912.44
4	9.11	6.16	53.17	1.60	15.43	11.69	1.01	83157.25
5	9.83	9.33	60.85	1.66	15.87	11.85	1.02	79644.27
6	8.90	5.86	50.61	1.36	15.95	11.71	1.02	82304.30
7	9.51	5.73	52.84	1.64	15.56	11.63	1.02	83114.35
8	9.37	5.36	50.19	2.72	14.00	11.90	1.02	82080.06
9	7.75	6.21	54.34	2.29	14.34	12.36	1.04	77751.41
10	9.94	9.84	49.40	3.22	14.23	11.83	1.05	82159.30
11	9.28	7.09	59.94	2.44	14.38	12.13	1.06	79185.05
12	11.28	6.35	62.60	1.92	14.89	12.07	1.06	80016.31
13	10.10	7.75	48.78	3.80	12.21	12.32	1.06	79808.80
14	10.56	6.69	47.41	2.96	12.17	12.36	1.06	80490.27
15	9.47	4.58	47.38	3.19	11.80	12.66	1.05	77298.46
16	10.15	2.68	53.38	3.22	13.28	12.21	1.05	80318.70
17	8.65	2.52	57.29	1.47	15.23	11.75	1.06	82784.15
18	9.41	2.65	45.48	2.33	15.30	11.50	1.05	84639.26
19	10.01	4.75	47.53	4.26	13.69	12.23	1.03	79798.66
20	9.01	2.04	55.57	2.38	15.07	12.16	1.03	79210.30
21	9.30	1.93	57.24	1.44	15.97	11.64	1.02	82896.76
22	10.39	4.63	54.36	1.35	16.17	11.43	1.02	84546.07
23	6.70	4.75	63.13	0.90	16.52	11.74	1.02	80864.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.32	5.53	53.97	2.17	14.98	11.91	1.03	81199.29
最 大 值	11.28	9.84	63.13	4.26	18.16	12.66	1.06	84639.26
發生時間	12	10	23	19	0	15		18
最 小 值	6.70	1.93	45.48	0.90	11.80	11.40	0.97	77298.46
發生時間	23	21	18	23	15	0		15
零點偏移(率)	-0.05 %	-0.00 %	-0.03 %	-0.01 %		-0.03		0.30 %
全幅偏移(率)	0.00 %	-0.80 %	0.20 %	-0.09 %		0.23		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月01日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.11	5.66	57.26	1.12	16.49	10.87	1.10	79423.24
1	6.98	3.59	56.92	1.07	17.19	10.44	1.10	82324.69
2	8.03	3.63	57.15	1.53	16.29	10.53	1.10	81770.54
3	8.35	4.44	60.97	1.73	15.60	11.00	1.10	78996.47
4	8.56	3.70	58.29	1.18	16.34	10.67	1.11	81599.34
5	8.70	3.89	57.19	1.49	15.40	10.79	1.10	81568.60
6	6.86	3.84	54.74	1.28	15.84	10.55	1.09	80725.25
7	8.91	3.55	54.61	1.05	16.66	10.25	1.10	81736.23
8	6.58	3.41	50.06	1.61	14.75	10.63	1.09	78935.61
9	7.82	3.29	60.80	1.75	14.89	10.83	1.10	79357.26
10	9.10	3.66	55.82	2.71	13.01	11.06	1.11	76400.72
11	7.41	3.93	56.10	2.85	12.46	11.13	1.15	75886.77
12	8.64	2.99	60.06	2.67	12.59	11.13	1.13	76050.83
13	3.19	3.12	62.69	2.90	12.80	11.31	1.13	73632.68
14	6.03	3.96	57.54	2.70	13.82	11.05	1.13	77533.81
15	6.31	8.70	50.28	3.90	11.78	11.22	1.12	71923.19
16	7.43	3.60	57.77	4.24	12.37	11.54	1.12	73132.50
17	6.88	3.55	57.89	1.81	14.23	11.01	1.13	77672.24
18	7.48	5.15	58.41	1.51	15.21	10.66	1.12	78823.12
19	9.53	2.50	58.92	3.02	15.07	10.87	1.10	78865.83
20	8.55	6.14	60.42	1.70	17.00	10.46	1.10	81436.11
21	7.44	6.02	62.44	1.32	16.45	10.70	1.10	80736.58
22	4.34	6.48	46.84	0.55	17.49	10.46	1.10	81795.65
23	6.73	10.68	47.18	0.57	17.48	10.29	1.10	82956.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.41	4.56	56.68	1.93	15.05	10.81	1.11	78886.84
最 大 值	9.53	10.68	62.69	4.24	17.49	11.54	1.16	82956.92
發生時間	19	23	13	16	22	16		23
最 小 值	3.19	2.50	46.84	0.55	11.78	10.25	1.08	71923.19
發生時間	13	19	22	22	15	7		15
零點偏移(率)	0.00 %	-0.01 %	-0.08 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	-0.51 %	-0.52 %	-0.12 %		0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								