

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月03日

報表日期: 114年06月03日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月03日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 6.10     | 1.60     | 53.85    | 1.93     | 17.30    | 10.70    | 1.02     | 82829.01  |
| 1                 | 1.67     | 4.79     | 55.13    | 2.70     | 17.18    | 10.83    | 1.01     | 80870.55  |
| 2                 | 4.39     | 2.61     | 62.72    | 3.04     | 16.96    | 10.79    | 1.01     | 83178.08  |
| 3                 | 7.07     | 7.21     | 57.20    | 2.21     | 18.28    | 10.29    | 1.01     | 82380.48  |
| 4                 | 6.42     | 1.87     | 59.71    | 1.80     | 17.93    | 10.33    | 1.02     | 81122.56  |
| 5                 | 2.54     | 2.33     | 55.13    | 1.89     | 18.23    | 10.63    | 1.02     | 80871.60  |
| 6                 | 6.61     | 1.85     | 59.78    | 1.51     | 18.74    | 10.49    | 1.04     | 82655.60  |
| 7                 | 3.14     | 2.86     | 56.71    | 2.08     | 17.40    | 10.74    | 1.03     | 81435.69  |
| 8                 | 3.56     | 2.03     | 53.16    | 2.53     | 17.14    | 10.70    | 1.04     | 82483.95  |
| 9                 | 2.43     | 4.20     | 65.31    | 2.56     | 17.36    | 10.69    | 1.04     | 82707.00  |
| 10                | 5.76     | 3.95     | 58.98    | 2.04     | 17.78    | 10.04    | 1.04     | 86569.05  |
| 11                | 8.46     | 4.76     | 56.22    | 2.59     | 16.13    | 10.56    | 1.02     | 82095.32  |
| 12                | 9.04     | 9.36     | 67.06    | 3.14     | 15.23    | 10.86    | 1.02     | 81145.11  |
| 13                | 13.15    | 3.15     | 63.83    | 3.07     | 15.60    | 10.88    | 1.02     | 82117.20  |
| 14                | 1.82     | 2.52     | 60.63    | 2.57     | 15.90    | 10.72    | 1.01     | 82878.84  |
| 15                | 7.73     | 5.22     | 60.81    | 3.10     | 14.68    | 10.97    | 1.02     | 80334.82  |
| 16                | 11.67    | 8.04     | 55.30    | 3.76     | 15.05    | 10.63    | 1.02     | 85182.63  |
| 17                | 6.51     | 2.46     | 46.59    | 2.85     | 15.95    | 10.65    | 1.02     | 86349.03  |
| 18                | 6.42     | 2.15     | 41.54    | 2.23     | 17.60    | 9.98     | 1.02     | 89762.37  |
| 19                | 6.43     | 2.31     | 46.32    | 2.66     | 15.40    | 10.66    | 1.02     | 84597.75  |
| 20                | 12.78    | 4.61     | 56.02    | 3.50     | 15.58    | 10.59    | 1.02     | 83749.56  |
| 21                | 9.96     | 2.11     | 46.74    | 2.25     | 16.96    | 10.12    | 1.02     | 84487.09  |
| 22                | 3.56     | 1.82     | 49.95    | 2.55     | 16.46    | 10.33    | 1.02     | 84565.77  |
| 23                | 11.11    | 1.67     | 54.34    | 2.89     | 16.54    | 10.79    | 1.02     | 80826.32  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均 值              | 6.60     | 3.56     | 55.96    | 2.56     | 16.72    | 10.58    | 1.02     | 83133.14  |
| 最大 值              | 13.15    | 9.36     | 67.06    | 3.76     | 18.74    | 10.97    | 1.04     | 89762.37  |
| 發生時間              | 13       | 12       | 12       | 16       | 6        | 15       |          | 18        |
| 最小 值              | 1.67     | 1.60     | 41.54    | 1.51     | 14.68    | 9.98     | 1.00     | 80334.82  |
| 發生時間              | 1        | 0        | 18       | 6        | 15       | 18       |          | 15        |
| 零點偏移(率)           | -0.03 %  | -0.05 %  | -0.02 %  | -0.10 %  |          | -0.07    |          | -0.10 %   |
| 全幅偏移(率)           | 0.14 %   | -0.03 %  | -0.66 %  | 0.34 %   |          | -0.34    |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月03日

| 項目<br>單位<br>小時\限標 | #3-HCl_C<br>ppm | #3-CO_C<br>ppm | #3-NOx_C<br>ppm | #3-SO2_C<br>ppm | #3-H2O<br>% | #3-O2_C<br>% | #3-OPAC<br>% | #3-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 0.61            | 2.39           | 56.41           | 2.91            | 18.03       | 9.01         | 1.48         | 75982.46             |
| 1                 | 4.91            | 5.59           | 59.80           | 3.29            | 17.92       | 8.99         | 1.49         | 75292.15             |
| 2                 | 6.81            | 3.71           | 61.28           | 3.38            | 17.17       | 9.44         | 1.48         | 79955.58             |
| 3                 | 5.79            | 3.46           | 61.36           | 3.59            | 15.29       | 9.90         | 1.48         | 78333.23             |
| 4                 | 3.81            | 7.08           | 61.73           | 3.73            | 14.66       | 9.90         | 1.46         | 77593.37             |
| 5                 | 1.40            | 4.07           | 60.47           | 3.01            | 15.78       | 9.59         | 1.46         | 77761.83             |
| 6                 | 5.27            | 6.25           | 59.05           | 3.36            | 15.65       | 9.56         | 1.47         | 80582.76             |
| 7                 | 13.67           | 4.83           | 61.15           | 2.36            | 15.58       | 9.78         | 1.48         | 83587.92             |
| 8                 | 5.52            | 3.23           | 62.11           | 1.74            | 17.86       | 9.07         | 1.45         | 76684.25             |
| 9                 | 6.26            | 5.11           | 63.99           | 1.97            | 17.78       | 8.63         | 1.43         | 79825.66             |
| 10                | 9.95            | 6.68           | 63.03           | 2.01            | 16.54       | 8.97         | 1.43         | 76542.34             |
| 11                | 8.52            | 9.43           | 57.81           | 2.01            | 16.15       | 9.16         | 1.47         | 77013.29             |
| 12                | 0.95            | 3.33           | 65.82           | 3.38            | 19.20       | 8.78         | 1.43         | 73175.88             |
| 13                | 11.47           | 3.79           | 60.66           | 4.47            | 18.83       | 7.84         | 1.44         | 81289.04             |
| 14                | 11.37           | 11.22          | 57.82           | 2.18            | 17.12       | 8.98         | 1.43         | 78874.54             |
| 15                | 4.41            | 12.16          | 49.70           | 2.85            | 16.99       | 8.73         | 1.43         | 78075.00             |
| 16                | 1.47            | 5.85           | 49.01           | 3.17            | 16.47       | 8.64         | 1.43         | 78189.00             |
| 17                | 7.65            | 3.55           | 55.16           | 4.03            | 17.08       | 8.85         | 1.43         | 81534.09             |
| 18                | 11.94           | 5.76           | 53.50           | 2.39            | 16.98       | 8.41         | 1.42         | 81815.43             |
| 19                | 7.94            | 3.95           | 63.16           | 1.23            | 17.77       | 8.23         | 1.43         | 83349.99             |
| 20                | 6.23            | 2.24           | 56.56           | 3.02            | 15.48       | 9.19         | 1.43         | 80305.99             |
| 21                | 12.60           | 3.40           | 58.13           | 3.10            | 16.56       | 8.60         | 1.43         | 79113.58             |
| 22                | 6.90            | 4.66           | 59.57           | 1.99            | 15.52       | 9.42         | 1.43         | 76404.30             |
| 23                | 6.84            | 3.71           | 66.87           | 2.10            | 17.72       | 9.33         | 1.43         | 74723.05             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 6.76            | 5.23           | 59.34           | 2.80            | 16.84       | 9.04         | 1.45         | 78583.53             |
| 最 大 值             | 13.67           | 12.16          | 66.87           | 4.47            | 19.20       | 9.90         | 1.50         | 83587.92             |
| 發生時間              | 7               | 15             | 23              | 13              | 12          | 3            |              | 7                    |
| 最 小 值             | 0.61            | 2.24           | 49.01           | 1.23            | 14.66       | 7.84         | 1.41         | 73175.88             |
| 發生時間              | 0               | 20             | 16              | 19              | 4           | 13           |              | 12                   |
| 零點偏移(率)           | 0.00 %          | 0.00 %         | -0.03 %         | 0.00 %          |             | -0.05        |              | -0.10 %              |
| 全幅偏移(率)           | 0.02 %          | 0.58 %         | -0.84 %         | 0.14 %          |             | 0.14         |              | 0.00 %               |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |