

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月04日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.74	4.61	57.76	2.35	15.28	10.60	0.91	86786.81
1	7.74	0.97	56.18	2.23	16.42	10.98	0.90	82332.53
2	5.86	2.43	41.25	3.03	14.47	10.90	0.90	83045.72
3	7.79	1.88	42.34	3.12	14.29	11.17	0.90	82414.52
4	3.54	3.11	41.37	3.18	12.58	11.31	0.89	79431.17
5	3.51	4.13	53.46	3.06	13.01	11.33	0.89	82275.58
6	12.62	1.49	58.59	2.38	13.20	11.43	0.88	81260.93
7	9.55	2.29	52.36	1.49	13.73	11.31	0.88	81763.13
8	9.89	4.87	49.48	1.89	13.49	11.17	0.89	80966.06
9	6.36	2.17	55.09	2.86	13.04	11.41	0.90	81068.98
10	2.77	1.19	55.65	2.00	13.17	11.07	0.90	80523.40
11	2.20	1.28	51.93	2.02	14.75	11.01	0.90	79657.06
12	3.39	4.69	32.32	2.12	16.31	10.33	0.89	82632.31
13	9.93	2.07	37.61	2.98	14.39	11.24	0.90	82812.31
14	4.31	2.32	38.72	1.62	13.44	11.29	0.88	79792.98
15	8.86	2.71	49.74	1.87	12.75	11.25	0.86	80104.84
16	10.27	2.29	59.87	2.03	12.71	11.19	0.85	80883.86
17	9.82	3.64	64.58	1.95	12.66	11.11	0.88	81027.26
18	8.83	2.20	60.01	1.55	12.19	11.43	0.89	79303.97
19	8.49	1.75	56.93	1.23	13.03	11.34	0.90	82051.94
20	7.58	1.45	55.30	1.25	13.39	11.27	0.90	83882.63
21	8.35	1.55	57.14	1.50	13.18	11.36	0.90	84159.87
22	8.47	2.62	55.55	2.69	12.87	11.40	0.90	83247.85
23	8.78	1.42	56.93	2.20	13.79	11.16	0.90	84748.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.40	2.46	51.67	2.19	13.67	11.17	0.89	81923.94
最 大 值	12.62	4.87	64.58	3.18	16.42	11.43	0.94	86786.81
發生時間	6	8	17	4	1	6		0
最 小 值	2.20	0.97	32.32	1.23	12.19	10.33	0.84	79303.97
發生時間	11	1	12	19	18	12		18
零點偏移(率)	-0.01 %	-0.06 %	-0.09 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.14 %	0.07 %	-0.49 %	0.46 %		0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.93	2.80	59.55	1.20	15.82	10.21	1.67	75855.10
1	10.29	5.97	55.07	1.29	16.49	10.01	1.69	78262.44
2	10.38	4.74	39.41	1.31	16.27	10.38	1.70	77796.81
3	10.71	5.60	41.64	3.29	14.64	10.58	1.69	74575.35
4	13.72	4.71	37.80	3.33	15.35	10.22	1.67	73974.67
5	11.23	5.63	46.77	2.79	15.47	10.06	1.65	75077.81
6	10.60	2.47	57.21	0.92	15.45	10.30	1.67	75851.12
7	10.41	4.92	56.17	1.86	14.88	10.33	1.71	73824.95
8	11.17	4.11	43.06	2.29	14.80	10.32	1.72	73873.44
9	8.69	2.22	41.67	2.93	14.22	10.62	1.71	72788.35
10	3.39	2.76	42.80	1.46	14.71	10.38	1.71	73540.05
11	1.76	7.41	46.64	0.81	17.56	9.92	1.69	76754.11
12	6.18	6.15	34.13	1.68	16.74	9.83	1.70	76930.39
13	10.59	10.51	40.15	2.56	16.43	10.20	1.71	76631.74
14	10.13	4.23	44.26	2.89	14.09	10.37	1.69	73010.19
15	13.56	7.28	45.44	3.16	14.10	10.31	1.69	71220.66
16	14.01	3.72	40.70	3.34	13.47	10.16	1.70	71175.89
17	9.02	2.53	46.00	1.66	14.88	9.75	1.69	75087.04
18	7.85	4.90	43.94	1.58	14.69	9.74	1.70	75267.83
19	8.44	3.50	47.53	1.70	14.41	9.94	1.71	73665.74
20	7.91	2.12	44.95	1.28	15.03	9.75	1.71	74736.28
21	9.52	2.67	47.56	1.42	15.00	9.76	1.71	75466.52
22	9.43	3.67	47.83	1.70	15.23	9.77	1.71	75520.81
23	10.44	2.03	41.51	1.93	15.11	9.70	1.72	75132.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.56	4.44	45.49	2.02	15.20	10.11	1.70	74834.17
最 大 值	14.01	10.51	59.55	3.34	17.56	10.62	1.74	78262.44
發生時間	16	13	0	16	11	9		1
最 小 值	1.76	2.03	34.13	0.81	13.47	9.70	1.64	71175.89
發生時間	11	23	12	11	16	23		16
零點偏移(率)	-0.08 %	0.00 %	-0.04 %	-0.01 %		-0.03		0.00 %
全幅偏移(率)	0.02 %	-0.43 %	-0.22 %	0.25 %		0.26		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								