

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.64	12.38	70.53	2.85	19.20	10.62	1.21	84543.74
1	8.72	12.68	65.13	3.25	18.96	10.92	1.20	82624.57
2	8.26	12.60	57.50	3.44	19.07	10.81	1.20	83220.42
3	2.25	13.64	66.45	2.40	17.73	11.75	1.22	76850.65
4	0.75	13.24	41.69	1.76	19.62	10.77	1.21	82874.44
5	4.14	12.06	43.44	2.94	18.05	10.58	1.18	83745.79
6	8.91	12.10	44.30	1.65	18.25	10.73	1.18	84904.62
7	9.83	12.37	48.47	1.46	18.44	10.92	1.19	82954.13
8	9.00	12.13	50.13	1.10	20.14	10.34	1.19	86112.53
9	7.62	13.26	54.06	1.30	18.34	11.60	1.18	77890.57
10	8.94	12.24	65.60	1.19	18.09	11.59	1.18	77968.93
11	10.28	11.42	60.29	1.39	18.12	11.20	1.18	81737.30
12	8.62	11.05	60.14	1.18	18.97	10.74	1.18	84300.00
13	9.86	11.31	57.50	1.54	17.46	11.14	1.18	82534.35
14	12.38	11.52	62.74	1.35	18.39	11.24	1.20	81089.62
15	10.04	11.98	61.29	3.45	16.84	11.40	1.19	81601.67
16	8.88	11.74	52.62	2.06	16.75	11.51	1.18	80713.74
17	9.08	11.84	61.73	1.64	18.15	11.37	1.18	80174.57
18	10.33	12.29	51.55	1.83	18.68	10.56	1.18	86215.56
19	7.58	13.02	56.12	1.53	18.29	10.87	1.18	84282.84
20	11.01	13.11	63.96	1.97	16.31	11.43	1.18	81485.93
21	9.58	13.81	59.56	2.48	15.45	11.67	1.17	80121.74
22	6.44	12.93	48.85	1.81	16.66	11.19	1.17	83599.53
23	10.29	12.83	60.52	2.87	18.16	11.08	1.18	82788.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.48	12.40	56.84	2.02	18.09	11.08	1.19	82263.98
最大值	12.38	13.81	70.53	3.45	20.14	11.75	1.23	86215.56
發生時間	14	21	0	15	8	3		18
最小值	0.75	11.05	41.69	1.10	15.45	10.34	1.15	76850.65
發生時間	4	12	4	8	21	8		3
零點偏移(率)	-0.24 %	-0.11 %	-0.01 %	-0.04 %		-0.02	-0.01	0.10 %
全幅偏移(率)	2.74 %	-2.53 %	0.06 %	-0.10 %		-0.24	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.27	12.05	43.57	0.73	20.16	10.21	0.95	82833.65
1	0.33	12.10	45.37	1.14	20.18	10.25	0.95	84089.39
2	0.53	12.83	63.03	1.18	20.33	9.84	0.97	88632.92
3	0.26	12.43	53.45	0.90	18.86	10.69	0.97	83008.42
4	0.55	12.69	54.29	0.68	19.89	10.20	0.97	85705.39
5	0.32	12.29	47.85	1.62	18.42	10.67	0.96	84221.51
6	0.98	11.77	55.97	0.55	19.63	10.54	0.95	83454.77
7	1.06	11.79	61.58	0.90	18.59	10.44	0.96	85462.33
8	1.14	12.44	45.23	0.76	19.49	10.40	0.96	85375.20
9	8.19	12.28	36.61	0.91	19.80	10.61	0.96	80389.75
10	2.01	12.32	42.03	1.03	19.77	10.25	0.94	81543.32
11	1.46	12.40	40.84	0.97	19.90	10.25	0.94	83591.64
12	1.05	12.23	50.76	1.41	18.73	10.72	0.96	81918.71
13	0.84	12.52	53.78	1.84	18.27	10.72	0.94	83758.39
14	1.40	12.14	59.12	1.01	19.21	10.57	0.96	84353.53
15	6.92	12.65	53.42	1.85	17.53	11.03	0.94	81597.49
16	1.15	13.55	53.59	3.23	15.16	11.41	0.94	79353.78
17	1.68	12.58	57.15	1.21	19.08	10.87	0.94	82755.86
18	1.16	13.22	52.90	0.89	20.15	10.18	0.94	86938.19
19	1.20	13.50	52.95	1.46	17.99	10.70	0.94	83767.12
20	1.26	13.72	57.78	1.47	17.39	10.76	0.94	82924.82
21	1.36	13.65	61.10	2.07	16.77	10.94	0.95	83528.63
22	2.90	13.07	54.85	0.81	18.47	10.76	0.95	83803.76
23	5.79	12.62	58.78	1.13	18.39	11.00	0.96	80611.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	1.83	12.62	52.33	1.24	18.84	10.58	0.95	83484.19
最大值	8.19	13.72	63.03	3.23	20.33	11.41	1.00	88632.92
發生時間	9	20	2	16	2	16		2
最小值	0.26	11.77	36.61	0.55	15.16	9.84	0.93	79353.78
發生時間	3	6	9	6	16	2		16
零點偏移(率)	0.06 %	0.00 %	-0.06 %	-0.00 %		-0.01	-0.01	-0.20 %
全幅偏移(率)	1.87 %	-0.91 %	-0.14 %	-1.16 %		0.11	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.42	11.61	59.34	2.68	19.24	9.75	1.39	75216.19
1	6.23	11.88	59.05	2.77	20.31	9.72	1.39	75780.32
2	3.00	11.75	50.76	2.35	20.95	9.50	1.39	71731.90
3	3.52	11.31	50.39	2.58	20.09	9.42	1.39	73483.01
4	2.75	12.52	45.47	2.43	18.66	9.28	1.40	76110.70
5	7.88	11.84	57.12	3.38	17.91	9.71	1.39	76160.37
6	5.18	12.52	50.28	2.03	18.69	8.80	1.36	77315.22
7	7.04	13.75	54.40	3.39	19.04	9.50	1.32	78020.12
8	7.76	11.16	52.31	3.06	18.68	9.67	1.31	77110.20
9	3.79	12.57	46.62	2.12	21.74	9.42	1.34	72610.68
10	6.00	13.80	35.81	3.29	21.86	8.55	1.35	78693.89
11	2.44	11.18	56.81	0.71	18.67	9.81	1.32	75463.86
12	7.08	11.05	42.37	1.03	19.55	9.08	1.31	75044.44
13	8.10	10.91	45.58	1.42	19.29	9.13	1.33	77069.86
14	13.72	11.39	46.18	1.76	19.75	9.06	1.36	77670.45
15	6.34	10.90	56.08	2.26	18.25	9.43	1.36	74975.33
16	9.32	11.12	55.78	3.19	19.48	9.06	1.33	77213.13
17	6.97	11.04	53.58	2.90	19.53	9.19	1.31	77512.47
18	9.97	11.96	52.47	3.10	19.48	9.20	1.31	76788.28
19	4.36	12.71	53.49	2.39	21.43	9.19	1.31	75542.23
20	8.42	12.33	43.87	2.84	20.29	9.00	1.33	79311.40
21	5.47	12.48	45.83	2.64	17.65	9.46	1.31	76646.70
22	8.90	12.45	44.39	3.23	19.94	8.81	1.31	75427.88
23	11.67	12.83	42.72	2.97	19.79	8.74	1.31	77474.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.68	11.96	50.03	2.52	19.59	9.27	1.34	76182.21
最大值	13.72	13.80	59.34	3.39	21.86	9.81	1.41	79311.40
發生時間	14	10	0	7	10	11		20
最小值	2.44	10.90	35.81	0.71	17.65	8.55	1.30	71731.90
發生時間	11	15	10	11	21	10		2
零點偏移(率)	-0.08 %	0.00 %	-0.11 %	0.00 %		-0.05	-0.01	-0.10 %
全幅偏移(率)	0.03 %	0.07 %	1.76 %	0.34 %		0.18	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								