

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.07	12.45	45.59	1.27	19.64	10.60	1.24	84825.33
1	7.79	12.37	44.15	1.23	20.27	10.49	1.24	85039.30
2	11.80	12.01	49.77	1.28	20.25	10.25	1.24	87505.83
3	8.39	12.44	47.73	1.33	18.60	10.84	1.24	84309.81
4	8.92	12.43	48.32	1.58	18.92	10.80	1.25	83884.15
5	4.44	12.63	59.42	3.18	17.67	10.88	1.27	84536.90
6	7.82	12.27	62.41	3.09	18.18	10.74	1.27	85531.76
7	12.47	12.26	59.65	2.93	18.58	10.71	1.26	85203.50
8	6.40	12.09	58.20	1.40	19.42	10.45	1.25	86440.97
9	12.25	12.37	54.55	2.06	18.01	10.85	1.25	84608.95
10	7.09	12.32	56.75	1.47	19.10	10.51	1.25	86080.58
11	10.01	12.37	54.73	1.93	19.32	10.33	1.25	87035.09
12	15.41	12.11	55.20	2.58	18.97	10.43	1.25	86764.97
13	7.47	12.09	52.13	1.57	19.25	10.31	1.25	87436.64
14	10.56	12.09	52.70	1.71	18.87	10.48	1.25	86248.56
15	11.61	12.05	56.79	2.74	18.91	10.49	1.25	86440.32
16	6.81	12.55	56.21	3.35	18.60	10.72	1.25	84828.32
17	10.76	12.81	47.06	3.89	18.21	10.68	1.25	85830.75
18	8.64	12.34	51.90	1.15	18.47	10.70	1.25	85889.42
19	6.86	12.67	52.11	1.10	18.23	11.05	1.24	82665.50
20	8.33	12.98	60.63	0.87	18.84	11.23	1.25	80704.70
21	1.49	13.69	62.71	0.43	19.16	11.64	1.27	77206.25
22	12.02	11.85	48.37	0.99	20.58	9.73	1.27	90610.93
23	8.80	12.53	53.40	0.94	19.71	10.35	1.27	86547.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.05	12.41	53.77	1.84	18.99	10.64	1.25	85257.35
最大值	15.41	13.69	62.71	3.89	20.58	11.64	1.27	90610.93
發生時間	12	21	21	17	22	21		22
最小值	1.49	11.85	44.15	0.43	17.67	9.73	1.23	77206.25
發生時間	21	22	1	21	5	22		21
零點偏移(率)	-0.11 %	-0.14 %	-0.02 %	-0.00 %		0.01	-0.01	0.10 %
全幅偏移(率)	-0.66 %	-0.41 %	-0.27 %	-0.70 %		-0.13	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.74	11.86	60.47	0.84	19.59	10.38	0.97	85419.40
1	4.39	12.55	53.90	1.15	19.37	10.95	0.98	81603.92
2	12.33	12.36	52.51	2.05	17.29	11.10	0.99	82556.13
3	1.12	13.98	69.18	1.45	17.77	12.06	1.00	74314.77
4	3.12	12.42	41.76	0.79	19.43	10.89	0.98	83215.09
5	11.00	12.80	48.10	2.67	17.93	10.72	0.98	84940.14
6	3.38	12.24	44.71	2.06	19.14	10.68	0.97	83851.41
7	8.90	12.30	49.78	1.56	19.18	10.71	0.97	83948.21
8	10.38	11.92	45.81	1.13	20.01	10.30	0.97	86397.33
9	4.67	12.04	48.52	1.32	19.17	10.53	0.98	85154.69
10	7.30	14.85	55.82	2.33	20.27	9.87	0.99	88552.95
11	7.45	12.31	50.26	0.80	19.88	10.39	0.98	85349.36
12	8.29	12.34	51.75	1.62	19.00	10.43	0.99	85616.18
13	13.93	12.15	53.90	1.58	18.69	10.69	0.99	83938.56
14	11.91	11.98	54.33	1.23	19.03	10.50	0.99	85292.60
15	14.92	11.92	51.22	1.18	19.14	10.45	0.99	85081.86
16	11.80	11.98	52.43	0.99	19.52	10.42	0.99	85221.81
17	9.04	11.83	45.62	0.81	19.45	10.33	0.99	86062.80
18	10.74	12.09	43.18	1.04	19.37	10.43	0.98	85259.24
19	3.56	12.60	64.76	0.45	20.18	10.89	0.98	80984.64
20	2.97	15.63	48.98	0.90	17.27	13.02	1.02	66697.19
21	1.32	13.88	42.18	0.90	19.13	11.14	0.98	80300.95
22	5.21	12.56	55.22	1.75	18.14	10.35	0.96	87332.99
23	12.12	12.05	43.72	2.03	19.16	10.20	0.96	86982.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.94	12.61	51.17	1.36	19.05	10.73	0.98	83503.11
最大值	14.92	15.63	69.18	2.67	20.27	13.02	1.14	88552.95
發生時間	15	20	3	5	10	20		10
最小值	1.12	11.83	41.76	0.45	17.27	9.87	0.94	66697.19
發生時間	3	17	4	19	20	10		20
零點偏移(率)	-0.10 %	-0.08 %	-0.05 %	-0.00 %		-0.02	-0.01	-0.10 %
全幅偏移(率)	1.37 %	0.52 %	-0.04 %	-0.03 %		-0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.23	11.67	49.38	2.30	21.44	8.82	1.31	80138.93
1	4.98	12.40	37.25	2.22	21.34	9.47	1.31	77795.32
2	4.64	12.23	48.81	2.89	19.80	9.64	1.32	78471.21
3	5.28	12.32	49.22	2.84	19.23	9.82	1.32	77914.05
4	3.73	12.53	51.69	2.72	19.20	10.01	1.32	76283.09
5	4.81	12.88	55.51	2.86	19.79	10.14	1.36	78148.77
6	3.84	12.03	46.64	2.69	19.15	9.53	1.34	78199.59
7	5.79	10.70	63.25	2.96	19.12	9.69	1.29	76253.31
8	3.86	11.52	55.44	1.85	19.39	9.37	1.27	75533.85
9	6.00	11.91	48.63	1.30	20.16	8.82	1.27	75828.12
10	6.40	12.29	47.86	1.29	19.71	9.04	1.29	76532.09
11	3.46	11.76	56.51	1.16	18.75	9.36	1.28	75324.74
12	6.88	12.07	53.06	1.35	19.87	9.20	1.29	76430.02
13	6.49	11.74	44.21	1.29	19.05	9.10	1.30	76887.29
14	11.18	11.70	48.23	1.63	20.51	8.88	1.32	78731.32
15	7.07	11.28	47.98	2.16	20.75	8.84	1.34	78235.50
16	9.80	11.42	64.04	2.89	18.23	10.00	1.34	78434.36
17	7.15	11.30	62.38	2.49	19.57	9.76	1.31	81359.54
18	8.73	11.61	54.40	2.87	18.62	10.19	1.28	78659.28
19	5.82	12.00	55.98	2.80	18.48	10.48	1.31	74644.58
20	2.29	14.96	67.70	2.95	17.81	11.49	1.58	63617.61
21	1.75	14.40	59.37	2.98	17.84	10.64	1.54	68021.48
22	2.42	11.11	51.98	1.47	22.49	9.07	1.29	77598.67
23	5.36	10.63	40.73	2.31	21.70	8.50	1.29	84966.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.46	12.02	52.51	2.26	19.67	9.58	1.33	76833.72
最大值	11.18	14.96	67.70	2.98	22.49	11.49	2.20	84966.66
發生時間	14	20	20	21	22	20		23
最小值	1.75	10.63	37.25	1.16	17.81	8.50	1.27	63617.61
發生時間	21	23	1	11	20	23		20
零點偏移(率)	-0.03 %	-0.01 %	-0.13 %	-0.04 %		-0.06	-0.01	-0.20 %
全幅偏移(率)	1.39 %	1.19 %	1.17 %	-0.17 %		0.15	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								