

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月17日

報表日期: 114年03月17日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.35	6.95	50.67	1.22	17.00	11.53	1.34	82390.28
1	7.95	7.97	48.48	1.71	17.49	11.47	1.34	82239.23
2	8.66	6.86	50.28	1.46	15.94	11.89	1.34	80147.99
3	9.95	7.32	49.35	1.81	15.12	11.90	1.34	81415.17
4	6.05	9.97	53.45	1.01	16.71	11.96	1.34	79357.57
5	11.56	4.12	47.16	1.33	16.76	11.68	1.32	81113.96
6	8.86	3.16	51.87	0.98	17.00	11.90	1.31	79307.96
7	8.78	3.05	59.51	1.05	16.51	11.87	1.31	79978.39
8	9.78	5.56	57.75	0.94	15.64	11.95	1.31	79971.00
9	11.95	5.63	51.52	1.72	15.73	12.05	1.31	78895.93
10	1.55	4.22	59.22	0.58	17.81	11.73	1.30	79796.60
11	4.92	4.57	42.65	0.64	17.41	11.44	1.29	82512.83
12	7.68	3.14	49.17	0.42	18.05	11.67	1.29	80147.43
13	11.20	3.18	46.08	0.98	16.84	11.58	1.29	82339.03
14	3.05	3.00	53.40	0.66	16.55	12.12	1.29	77700.98
15	8.99	3.02	49.31	0.90	16.35	11.87	1.29	79781.15
16	7.11	2.77	54.02	0.72	17.28	11.54	1.30	81317.99
17	8.30	2.99	44.52	0.92	16.31	11.49	1.31	81446.03
18	7.59	4.57	51.69	1.20	16.58	11.92	1.31	77658.62
19	7.53	2.87	49.48	0.54	17.67	11.35	1.31	81409.63
20	9.99	2.96	41.81	0.99	17.45	11.11	1.31	83811.65
21	8.59	2.95	39.86	0.89	17.16	11.29	1.31	82287.75
22	10.71	3.21	47.72	1.25	16.64	11.40	1.32	82280.48
23	8.36	4.94	57.67	0.51	17.60	11.63	1.34	80711.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.19	4.54	50.28	1.02	16.82	11.68	1.31	80750.80
最 大 值	11.95	9.97	59.51	1.81	18.05	12.12	1.34	83811.65
發生時間	9	4	7	3	12	14		20
最 小 值	1.55	2.77	39.86	0.42	15.12	11.11	1.29	77658.62
發生時間	10	16	21	12	3	20		18
零點偏移(率)	-0.05 %	-0.06 %	-0.02 %	-0.00 %		-0.40		0.30 %
全幅偏移(率)	0.00 %	1.05 %	-1.19 %	0.92 %		-0.14		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月17日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.51	2.51	50.30	2.38	15.58	10.90	1.17	84524.62
1	4.99	3.02	41.11	1.81	16.02	10.69	1.15	79237.46
2	7.14	2.95	40.29	2.01	15.53	10.72	1.17	79960.12
3	1.97	4.13	43.40	1.87	15.09	10.90	1.15	77832.76
4	0.91	6.60	47.65	1.46	17.79	10.39	1.15	86522.57
5	0.67	7.86	56.39	1.21	17.97	10.54	1.15	81701.39
6	1.36	1.87	56.48	1.06	18.85	9.72	1.14	83962.98
7	3.82	5.07	50.79	2.33	14.98	11.02	1.13	82683.54
8	3.22	1.04	49.99	2.06	14.83	11.23	1.13	80824.56
9	1.14	1.52	55.58	1.43	15.87	10.72	1.12	84666.30
10	2.75	1.68	54.46	1.71	15.04	10.92	1.11	80911.21
11	3.08	1.76	59.91	0.91	16.87	10.74	1.12	81677.31
12	5.93	2.00	57.71	1.20	16.48	10.68	1.13	83219.02
13	7.84	2.34	59.78	1.58	15.47	10.93	1.14	81114.70
14	9.20	2.74	59.31	1.53	15.88	11.26	1.14	77548.14
15	9.09	2.57	54.02	1.81	16.17	10.71	1.13	80774.86
16	10.41	2.80	47.04	1.75	16.11	10.69	1.12	80697.94
17	7.89	6.27	40.48	2.19	15.38	10.48	1.11	78405.52
18	6.45	4.14	56.08	1.41	16.91	10.45	1.10	78352.39
19	7.39	2.30	57.09	1.49	17.21	10.19	1.10	83847.15
20	10.63	3.77	60.86	2.47	15.57	10.64	1.12	82064.48
21	14.11	3.31	45.56	2.16	16.70	10.24	1.11	77821.23
22	9.23	2.73	54.67	1.80	15.85	11.10	1.13	79853.25
23	5.86	4.12	49.38	1.43	17.30	10.57	1.15	84913.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.98	3.30	52.01	1.71	16.23	10.68	1.13	81379.85
最 大 值	14.11	7.86	60.86	2.47	18.85	11.26	1.18	86522.57
發生時間	21	5	20	20	6	14		4
最 小 值	0.67	1.04	40.29	0.91	14.83	9.72	1.10	77548.14
發生時間	5	8	2	11	8	6		14
零點偏移(率)	-0.01 %	-0.05 %	-0.11 %	-0.00 %		-0.11		0.10 %
全幅偏移(率)	-0.79 %	0.79 %	0.29 %	0.53 %		0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月17日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.02	8.34	56.44	0.98	16.14	10.76	1.50	83053.16
1	6.17	4.61	54.17	0.83	16.54	10.92	1.50	78702.07
2	10.49	5.87	54.83	1.62	16.02	10.55	1.50	82021.95
3	6.13	3.21	58.26	1.79	15.19	11.11	1.49	75292.31
4	6.35	10.73	49.80	0.73	16.93	10.40	1.49	77811.04
5	7.72	2.19	51.35	0.77	17.17	10.34	1.50	78817.17
6	4.09	5.31	46.03	0.61	16.80	10.13	1.50	77030.13
7	13.27	8.95	44.36	1.03	16.27	10.25	1.53	75702.51
8	4.53	5.26	47.70	0.50	16.55	10.22	1.55	78612.00
9	0.86	5.37	51.17	0.15	17.94	10.03	1.54	80645.36
10	0.42	9.85	49.09	0.20	17.12	10.19	1.52	80875.92
11	2.15	6.49	53.35	0.37	15.83	10.88	1.51	76432.80
12	2.29	3.65	54.33	0.15	16.89	10.79	1.52	76068.51
13	2.69	6.91	49.91	0.26	16.37	10.62	1.52	76943.15
14	2.07	1.72	55.30	0.27	16.79	11.00	1.52	74026.67
15	5.27	6.10	48.02	0.39	17.08	10.38	1.52	79076.84
16	8.75	4.61	47.44	0.38	16.95	10.31	1.52	80723.23
17	7.96	3.62	47.49	0.60	16.17	10.45	1.53	79155.75
18	8.97	1.99	53.35	0.38	17.66	10.22	1.54	80319.47
19	9.52	6.19	48.35	0.60	17.38	10.06	1.54	84141.20
20	7.63	2.93	52.20	0.58	16.45	10.51	1.55	83524.92
21	9.80	2.08	54.64	0.66	16.30	10.70	1.55	82250.20
22	8.34	7.04	58.02	0.50	17.24	10.44	1.55	83406.53
23	6.81	2.11	58.69	0.19	18.16	10.40	1.55	81582.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.22	5.21	51.85	0.61	16.75	10.49	1.52	79425.66
最 大 值	13.27	10.73	58.69	1.79	18.16	11.11	1.57	84141.20
發生時間	7	4	23	3	23	3		19
最 小 值	0.42	1.72	44.36	0.15	15.19	10.03	1.48	74026.67
發生時間	10	14	7	9	3	9		14
零點偏移(率)	-0.01 %	-0.02 %	-0.02 %	-0.00 %		-0.12		0.20 %
全幅偏移(率)	0.02 %	-0.19 %	-0.55 %	0.40 %		-0.24		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								