

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月01日

報表日期: 114年06月01日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	1.87	2.10	54.69	2.50	15.72	11.69	1.25	79077.25
1	1.78	3.34	65.45	2.20	17.84	11.37	1.25	81214.17
2	1.74	5.32	60.36	2.56	16.97	11.41	1.25	81813.00
3	1.18	4.61	55.03	2.55	16.96	11.32	1.26	81937.23
4	1.34	3.49	57.57	2.40	16.59	11.41	1.29	82164.59
5	4.45	2.47	63.56	1.78	16.41	11.52	1.29	80548.50
6	4.06	5.31	60.51	1.76	15.79	11.54	1.29	81116.73
7	7.69	3.17	61.05	2.39	14.54	11.86	1.29	79097.77
8	13.78	6.22	58.79	3.43	14.04	11.70	1.26	79257.94
9	11.51	3.65	59.37	2.73	14.34	11.90	1.28	78440.41
10	4.14	2.25	65.27	1.68	15.60	11.72	1.28	79708.14
11	6.87	4.31	59.10	2.53	16.54	11.41	1.26	81521.47
12	3.59	4.18	58.10	3.88	15.61	11.63	1.28	80352.35
13	3.44	0.93	62.01	3.67	15.71	11.38	1.27	80718.12
14	1.49	3.38	57.81	2.92	15.76	11.53	1.27	79328.80
15	0.12	1.33	49.64	2.69	15.85	11.23	1.28	79520.23
16	0.57	3.82	52.76	2.84	15.82	11.36	1.28	78732.32
17	1.57	1.22	60.93	2.54	16.93	11.33	1.26	79372.29
18	1.12	2.73	58.97	3.35	15.56	11.31	1.27	80761.74
19	2.27	5.05	58.21	2.34	18.08	10.88	1.26	83829.59
20	3.93	1.76	52.98	4.14	15.27	11.29	1.26	81341.44
21	0.36	2.66	59.49	1.74	17.29	11.14	1.26	80763.20
22	0.47	4.05	62.40	1.48	17.29	10.92	1.27	83714.04
23	6.84	3.42	55.68	3.60	16.62	11.42	1.29	79691.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.59	3.37	58.74	2.65	16.13	11.43	1.27	80584.26
最 大 值	13.78	6.22	65.45	4.14	18.08	11.90	1.29	83829.59
發生時間	8	8	1	20	19	9		19
最 小 值	0.12	0.93	49.64	1.48	14.04	10.88	1.24	78440.41
發生時間	15	13	15	22	8	19		9
零點偏移(率)	0.00 %	0.00 %	-0.01 %	0.00 %		-0.03		0.10 %
全幅偏移(率)	0.00 %	0.00 %	-0.03 %	0.00 %		-0.25		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月01日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	2.83	1.40	60.76	2.00	17.41	10.84	1.02	82163.99
1	0.22	7.96	54.05	2.65	17.67	10.58	1.02	83519.65
2	5.55	1.82	61.94	2.46	18.04	10.02	1.02	87944.43
3	8.62	2.19	60.94	2.71	16.88	10.75	1.03	83738.40
4	7.41	1.76	61.11	2.19	17.20	10.62	1.04	85233.74
5	2.76	3.67	59.58	1.84	18.54	10.31	1.03	85867.49
6	8.47	1.80	63.39	1.37	18.97	9.95	1.04	94854.38
7	6.37	1.42	68.31	1.63	18.08	10.34	1.06	85280.20
8	5.83	1.61	61.60	1.40	18.26	10.38	1.05	85825.77
9	1.74	1.80	59.18	1.53	17.99	10.64	1.04	82184.62
10	1.16	1.90	54.99	1.66	18.24	10.55	1.04	82557.91
11	3.10	3.10	54.05	1.78	18.20	10.22	1.05	85520.66
12	2.98	1.93	58.57	2.79	16.08	10.73	1.04	82443.39
13	1.62	4.58	57.32	3.17	16.20	10.51	1.04	83505.49
14	6.95	5.76	56.29	2.04	18.25	10.10	1.04	84590.58
15	7.22	2.51	49.81	2.51	17.53	10.08	1.04	83321.09
16	1.19	2.46	46.33	2.37	17.20	10.31	1.04	81506.30
17	0.60	3.01	54.86	1.96	18.28	10.35	1.04	82718.66
18	3.45	3.28	55.64	1.50	19.51	10.36	1.05	83966.56
19	4.13	1.43	51.19	1.82	19.11	10.37	1.05	84249.84
20	1.45	1.23	47.45	0.81	20.70	10.40	1.05	81898.79
21	0.17	2.14	48.92	0.96	19.65	11.12	1.06	76713.82
22	0.06	3.82	42.82	2.29	17.69	11.83	1.12	73564.07
23	4.94	4.18	54.36	2.19	17.76	10.64	1.04	82579.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.70	2.78	55.98	1.98	18.06	10.50	1.04	83572.89
最 大 值	8.62	7.96	68.31	3.17	20.70	11.83	1.54	94854.38
發生時間	3	1	7	13	20	22		6
最 小 值	0.06	1.23	42.82	0.81	16.08	9.95	1.02	73564.07
發生時間	22	20	22	20	12	6		22
零點偏移(率)	-0.15 %	-0.04 %	-0.10 %	-0.10 %		-0.05		-0.10 %
全幅偏移(率)	0.14 %	0.14 %	0.12 %	0.03 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.87	7.77	52.72	2.10	18.36	9.08	1.46	78352.34
1	0.97	6.41	51.73	2.04	21.97	8.10	1.43	81584.92
2	1.97	6.12	58.10	2.53	16.63	9.36	1.42	80646.31
3	8.55	9.73	58.52	3.04	15.52	9.69	1.42	76952.92
4	4.63	5.27	59.03	3.30	14.78	9.79	1.42	73607.79
5	1.75	5.97	55.10	2.99	15.29	9.73	1.43	75104.22
6	5.14	9.49	53.08	1.92	15.38	9.47	1.43	74073.64
7	2.66	3.67	51.10	2.57	16.50	9.08	1.43	72356.19
8	6.07	6.04	51.02	2.42	16.94	8.88	1.47	74960.80
9	9.53	5.66	49.60	1.83	16.34	8.95	1.46	75487.53
10	9.02	4.26	50.32	1.66	16.11	9.19	1.48	75422.05
11	8.39	6.76	53.51	2.39	16.48	9.22	1.46	75596.46
12	5.30	9.02	56.99	2.84	18.63	8.89	1.48	74424.82
13	6.37	6.91	47.65	3.09	17.81	8.50	1.48	75173.11
14	8.62	7.10	43.16	2.11	19.65	7.80	1.48	76798.23
15	5.66	1.80	50.41	1.75	20.61	7.35	1.44	75166.61
16	9.45	4.92	40.87	2.67	18.91	7.47	1.43	75772.96
17	8.35	1.87	58.13	3.47	18.07	8.68	1.44	78466.28
18	5.76	3.33	56.62	2.78	18.76	8.51	1.44	77452.40
19	3.03	1.67	47.86	2.55	19.53	8.37	1.43	71704.23
20	4.01	9.03	41.84	3.11	19.67	7.68	1.44	78500.38
21	1.45	3.69	53.09	2.34	18.47	8.52	1.47	75805.94
22	3.67	3.78	53.89	2.79	18.18	8.58	1.48	76377.92
23	0.89	0.88	60.42	2.74	18.31	11.01	1.46	66062.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.13	5.46	52.28	2.54	17.79	8.83	1.45	75660.46
最 大 值	9.53	9.73	60.42	3.47	21.97	11.01	1.50	81584.92
發生時間	9	3	23	17	1	23		1
最 小 值	0.89	0.88	40.87	1.66	14.78	7.35	1.41	66062.89
發生時間	23	23	16	10	4	15		23
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.07 %		-0.03		-0.10 %
全幅偏移(率)	0.02 %	0.60 %	-0.34 %	0.05 %		0.15		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								