

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.29	1.67	65.06	3.57	13.41	12.39	1.39	71253.33
1	8.49	1.60	51.92	2.86	14.86	11.80	1.38	74044.68
2	8.75	3.79	40.05	4.05	12.96	12.51	1.36	69713.13
3	9.82	3.05	54.37	3.11	14.67	12.20	1.37	71209.30
4	9.67	5.30	48.18	3.60	13.78	12.29	1.37	71355.89
5	3.02	9.60	62.01	3.60	12.83	12.64	1.38	77608.82
6	9.85	3.10	58.13	3.49	13.96	12.27	1.39	72063.46
7	9.57	3.26	55.18	2.33	16.49	11.21	1.40	77902.06
8	9.83	2.89	56.71	3.05	14.76	11.94	1.44	73505.09
9	8.21	3.15	50.07	3.26	14.02	12.36	1.41	71216.60
10	7.95	3.63	59.26	3.01	14.34	12.42	1.44	69685.19
11	8.39	4.41	43.38	4.00	12.60	12.73	1.42	68014.47
12	4.04	4.75	52.14	3.58	12.91	12.84	1.41	66319.75
13	0.26	3.21	51.73	3.30	12.69	12.65	1.44	68752.80
14	0.16	4.64	47.95	3.61	12.48	12.70	1.47	68346.30
15	0.08	3.97	66.71	2.76	13.95	12.58	1.46	67919.57
16	0.19	4.39	38.36	3.11	13.45	12.67	1.42	67811.93
17	0.14	3.62	49.42	2.67	14.08	12.64	1.41	67999.82
18	0.57	3.37	51.63	2.60	14.37	12.42	1.45	69305.95
19	0.24	2.95	63.11	2.24	14.48	12.23	1.44	70957.38
20	0.11	4.50	38.94	3.28	12.62	12.58	1.41	69212.41
21	0.24	4.29	60.28	2.62	14.41	12.62	1.41	67802.95
22	0.23	3.20	54.49	1.16	18.26	11.33	1.39	74615.11
23	0.16	3.58	56.23	1.20	18.48	12.00	1.40	69507.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.59	3.83	53.14	3.00	14.20	12.33	1.41	70671.79
最大值	10.29	9.60	66.71	4.05	18.48	12.84	1.48	77902.06
發生時間	0	5	15	2	23	12		7
最小值	0.08	1.60	38.36	1.16	12.48	11.21	1.36	66319.75
發生時間	15	1	16	22	14	7		12
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.25 %	0.15 %	-0.24 %	0.08 %		0.34	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.96	2.14	55.96	2.27	16.93	10.56	1.39	85798.33
1	7.50	2.99	53.48	1.48	19.30	10.74	1.38	82501.83
2	7.95	11.19	42.95	2.56	17.04	10.45	1.38	85296.85
3	10.58	4.61	36.12	2.96	16.96	9.89	1.37	82493.43
4	9.83	5.71	38.25	2.91	17.12	9.64	1.37	82267.06
5	9.62	5.40	35.24	2.53	17.26	10.21	1.38	83936.36
6	6.70	4.18	34.71	2.13	18.29	9.85	1.38	82667.60
7	10.40	3.78	39.62	2.17	17.31	10.19	1.39	85910.07
8	9.64	2.14	51.96	2.05	17.05	10.15	1.43	83197.52
9	9.66	1.73	53.96	2.34	15.77	10.51	1.38	79712.01
10	5.39	2.25	41.93	2.00	15.80	10.49	1.40	78194.54
11	1.74	2.07	44.39	1.73	15.37	10.77	1.37	78603.98
12	0.33	1.86	38.12	1.65	15.32	10.61	1.38	77746.91
13	1.82	1.95	36.92	1.61	16.45	10.06	1.39	81147.70
14	5.44	2.28	48.23	1.93	15.89	10.53	1.42	82137.39
15	5.03	2.21	42.34	1.93	16.00	10.60	1.44	80039.83
16	4.01	1.98	35.82	1.85	16.57	10.15	1.40	81950.72
17	4.88	1.96	38.22	1.78	16.15	10.26	1.37	82953.96
18	7.48	3.92	41.30	1.89	16.88	9.94	1.37	84706.61
19	9.62	2.44	44.66	1.81	17.89	9.92	1.40	84415.35
20	8.90	2.54	43.41	1.39	18.88	9.91	1.38	87970.46
21	8.79	2.94	38.04	1.77	17.04	10.24	1.38	84413.69
22	5.73	4.86	48.70	1.86	16.06	10.57	1.38	82617.37
23	1.76	1.74	41.90	1.07	18.45	10.10	1.37	85462.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.74	3.29	42.76	1.99	16.91	10.26	1.39	82755.91
最大值	10.58	11.19	55.96	2.96	19.30	10.77	1.45	87970.46
發生時間	3	2	0	3	1	11		20
最小值	0.33	1.73	34.71	1.07	15.32	9.64	1.34	77746.91
發生時間	12	9	6	23	12	4		12
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.28 %	0.38 %	-0.62 %	-0.03 %		0.18	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.46	3.29	59.52	1.02	17.92	10.09	1.78	87986.04
1	5.57	3.14	60.43	1.68	16.52	10.06	1.77	91154.00
2	16.41	11.62	35.56	2.78	14.75	10.30	1.75	86688.27
3	11.66	4.53	52.52	2.82	15.34	11.16	1.73	82407.77
4	2.74	7.63	55.52	2.88	13.69	10.86	1.74	85035.72
5	9.64	3.39	59.62	3.02	14.80	10.54	1.75	83503.73
6	13.49	5.61	47.42	3.09	13.80	10.91	1.75	81536.63
7	4.49	5.55	70.65	1.50	15.75	10.45	1.78	86392.32
8	6.19	2.12	49.93	1.92	15.16	10.29	1.77	83224.67
9	4.08	3.06	47.08	1.74	14.73	10.69	1.76	80315.00
10	4.62	2.06	59.11	1.98	14.75	10.80	1.77	83208.05
11	5.69	4.32	47.86	3.51	11.72	12.09	1.78	79804.01
12	3.52	4.91	49.88	2.20	13.51	11.80	1.80	80866.52
13	0.66	2.14	55.82	1.85	13.74	11.71	1.80	80528.41
14	0.13	2.17	56.29	1.82	13.95	11.63	1.79	78467.18
15	0.07	2.49	46.21	1.27	14.30	11.33	1.76	75996.72
16	0.10	3.26	53.26	1.41	14.47	11.19	1.78	80176.00
17	0.09	3.81	52.67	1.14	14.99	10.87	1.77	85253.97
18	0.50	2.07	57.84	1.12	15.44	11.05	1.76	82959.66
19	0.42	2.18	55.78	0.90	15.86	10.97	1.76	83586.49
20	2.03	2.09	50.46	0.99	16.16	10.56	1.75	86617.06
21	3.35	2.12	63.06	1.19	15.68	11.35	1.75	81030.00
22	2.79	4.18	47.63	1.04	16.12	10.68	1.76	87039.77
23	2.58	2.24	57.23	1.00	16.33	11.09	1.74	83108.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.30	3.75	53.81	1.83	14.98	10.94	1.76	83203.62
最大值	16.41	11.62	70.65	3.51	17.92	12.09	1.80	91154.00
發生時間	2	2	7	11	0	11		1
最小值	0.07	2.06	35.56	0.90	11.72	10.06	1.72	75996.72
發生時間	15	10	2	19	11	1		15
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	0.10 %	0.02 %	-0.60 %	0.07 %		0.25	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								