

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.60	13.12	51.89	2.19	17.91	11.21	1.26	80968.63
1	8.45	13.28	48.66	2.30	19.16	11.18	1.28	80066.96
2	11.01	12.94	52.35	2.85	17.57	11.08	1.27	83257.26
3	10.03	12.92	50.00	1.59	18.24	11.06	1.25	82577.68
4	6.92	12.92	44.42	1.44	17.73	11.11	1.25	82223.55
5	6.42	12.98	46.44	1.77	17.22	11.28	1.25	86398.27
6	8.52	13.26	54.58	2.35	17.39	11.22	1.25	81370.60
7	10.34	12.87	47.88	2.30	17.66	11.14	1.25	82052.36
8	12.83	12.79	54.04	1.95	17.55	11.11	1.26	81484.79
9	7.22	12.93	52.86	1.70	17.41	11.29	1.29	80099.65
10	12.55	12.77	48.22	2.13	17.42	11.14	1.30	81859.15
11	7.08	13.24	56.80	2.78	15.07	11.62	1.29	77719.80
12	15.57	12.95	54.38	2.53	16.00	11.51	1.29	78443.61
13	8.83	12.91	56.90	1.60	17.86	11.22	1.26	81112.30
14	14.81	12.88	51.19	2.66	17.15	11.26	1.25	80364.49
15	7.50	12.86	61.25	1.62	17.68	11.19	1.25	81454.15
16	11.07	12.80	57.02	1.99	17.27	11.19	1.26	81834.57
17	5.75	12.69	53.21	1.22	18.46	10.94	1.29	82456.46
18	8.86	13.17	46.29	1.86	17.96	11.32	1.29	79511.72
19	4.53	14.85	51.98	1.35	17.94	11.38	1.27	79821.26
20	7.04	12.50	49.41	1.85	17.31	11.08	1.29	83162.97
21	10.33	12.59	43.23	2.28	16.64	11.09	1.29	81049.04
22	10.98	12.68	51.53	2.90	17.27	11.24	1.29	80451.38
23	7.85	12.44	49.67	2.21	18.37	10.90	1.29	83585.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.30	12.97	51.43	2.06	17.51	11.20	1.27	81388.58
最大值	15.57	14.85	61.25	2.90	19.16	11.62	1.31	86398.27
發生時間	12	19	15	22	1	11		5
最小值	4.53	12.44	43.23	1.22	15.07	10.90	1.25	77719.80
發生時間	19	23	21	17	11	23		11
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	-0.00 %		-0.17	-0.01	0.20 %
全幅偏移(率)	-0.40 %	0.07 %	0.42 %	1.10 %		0.06	0.10	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.66	8.50	47.65	0.83	18.14	10.88	0.82	81467.33
1	10.07	10.27	59.49	1.10	19.22	10.86	0.83	80710.95
2	7.50	11.39	55.50	0.94	18.66	10.81	0.82	83425.23
3	10.95	9.47	62.21	0.79	18.24	11.05	0.81	81470.79
4	8.60	9.72	52.73	0.74	18.32	11.01	0.80	81260.41
5	9.08	8.18	47.82	1.10	17.41	11.19	0.79	80202.00
6	8.28	10.90	49.01	0.83	18.21	11.40	0.79	75263.39
7	11.32	10.89	56.18	1.16	17.92	11.43	0.79	76303.56
8	9.28	10.29	50.45	0.80	18.08	11.03	0.80	79719.32
9	12.91	9.15	56.13	1.01	18.14	10.89	0.81	81661.36
10	9.20	8.99	56.72	1.18	16.98	11.23	0.81	79168.97
11	10.67	8.04	51.96	1.09	16.71	11.26	0.79	76813.41
12	11.60	8.36	59.90	1.45	17.04	11.09	0.81	79359.55
13	9.01	7.90	63.66	1.52	16.56	11.36	0.83	78789.36
14	13.31	9.18	66.07	1.30	17.71	10.99	0.82	81366.02
15	9.93	8.52	59.21	1.46	16.77	11.09	0.81	81283.38
16	10.54	10.06	52.09	1.00	18.28	11.04	0.81	77966.23
17	7.23	9.69	39.16	0.75	17.92	11.61	0.81	71609.93
18	8.81	10.72	52.75	0.95	18.19	11.57	0.80	72983.35
19	10.82	12.82	55.42	1.05	18.13	11.51	0.79	71362.31
20	8.72	11.14	58.49	1.58	16.67	11.77	0.79	73471.02
21	13.20	7.88	58.11	2.24	16.65	11.46	0.79	78838.39
22	10.81	8.22	62.96	0.89	17.80	11.41	0.79	76977.35
23	12.51	8.10	51.93	1.39	16.70	11.40	0.79	79244.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.17	9.52	55.23	1.13	17.69	11.22	0.80	78363.26
最大值	13.31	12.82	66.07	2.24	19.22	11.77	0.83	83425.23
發生時間	14	19	14	21	1	20		2
最小值	7.23	7.88	39.16	0.74	16.56	10.81	0.79	71362.31
發生時間	17	21	17	4	13	2		19
零點偏移(率)	-0.08 %	-0.05 %	-0.06 %	-0.01 %		-0.08	-0.06	-0.10 %
全幅偏移(率)	-0.42 %	-1.02 %	0.07 %	0.01 %		-0.09	0.31	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.05	12.22	56.01	2.72	20.28	9.82	1.36	77455.27
1	7.98	12.34	54.37	2.57	19.37	9.95	1.36	77280.51
2	8.97	12.40	57.51	3.18	17.21	10.22	1.36	74858.61
3	8.94	12.46	55.24	2.83	16.69	10.48	1.36	75318.43
4	10.68	12.42	55.42	2.95	17.25	10.34	1.36	76441.47
5	8.27	12.45	56.48	2.71	17.50	10.39	1.36	77642.51
6	8.29	12.44	55.40	2.67	17.77	10.32	1.36	77004.47
7	10.90	12.19	50.05	3.00	16.62	10.42	1.35	75131.67
8	9.15	12.07	55.76	2.91	16.51	10.40	1.34	75719.32
9	10.28	11.83	56.89	2.80	16.36	10.61	1.33	75067.66
10	7.99	12.23	55.30	2.91	15.95	10.64	1.34	74679.32
11	8.59	12.90	55.83	3.27	15.59	10.59	1.32	74725.07
12	12.07	11.81	56.83	2.96	16.43	10.55	1.33	75998.78
13	8.06	11.68	58.89	2.73	17.81	10.34	1.31	78147.84
14	9.51	11.90	59.71	2.73	17.37	10.56	1.32	77510.03
15	7.05	12.11	56.19	2.48	16.47	10.83	1.32	74931.57
16	9.65	12.10	58.65	2.62	16.86	10.81	1.31	76461.87
17	10.75	12.11	65.58	2.74	17.89	10.69	1.31	76943.42
18	6.28	11.98	62.31	2.45	18.22	10.55	1.32	77578.25
19	7.57	11.93	57.24	2.52	16.75	10.66	1.31	76267.27
20	9.86	12.09	50.68	2.11	16.40	10.32	1.31	74869.46
21	10.69	11.54	48.50	1.41	16.84	10.03	1.31	75196.17
22	7.80	11.64	48.59	1.24	17.79	9.82	1.31	76279.32
23	9.52	11.27	50.59	1.53	18.24	9.92	1.32	76274.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.04	12.09	55.75	2.59	17.26	10.39	1.33	76157.64
最大值	12.07	12.90	65.58	3.27	20.28	10.83	1.36	78147.84
發生時間	12	11	17	11	0	15		13
最小值	6.28	11.27	48.50	1.24	15.59	9.82	1.29	74679.32
發生時間	18	23	21	22	11	0		10
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	-0.03 %		-0.09	-0.01	0.10 %
全幅偏移(率)	1.46 %	1.99 %	1.61 %	1.16 %		0.09	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								