

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.67	5.96	39.72	0.98	19.60	10.70	1.08	77520.73
1	6.41	7.01	57.16	0.96	19.60	10.95	1.08	75579.34
2	5.66	9.05	63.07	0.98	17.70	11.40	1.07	73962.56
3	5.92	7.58	46.34	0.93	18.53	10.98	1.06	76441.68
4	0.87	9.16	68.34	0.98	17.10	12.11	1.06	69516.57
5	0.14	9.55	65.03	0.61	17.43	12.23	1.05	66746.01
6	0.66	9.38	48.26	0.69	17.39	12.23	1.05	68095.00
7	2.38	8.37	42.78	0.84	17.61	11.59	1.05	72615.83
8	4.05	9.30	68.10	0.81	17.84	11.63	1.08	72531.41
9	3.56	9.92	50.01	1.04	17.51	11.35	1.10	74980.45
10	4.23	8.63	65.56	1.08	17.47	11.69	1.13	72010.02
11	0.65	8.99	54.04	0.67	18.26	11.00	1.13	76882.03
12	2.12	10.10	47.59	1.30	16.87	11.41	1.11	74693.80
13	2.94	12.01	47.71	2.35	15.22	11.54	1.10	74874.40
14	1.75	8.53	44.50	2.18	15.55	11.31	1.09	75037.99
15	4.03	10.56	47.45	2.00	15.41	11.66	1.11	72164.62
16	9.24	8.65	46.11	2.22	15.35	11.47	1.11	73412.49
17	7.67	7.86	52.93	1.21	17.46	10.94	1.12	76781.70
18	10.07	7.73	51.22	1.99	15.86	11.32	1.10	75787.85
19	1.15	9.50	67.12	0.76	17.22	11.96	1.13	70796.03
20	0.44	10.28	62.09	0.57	17.83	11.11	1.11	77869.15
21	4.35	8.77	49.59	1.08	17.04	11.24	1.07	77118.56
22	5.82	10.51	47.45	1.63	16.92	11.22	1.06	77341.99
23	9.14	8.65	50.37	1.42	17.20	11.18	1.05	76992.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.29	9.00	53.44	1.22	17.25	11.43	1.09	74156.38
最大值	10.07	12.01	68.34	2.35	19.60	12.23	1.22	77869.15
發生時間	18	13	4	13	0	5		20
最小值	0.14	5.96	39.72	0.57	15.22	10.70	1.05	66746.01
發生時間	5	0	0	20	13	0		5
零點偏移(率)	-0.22 %	0.00 %	-0.03 %	0.00 %		0.03		0.00 %
全幅偏移(率)	0.01 %	1.07 %	0.09 %	0.50 %		0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.62	9.51	49.97	2.43	17.00	10.28	0.97	85504.27
1	3.07	4.70	45.26	1.86	19.32	10.06	0.97	85641.16
2	3.64	11.75	43.24	1.58	19.61	9.75	0.97	87647.16
3	2.51	11.57	40.50	1.15	19.68	9.86	0.97	86828.21
4	4.27	7.46	41.23	2.17	18.37	10.04	0.94	86329.10
5	3.42	5.83	45.49	1.55	18.67	10.21	0.94	83990.31
6	0.68	8.38	52.43	1.03	18.42	10.70	0.97	78982.20
7	0.67	5.56	51.76	1.83	17.68	10.86	0.97	80490.04
8	3.13	8.19	49.39	1.65	18.87	10.18	0.99	84319.06
9	3.94	10.07	42.95	2.05	18.06	10.07	0.99	86204.66
10	6.03	1.57	48.92	2.39	16.79	10.65	0.97	82687.53
11	7.32	3.46	48.89	2.93	15.75	10.84	0.95	81774.52
12	10.54	6.09	53.78	3.06	14.94	11.19	0.95	80280.03
13	5.19	6.36	50.55	3.26	14.85	11.17	0.97	80740.40
14	8.76	7.29	55.85	2.25	15.87	10.65	0.95	83963.24
15	7.57	6.87	50.28	2.98	14.54	10.98	0.94	83008.57
16	9.55	4.39	56.89	2.69	15.53	10.63	0.94	85131.23
17	7.68	6.11	44.39	2.03	17.11	10.32	0.95	84916.36
18	2.20	3.48	44.15	1.56	17.04	10.84	0.96	81717.62
19	0.12	7.97	42.99	1.37	17.98	10.48	0.97	83627.19
20	0.77	5.76	37.68	2.06	17.01	10.22	0.98	86313.64
21	4.43	5.34	41.39	2.11	16.26	10.56	0.98	84507.23
22	0.65	4.07	48.09	2.13	16.91	10.51	0.98	84136.22
23	2.46	7.62	45.10	1.80	17.86	10.11	0.97	86799.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.38	6.64	47.13	2.08	17.26	10.46	0.96	83980.83
最大值	10.54	11.75	56.89	3.26	19.68	11.19	0.99	87647.16
發生時間	12	2	16	13	3	12		2
最小值	0.12	1.57	37.68	1.03	14.54	9.75	0.94	78982.20
發生時間	19	10	20	6	15	2		6
零點偏移(率)	-0.04 %	-0.07 %	-0.03 %	-0.01 %		0.04		-0.20 %
全幅偏移(率)	0.02 %	-0.52 %	-0.25 %	-0.06 %		-0.09		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.48	6.15	54.79	1.16	15.50	11.34	0.94	81797.91
1	5.22	10.01	54.67	1.49	16.20	11.17	0.94	81209.44
2	5.76	4.17	62.13	1.31	16.45	11.09	0.94	82519.54
3	5.61	5.17	50.91	1.07	17.35	10.88	0.94	83853.64
4	3.73	5.64	51.17	1.06	16.76	10.93	0.92	82257.31
5	3.98	9.30	47.24	1.05	16.78	10.71	0.91	81889.55
6	4.79	6.11	48.68	1.28	16.22	10.90	0.92	79362.64
7	1.06	3.48	50.30	1.15	15.79	11.00	0.94	81104.97
8	1.94	3.61	53.83	1.27	15.65	11.07	0.94	78953.40
9	3.98	4.33	50.53	1.53	15.37	10.96	0.94	81119.06
10	4.31	4.12	52.10	1.43	15.21	11.13	0.94	76373.47
11	6.35	8.81	48.16	2.29	14.03	10.89	0.95	77970.81
12	9.25	9.46	46.35	2.77	13.06	11.28	0.94	74219.72
13	5.97	5.99	49.27	2.36	13.07	11.14	0.94	72998.04
14	6.09	8.87	53.21	3.08	11.16	11.44	0.93	68613.57
15	7.46	7.35	51.95	3.21	11.72	11.54	0.94	71299.23
16	10.29	7.64	52.77	3.19	12.55	11.37	0.93	75072.98
17	10.39	3.90	51.31	2.94	12.52	11.73	0.93	77792.86
18	8.08	4.44	55.07	2.11	14.67	11.33	0.94	80954.89
19	6.03	5.93	46.62	1.30	15.14	10.90	0.94	78786.81
20	5.63	3.70	51.15	1.51	14.52	10.98	0.93	79282.38
21	9.05	9.08	54.58	2.09	14.10	11.21	0.94	80377.56
22	7.70	4.84	55.15	2.15	13.60	11.46	0.94	78637.15
23	8.30	6.55	56.14	2.36	13.62	11.43	0.94	79351.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.02	6.19	52.00	1.88	14.63	11.16	0.94	78574.93
最大值	10.39	10.01	62.13	3.21	17.35	11.73	0.96	83853.64
發生時間	17	1	2	15	3	17		3
最小值	1.06	3.48	46.35	1.05	11.16	10.71	0.91	68613.57
發生時間	7	7	12	5	14	5		14
零點偏移(率)	-0.05 %	-0.02 %	-0.14 %	-0.03 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.22 %	-0.21 %	-0.00 %		0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								