

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月28日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.83	8.65	52.86	2.92	12.94	12.20	1.23	66935.47
1	8.50	8.55	57.42	2.73	13.93	12.07	1.23	68122.75
2	8.84	9.77	50.31	3.25	12.46	12.13	1.23	68054.32
3	8.50	8.89	51.02	3.08	12.79	12.19	1.22	66537.61
4	6.28	9.63	63.52	2.86	13.08	12.51	1.22	65741.38
5	9.03	8.78	53.36	3.54	14.14	12.12	1.20	68834.85
6	8.45	9.26	64.83	2.72	13.13	12.77	1.21	64089.47
7	8.72	8.79	46.81	2.79	13.07	12.15	1.22	68963.79
8	6.70	8.88	58.73	2.12	14.20	12.23	1.24	67980.14
9	8.68	8.28	64.76	2.25	13.91	11.85	1.23	71175.09
10	8.73	8.52	53.24	2.38	14.69	11.95	1.23	69968.03
11	9.04	8.78	58.72	2.60	13.89	12.33	1.21	67205.23
12	10.67	10.86	48.42	2.93	12.74	12.47	1.20	67046.49
13	8.78	9.07	62.08	2.64	13.61	12.44	1.20	67091.81
14	8.52	9.09	63.37	2.74	13.18	12.57	1.19	66833.08
15	8.95	9.49	63.22	2.60	13.00	12.52	1.20	67706.25
16	10.24	9.04	62.11	2.35	13.72	12.16	1.20	70044.24
17	8.34	8.94	55.23	2.40	13.15	12.08	1.21	70286.46
18	9.58	10.87	56.10	2.73	12.18	12.23	1.20	69611.72
19	9.60	11.54	60.78	2.23	14.17	12.09	1.21	70076.04
20	8.24	10.00	65.21	1.79	14.80	11.88	1.20	71366.53
21	8.91	9.76	53.17	1.64	15.16	11.47	1.20	73558.73
22	8.49	10.31	64.56	1.92	14.53	12.30	1.20	67932.67
23	9.48	11.74	49.94	1.78	14.50	12.08	1.21	69874.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.75	9.48	57.49	2.54	13.62	12.20	1.21	68543.18
最 大 值	10.67	11.74	65.21	3.54	15.16	12.77	1.25	73558.73
發生時間	12	23	20	5	21	6		21
最 小 值	6.28	8.28	46.81	1.64	12.18	11.47	1.19	64089.47
發生時間	4	9	7	21	18	21		6
零點偏移(率)	0.00 %	-0.09 %	-0.08 %	-0.02 %		-0.02		0.20 %
全幅偏移(率)	0.00 %	0.12 %	0.20 %	-0.04 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月28日

報表日期: 114年08月28日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	2.55	10.56	57.45	2.58	14.57	11.42	0.94	75913.72
1	2.79	9.34	56.48	2.42	15.95	11.12	0.94	78770.25
2	2.89	9.48	55.96	2.60	14.16	11.46	0.94	75352.19
3	3.13	9.98	58.34	1.88	16.57	11.91	0.94	74401.66
4	2.98	9.17	54.08	2.00	16.27	11.22	0.94	80984.30
5	2.62	9.44	47.84	2.82	14.12	11.68	0.93	79002.00
6	3.06	5.74	56.64	3.28	15.44	11.40	0.97	81417.39
7	2.54	5.95	51.36	3.04	14.80	11.27	0.99	80005.27
8	2.36	10.42	52.90	2.93	14.72	11.46	1.00	77499.73
9	2.30	7.95	54.30	2.72	15.96	11.23	0.99	80193.78
10	2.32	9.29	62.38	2.50	15.86	11.12	1.00	81635.03
11	2.38	8.67	62.66	3.18	14.21	11.62	0.99	78647.15
12	2.54	8.35	56.39	2.46	15.77	11.64	0.98	76642.78
13	2.64	8.17	49.88	2.94	15.26	11.46	0.96	77098.89
14	4.12	8.10	50.00	3.38	14.54	11.28	0.94	74968.56
15	4.31	8.05	65.73	2.52	15.61	11.28	0.96	76770.75
16	2.20	8.31	64.09	1.92	16.41	10.72	0.97	81440.74
17	2.51	8.10	63.83	1.43	18.31	10.17	0.97	79202.51
18	2.21	9.02	52.96	1.78	16.89	10.25	0.97	84412.24
19	2.35	11.07	53.23	2.11	16.18	10.84	0.96	80113.49
20	2.33	9.12	54.12	2.14	16.89	10.39	0.97	80217.52
21	2.21	9.48	50.45	1.43	16.37	10.23	0.95	81471.51
22	2.20	10.33	60.42	2.79	15.41	11.15	0.96	79949.30
23	2.50	9.50	60.91	2.36	16.29	11.31	0.98	78207.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.67	8.90	56.35	2.47	15.69	11.15	0.96	78929.91
最 大 值	4.31	11.07	65.73	3.38	18.31	11.91	1.02	84412.24
發生時間	15	19	15	14	17	3		18
最 小 值	2.20	5.74	47.84	1.43	14.12	10.17	0.92	74401.66
發生時間	16	6	5	17	5	17		3
零點偏移(率)	-0.66 %	-0.00 %	-0.08 %	-0.00 %		-0.07		-0.20 %
全幅偏移(率)	0.14 %	-0.14 %	0.14 %	-0.13 %		-0.23		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

