

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月07日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.51	2.47	39.16	0.58	17.13	11.74	1.09	81460.39
1	9.97	6.17	50.25	0.89	17.38	11.18	1.08	85671.16
2	10.48	11.38	42.94	1.45	15.74	11.65	1.07	82979.54
3	11.35	8.46	43.59	2.64	13.37	12.22	1.05	79841.10
4	12.58	9.49	44.28	3.08	12.71	12.41	1.04	78515.82
5	13.30	10.07	48.17	2.46	14.20	12.11	1.02	78346.64
6	11.64	5.54	49.28	2.59	13.64	12.15	1.02	80101.34
7	13.63	6.85	52.72	3.02	12.99	12.78	1.02	75058.48
8	7.58	7.26	61.65	2.85	12.89	13.05	1.03	72140.11
9	13.36	6.66	64.19	2.28	13.67	12.12	1.03	77677.10
10	11.50	4.77	60.51	2.26	13.39	12.17	1.02	80669.31
11	12.15	6.49	59.79	2.45	13.67	12.30	1.02	78825.32
12	11.21	6.74	45.97	2.57	13.86	12.30	1.03	78634.98
13	10.24	5.81	46.57	3.34	12.31	12.60	1.02	77586.22
14	10.22	5.37	51.59	2.54	12.76	12.32	1.02	80241.82
15	8.98	6.17	57.97	2.82	12.34	12.94	1.06	74709.75
16	12.54	5.37	50.96	1.59	14.34	12.14	1.04	80709.70
17	17.32	5.63	48.34	2.88	13.52	12.14	1.04	81063.62
18	7.77	7.21	36.75	5.17	14.13	12.01	1.06	81756.08
19	12.67	5.95	35.01	5.10	13.05	12.05	1.03	81936.70
20	6.38	5.99	38.07	5.51	13.82	12.09	1.05	81176.13
21	3.93	6.25	38.67	4.81	13.59	12.02	1.06	81914.08
22	3.68	6.68	40.39	4.46	13.42	12.44	1.06	77891.27
23	7.67	5.84	40.27	3.19	13.82	12.26	1.04	79258.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.40	6.61	47.80	2.94	13.82	12.22	1.04	79506.87
最 大 值	17.32	11.38	64.19	5.51	17.38	13.05	1.09	85671.16
發生時間	17	2	9	20	1	8		1
最 小 值	3.68	2.47	35.01	0.58	12.31	11.18	1.02	72140.11
發生時間	22	0	19	0	13	1		8
零點偏移(率)	-0.02 %	-0.02 %	-0.02 %	-0.00 %		0.02		0.10 %
全幅偏移(率)	-0.01 %	-0.88 %	-0.09 %	-0.37 %		-0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月07日

[illegible]