

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.78	13.41	53.76	2.21	14.57	12.68	1.34	72268.23
1	13.73	12.18	46.18	2.62	15.37	11.60	1.32	80415.51
2	9.00	13.16	45.86	2.53	16.42	11.44	1.31	81348.46
3	9.77	13.19	55.31	1.78	15.95	10.94	1.31	85937.72
4	6.80	11.85	60.18	3.53	12.67	11.71	1.30	82466.21
5	8.96	13.31	44.13	1.50	15.94	11.84	1.30	78594.61
6	8.95	12.90	43.63	2.14	15.14	11.67	1.31	81187.18
7	10.07	13.12	42.13	2.04	14.89	11.84	1.33	80132.56
8	8.90	13.05	52.30	3.11	13.57	11.98	1.34	79316.98
9	9.41	13.62	49.77	3.26	13.49	12.18	1.34	77692.26
10	10.71	13.61	51.19	2.60	14.75	11.83	1.29	79216.30
11	12.59	13.54	49.74	3.50	12.86	11.92	1.29	78811.00
12	10.18	14.19	49.85	1.90	13.52	11.97	1.29	77944.18
13	12.45	13.66	49.58	2.83	12.99	12.06	1.30	77502.67
14	9.28	13.85	51.60	3.05	11.87	12.33	1.34	77129.83
15	12.05	14.30	54.18	2.54	12.72	12.59	1.34	74676.11
16	14.07	14.25	48.65	3.32	14.39	11.87	1.34	79891.41
17	11.31	13.10	54.89	3.13	14.11	12.01	1.33	78133.75
18	13.48	12.68	47.94	3.69	13.88	11.99	1.30	79537.84
19	10.90	13.50	58.12	3.04	14.08	11.89	1.29	79305.76
20	13.55	12.27	61.78	3.27	13.19	12.01	1.29	73204.45
21	9.09	14.46	52.91	3.02	14.09	11.72	1.29	77180.21
22	12.09	13.46	54.46	2.82	14.70	11.72	1.30	80375.07
23	9.66	12.15	52.19	2.48	13.80	11.98	1.29	77334.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.66	13.28	51.26	2.75	14.12	11.91	1.31	78733.43
最大值	14.07	14.46	61.78	3.69	16.42	12.68	1.35	85937.72
發生時間	16	21	20	18	2	0		3
最小值	6.80	11.85	42.13	1.50	11.87	10.94	1.29	72268.23
發生時間	4	4	7	5	14	3		0
零點偏移(率)	-0.03 %	-0.03 %	-0.17 %	0.00 %		-0.35	-0.01	0.30 %
全幅偏移(率)	0.72 %	0.33 %	0.50 %	0.46 %		0.10	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.20	11.87	51.41	1.90	15.23	10.77	1.04	77432.43
1	8.47	12.23	52.36	1.84	15.39	11.07	1.04	74729.94
2	5.25	12.20	47.16	1.97	15.56	10.71	1.03	75335.18
3	7.32	12.75	44.14	2.24	15.21	10.53	1.02	75627.08
4	4.25	11.69	40.36	1.47	15.40	10.08	1.02	73097.93
5	5.41	12.42	58.24	2.30	14.97	10.85	1.02	79601.08
6	2.84	11.71	49.21	1.33	17.00	10.67	1.02	77188.71
7	4.10	11.53	42.38	1.86	16.01	10.34	1.02	77637.42
8	8.49	11.65	41.54	1.24	15.96	10.61	1.03	76381.07
9	8.47	11.37	38.53	1.26	16.06	10.32	1.04	76803.45
10	9.10	11.81	49.41	1.84	14.72	10.75	1.02	75794.28
11	6.86	11.52	44.11	1.38	15.39	10.57	1.02	76480.92
12	5.71	12.87	55.38	1.61	14.16	10.63	1.01	75072.04
13	6.51	11.71	53.83	0.62	16.37	10.50	1.02	76415.20
14	6.12	11.84	57.60	0.80	15.28	10.71	1.03	75511.89
15	10.47	12.59	56.92	2.05	14.18	10.83	1.05	74661.96
16	14.94	12.92	62.10	2.94	13.60	10.79	1.05	77856.42
17	13.41	12.39	62.01	2.42	14.30	10.84	1.04	74731.62
18	14.59	12.81	59.51	2.15	15.06	10.44	1.03	75946.90
19	10.73	10.91	56.43	2.91	14.09	10.05	1.01	74804.36
20	11.53	10.84	56.68	2.63	15.07	9.78	1.00	75978.55
21	9.10	10.98	52.54	1.50	17.47	9.65	1.01	79193.39
22	7.33	11.81	56.89	1.51	16.41	9.41	1.01	76530.19
23	9.43	11.83	58.26	1.30	15.23	10.39	1.01	75715.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.57	11.93	51.96	1.79	15.34	10.47	1.03	76188.63
最大值	15.20	12.92	62.10	2.94	17.47	11.07	1.08	79601.08
發生時間	0	16	16	16	21	1		5
最小值	2.84	10.84	38.53	0.62	13.60	9.41	0.99	73097.93
發生時間	6	20	9	13	16	22		4
零點偏移(率)	-0.09 %	-0.07 %	-0.03 %	-0.01 %		-0.08	-0.01	-0.10 %
全幅偏移(率)	-0.05 %	0.27 %	0.51 %	-0.32 %		-0.14	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.33	12.33	46.36	2.43	15.69	10.07	1.43	74686.92
1	8.01	12.63	49.26	2.69	15.63	10.19	1.44	72881.26
2	7.14	15.20	38.39	3.17	18.06	8.74	1.43	71921.49
3	9.26	11.22	53.81	0.22	16.62	8.99	1.43	72657.09
4	8.39	11.25	52.97	1.21	16.96	9.16	1.44	73759.90
5	9.20	9.28	52.67	2.91	16.91	8.98	1.44	72014.88
6	8.96	12.63	48.15	1.65	18.03	8.55	1.44	74057.56
7	11.47	11.48	39.43	3.14	16.43	9.31	1.43	73404.04
8	3.05	11.74	42.41	4.17	15.82	9.43	1.43	72501.65
9	9.39	11.83	42.56	2.02	16.17	9.47	1.43	71170.56
10	10.54	11.22	40.79	1.68	18.06	8.65	1.43	74573.55
11	8.34	10.96	49.86	1.35	16.54	8.89	1.44	72571.15
12	7.43	12.77	51.85	1.91	15.83	9.08	1.41	69137.10
13	9.30	11.29	53.21	1.71	16.54	8.82	1.41	70523.57
14	5.66	11.28	48.25	1.16	16.72	8.83	1.42	71037.92
15	8.01	11.95	45.20	2.44	15.54	9.20	1.42	69442.15
16	10.23	12.59	40.94	2.86	16.46	8.92	1.42	71779.47
17	7.81	12.66	48.26	2.12	15.59	9.06	1.41	71479.59
18	9.49	10.96	56.35	2.19	17.08	9.09	1.42	72913.42
19	9.83	11.67	58.56	2.29	15.25	9.11	1.41	73233.37
20	8.30	10.99	58.04	2.54	15.87	9.13	1.42	71401.64
21	9.42	10.91	58.05	2.36	16.24	9.16	1.43	74493.58
22	9.03	11.46	49.95	1.73	17.43	8.73	1.43	73579.87
23	8.64	11.38	52.38	1.98	16.79	8.83	1.42	72055.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.55	11.74	49.07	2.16	16.51	9.10	1.43	72386.57
最大值	11.47	15.20	58.56	4.17	18.06	10.19	1.46	74686.92
發生時間	7	2	19	8	2	1		0
最小值	3.05	9.28	38.39	0.22	15.25	8.55	1.40	69137.10
發生時間	8	5	2	3	19	6		12
零點偏移(率)	-0.13 %	-0.04 %	-0.01 %	0.00 %		-0.07	-0.01	0.20 %
全幅偏移(率)	-0.50 %	-1.39 %	0.28 %	0.18 %		0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								