

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.87	6.47	47.70	2.35	16.91	11.95	1.42	73496.49
1	10.30	6.20	51.09	2.19	17.43	12.02	1.42	72327.67
2	9.69	2.83	47.47	2.24	17.72	11.97	1.41	72859.93
3	10.83	1.26	57.72	2.16	17.61	11.83	1.42	74291.97
4	9.43	1.35	53.52	2.04	18.04	11.54	1.44	76103.99
5	12.41	3.12	48.01	1.90	18.99	11.06	1.48	77713.87
6	8.67	3.23	47.72	2.05	18.17	11.50	1.48	76381.69
7	11.00	1.65	48.56	2.30	17.10	11.86	1.48	74728.84
8	6.18	2.75	46.11	2.40	16.12	11.94	1.47	71118.39
9	6.39	4.05	43.85	2.63	16.12	12.11	1.44	72208.09
10	10.18	2.64	44.92	2.44	16.84	11.93	1.45	73115.43
11	9.27	4.63	47.81	2.38	17.26	11.99	1.45	72476.42
12	10.12	2.23	45.24	2.34	17.10	11.81	1.42	73995.65
13	10.23	1.27	55.77	2.19	17.88	11.71	1.46	74122.99
14	6.65	1.82	55.91	2.17	17.85	12.15	1.48	70998.12
15	11.09	2.58	49.63	2.32	17.42	11.84	1.46	73647.75
16	12.86	8.98	45.94	2.61	16.57	12.05	1.44	72384.46
17	8.29	0.74	54.23	2.18	17.76	12.00	1.44	71986.61
18	8.47	1.03	59.47	1.98	18.38	11.76	1.48	73945.57
19	12.26	1.50	59.17	2.12	17.99	11.79	1.48	73549.82
20	10.78	2.45	54.57	2.25	17.38	11.93	1.47	72948.20
21	9.27	2.40	64.49	2.18	18.23	12.35	1.48	69083.86
22	10.39	1.90	57.29	2.08	18.37	11.85	1.49	72788.47
23	8.70	4.83	57.43	2.18	17.88	12.01	1.49	72076.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.72	3.00	51.82	2.24	17.55	11.87	1.46	73264.63
最大值	12.86	8.98	64.49	2.63	18.99	12.35	1.50	77713.87
發生時間	16	16	21	9	5	21		5
最小值	6.18	0.74	43.85	1.90	16.12	11.06	1.41	69083.86
發生時間	8	17	9	5	8	5		21
零點偏移(率)	-0.14 %	-0.03 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.02 %	-0.08 %	-0.14 %	0.59 %		0.44	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.51	1.59	66.41	2.29	15.76	10.54	1.46	66717.42
1	10.00	3.22	53.73	2.35	14.93	10.96	1.46	64296.92
2	9.74	3.71	54.73	2.08	17.02	10.52	1.46	64579.54
3	11.10	4.68	54.45	2.94	15.31	10.26	1.46	64414.24
4	10.20	4.50	47.30	2.23	16.40	10.25	1.45	64625.03
5	10.37	1.24	55.32	2.10	16.65	10.33	1.44	65816.06
6	8.93	5.19	60.26	2.52	14.32	11.23	1.40	68193.04
7	10.35	5.20	54.68	2.57	13.84	11.05	1.39	63247.84
8	9.79	1.25	51.36	2.57	14.11	10.66	1.38	60174.29
9	9.28	4.91	50.87	2.40	14.81	9.78	1.36	57983.75
10	9.99	2.54	56.28	2.44	14.87	10.03	1.40	61308.70
11	10.30	0.87	65.31	2.18	14.93	10.99	1.38	64295.24
12	10.31	1.81	53.06	2.11	15.89	10.53	1.36	61159.10
13	10.31	2.18	50.58	2.08	15.84	10.10	1.38	61226.78
14	11.51	4.30	51.72	2.46	14.95	10.27	1.38	60707.60
15	11.62	7.34	60.34	3.02	15.89	10.83	1.38	63920.33
16	9.79	2.32	49.43	2.37	14.81	10.95	1.36	63569.41
17	11.39	1.23	53.79	2.20	14.41	11.21	1.36	62745.42
18	10.37	1.51	55.97	2.41	13.93	11.10	1.39	62870.59
19	9.94	0.68	53.16	2.18	15.06	11.07	1.42	62397.98
20	11.07	1.22	46.95	2.11	16.18	10.28	1.41	62634.85
21	10.52	0.89	53.53	2.34	15.03	10.94	1.43	65214.93
22	10.74	0.61	50.46	2.18	14.94	11.12	1.44	63552.57
23	9.90	1.28	51.52	1.98	15.70	10.80	1.42	62381.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.38	2.68	54.22	2.34	15.23	10.66	1.41	63251.37
最大值	11.62	7.34	66.41	3.02	17.02	11.23	1.47	68193.04
發生時間	15	15	0	15	2	6		6
最小值	8.93	0.61	46.95	1.98	13.84	9.78	1.34	57983.75
發生時間	6	22	20	23	7	9		9
零點偏移(率)	-0.10 %	-0.07 %	-0.00 %	-0.01 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.61 %	0.34 %	0.14 %	0.22 %		0.31	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.26	6.14	50.45	2.76	14.04	11.28	1.80	84378.27
1	15.51	3.47	53.37	2.82	13.80	11.60	1.80	82681.00
2	11.80	3.47	56.88	2.17	15.32	11.44	1.80	84147.55
3	13.08	7.41	54.43	3.14	12.87	11.62	1.80	82315.99
4	13.48	6.04	52.73	2.76	13.59	11.38	1.80	83439.42
5	12.66	4.48	63.85	2.70	14.01	11.67	1.80	82159.85
6	8.89	5.78	55.57	3.08	12.76	11.58	1.79	83531.46
7	12.07	11.62	50.40	4.04	11.05	11.82	1.73	71251.83
8	5.27	7.81	51.97	2.97	11.90	11.62	1.74	77424.14
9	6.60	11.92	57.09	3.51	11.39	12.27	1.75	74692.73
10	8.72	5.88	66.24	2.79	13.46	11.63	1.78	82772.49
11	14.61	4.33	54.20	3.27	12.45	11.45	1.75	82749.59
12	9.58	2.83	57.62	3.14	12.26	11.56	1.74	81166.14
13	11.68	2.36	56.71	3.22	12.68	11.44	1.75	80760.86
14	10.23	1.28	55.99	2.62	13.45	11.28	1.76	79243.61
15	11.29	2.64	59.54	2.99	12.69	11.87	1.76	80027.18
16	8.79	2.01	58.63	2.18	14.06	11.48	1.75	81221.46
17	10.58	1.99	67.03	2.68	13.31	11.62	1.76	79722.93
18	11.50	1.50	68.34	2.53	14.03	11.69	1.74	79270.11
19	12.34	1.97	68.75	1.85	15.21	11.40	1.76	80629.52
20	11.29	1.35	67.22	2.14	14.61	11.59	1.76	78573.94
21	13.38	2.53	65.77	2.61	13.62	11.70	1.76	78339.22
22	12.11	2.09	68.24	2.41	14.11	11.56	1.76	79886.26
23	13.10	3.67	64.95	2.45	14.21	11.30	1.76	82018.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.37	4.36	59.42	2.78	13.37	11.58	1.77	80516.83
最大值	15.51	11.92	68.75	4.04	15.32	12.27	1.81	84378.27
發生時間	1	9	19	7	2	9		0
最小值	5.27	1.28	50.40	1.85	11.05	11.28	1.72	71251.83
發生時間	8	14	7	19	7	0		7
零點偏移(率)	-0.07%	-0.03%	-0.11%	-0.04%		0.02	0.00	0.00%
全幅偏移(率)	0.02%	0.06%	-0.11%	0.10%		0.33	0.00	0.20%
有效比率	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
備註								