

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.55	3.49	59.21	1.69	19.45	12.47	1.41	65804.96
1	0.27	16.49	71.82	1.77	19.16	13.45	1.61	58757.33
2	0.75	4.31	36.19	1.87	18.54	12.68	1.61	65366.46
3	5.01	1.45	38.99	1.59	19.04	11.76	1.45	71723.78
4	6.72	6.26	51.34	1.72	18.92	11.55	1.45	74121.43
5	14.78	8.28	39.65	2.52	17.91	11.68	1.46	73480.06
6	9.96	6.18	50.11	2.01	19.34	11.32	1.47	75644.82
7	5.05	2.00	43.70	1.79	19.75	11.19	1.47	75964.08
8	2.90	1.59	43.55	1.78	19.27	11.59	1.45	73223.04
9	2.60	1.43	56.24	1.74	20.03	11.41	1.41	74319.52
10	10.39	9.29	44.89	1.87	18.79	11.30	1.41	76497.24
11	7.88	3.41	46.25	2.06	18.53	11.40	1.40	75982.17
12	9.01	1.66	53.26	2.06	18.73	11.34	1.41	75997.32
13	8.63	2.08	48.44	2.13	18.60	11.44	1.43	75267.16
14	3.80	1.09	54.28	1.88	18.84	11.51	1.46	74412.03
15	7.31	1.02	57.41	1.78	19.89	11.21	1.46	76207.33
16	9.73	2.21	47.09	2.14	18.03	11.48	1.46	74939.13
17	4.92	4.21	48.17	2.09	17.71	11.60	1.46	75006.84
18	1.36	1.07	60.71	1.83	18.93	11.51	1.45	74224.33
19	1.22	1.76	68.06	1.90	18.70	12.01	1.46	70946.69
20	1.92	1.01	65.85	1.83	18.78	11.57	1.44	75000.01
21	1.50	0.98	64.22	1.77	18.94	11.68	1.44	73316.65
22	0.09	0.88	66.23	1.42	20.81	11.30	1.44	74740.65
23	0.94	1.69	63.58	1.85	19.56	12.12	1.45	69104.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.05	3.49	53.30	1.88	19.01	11.69	1.46	72918.64
最大值	14.78	16.49	71.82	2.52	20.81	13.45	1.90	76497.24
發生時間	5	1	1	5	22	1		10
最小值	0.09	0.88	36.19	1.42	17.71	11.19	1.40	58757.33
發生時間	22	22	2	22	17	7		1
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	3.36 %	0.33 %	-0.89 %	0.22 %		0.31	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.13	0.99	58.94	0.64	20.68	10.37	1.38	64225.58
1	3.72	3.48	45.92	1.09	18.88	10.09	1.38	64674.04
2	3.01	1.89	47.80	1.31	17.57	10.51	1.38	66098.01
3	4.01	3.30	49.71	1.52	16.86	10.59	1.38	63601.72
4	4.46	2.46	50.83	1.23	18.26	10.36	1.38	65061.48
5	3.35	9.92	45.42	1.25	18.35	10.11	1.38	64719.06
6	1.59	4.63	40.90	1.27	18.19	9.72	1.39	63776.73
7	3.48	0.61	49.19	1.64	16.37	9.84	1.43	63807.19
8	8.95	1.24	51.62	1.98	17.16	9.77	1.46	65402.03
9	3.78	2.62	49.83	1.26	18.06	9.65	1.44	65646.71
10	2.43	5.15	42.76	1.66	15.75	10.41	1.44	64640.57
11	3.70	2.58	48.71	1.57	16.60	10.35	1.43	66041.50
12	8.54	5.27	48.64	2.10	15.27	10.65	1.42	63552.32
13	3.61	7.84	50.65	1.36	17.52	10.04	1.39	65206.99
14	1.76	1.85	43.88	1.42	16.69	10.16	1.42	65942.30
15	4.17	4.36	50.16	1.54	16.78	10.46	1.44	65969.84
16	2.40	2.55	38.85	1.67	15.40	10.22	1.45	62449.28
17	0.63	3.88	42.98	1.36	16.49	9.94	1.45	63425.23
18	0.33	1.20	43.09	1.35	16.57	10.21	1.45	63284.58
19	1.20	9.23	48.70	1.44	15.67	10.49	1.46	65129.30
20	1.67	1.12	61.96	1.55	16.08	11.29	1.46	62058.94
21	2.04	1.09	57.39	1.09	17.72	10.49	1.46	66867.81
22	3.77	1.28	59.91	1.31	17.16	10.83	1.46	65795.91
23	6.69	1.07	56.52	1.27	17.82	10.44	1.46	66505.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.52	3.32	49.35	1.41	17.16	10.29	1.42	64745.10
最大值	8.95	9.92	61.96	2.10	20.68	11.29	1.46	66867.81
發生時間	8	5	20	12	0	20		21
最小值	0.33	0.61	38.85	0.64	15.27	9.65	1.37	62058.94
發生時間	18	7	16	0	12	9		20
零點偏移(率)	-0.05 %	-0.03 %	-0.02 %	0.00 %		-0.05	0.00	0.00 %
全幅偏移(率)	1.58 %	0.32 %	-0.00 %	0.24 %		0.21	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.68	2.34	59.15	0.77	18.39	10.69	1.87	87165.98
1	5.68	4.17	57.20	0.92	17.36	10.92	1.86	87260.80
2	4.70	3.46	62.29	0.99	16.65	11.15	1.85	86364.32
3	8.53	2.63	55.72	1.09	16.08	11.13	1.85	86328.59
4	7.02	4.70	57.46	1.34	15.47	11.24	1.84	86121.20
5	6.05	1.92	56.20	1.36	15.08	11.40	1.82	84530.99
6	9.42	2.43	54.55	1.48	15.10	11.23	1.82	86373.04
7	4.70	4.11	58.43	1.63	14.49	11.47	1.83	86587.17
8	2.92	2.17	57.93	1.51	14.71	11.34	1.85	85344.64
9	3.17	2.41	63.40	1.59	14.48	11.48	1.83	83853.70
10	3.16	2.25	61.67	1.67	14.41	11.47	1.82	84942.88
11	4.55	2.68	59.19	1.59	14.69	11.38	1.81	86166.56
12	10.17	4.65	62.65	2.03	14.07	11.51	1.81	84526.84
13	8.12	3.62	62.81	1.91	14.43	11.45	1.83	84851.06
14	5.04	3.15	60.46	1.68	14.41	11.47	1.85	85348.40
15	7.18	5.40	62.99	1.99	13.93	11.52	1.85	85074.56
16	4.08	5.61	66.01	2.00	13.99	11.60	1.84	85038.25
17	1.92	3.02	65.01	1.34	15.01	11.30	1.83	86312.64
18	1.05	6.20	60.63	1.16	15.58	11.00	1.81	88960.95
19	2.79	5.94	64.59	1.19	16.27	10.99	1.80	88297.50
20	4.07	5.06	62.69	1.16	15.65	11.15	1.80	88147.48
21	2.69	6.53	65.97	1.27	15.39	11.56	1.82	83718.61
22	1.23	7.78	65.65	1.21	15.94	11.38	1.85	85162.82
23	7.93	11.98	62.96	2.40	12.79	11.70	1.83	84093.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.04	4.34	61.07	1.47	15.18	11.31	1.83	85857.18
最大值	10.17	11.98	66.01	2.40	18.39	11.70	1.89	88960.95
發生時間	12	23	16	23	0	23		18
最小值	1.05	1.92	54.55	0.77	12.79	10.69	1.79	83718.61
發生時間	18	5	6	0	23	0		21
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.01 %		-0.47	0.00	0.00 %
全幅偏移(率)	3.41 %	0.26 %	-0.46 %	0.37 %		0.28	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								