

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月29日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.41	12.20	59.73	1.13	19.48	10.40	0.94	85510.27
1	12.13	12.94	46.32	1.45	19.49	10.49	0.94	85109.28
2	7.41	12.47	53.95	1.23	18.51	10.91	0.94	83094.89
3	12.53	12.43	57.50	1.27	18.51	10.81	0.94	83886.14
4	7.94	12.32	54.64	1.24	18.53	10.87	0.94	83345.75
5	9.83	13.31	58.97	1.07	19.39	10.61	0.95	84368.54
6	9.88	11.87	54.79	1.84	19.13	10.33	0.95	84228.15
7	12.41	12.40	57.35	1.26	19.56	10.39	0.93	86100.19
8	10.03	12.97	50.24	1.81	17.86	10.91	0.94	83629.73
9	6.88	13.69	55.48	1.66	17.70	11.03	0.94	82070.71
10	10.85	13.78	57.01	1.78	17.25	11.05	0.93	82238.12
11	8.48	13.64	61.16	1.54	18.01	10.97	0.94	81807.47
12	9.30	13.99	55.02	1.53	18.40	11.16	0.92	80110.17
13	6.70	14.02	54.05	2.38	17.61	10.97	0.91	83013.48
14	9.55	13.44	60.12	1.58	19.11	10.69	0.93	83434.58
15	10.55	14.65	49.28	1.46	18.74	10.84	0.91	82866.39
16	7.09	14.71	50.43	1.46	18.16	10.99	0.92	82609.23
17	9.19	13.43	56.29	2.53	17.20	11.29	0.91	81444.82
18	6.85	13.29	46.60	1.86	18.15	10.97	0.90	82035.90
19	9.10	12.66	54.59	1.15	19.13	10.89	0.90	81626.50
20	6.96	13.22	56.22	1.46	18.47	10.79	0.90	83668.37
21	8.95	12.59	55.47	0.46	19.16	10.41	0.90	85558.66
22	8.15	12.00	55.91	0.70	20.04	10.24	0.91	86446.02
23	9.81	12.15	47.48	0.87	19.87	10.32	0.91	85947.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.12	13.09	54.52	1.45	18.64	10.76	0.92	83506.27
最 大 值	12.53	14.71	61.16	2.53	20.04	11.29	0.99	86446.02
發生時間	3	16	11	17	22	17		22
最 小 值	6.70	11.87	46.32	0.46	17.20	10.24	0.90	80110.17
發生時間	13	6	1	21	17	22		12
零點偏移(率)	-0.07 %	-0.07 %	-0.03 %	-0.01 %		0.04	-0.01	-0.10 %
全幅偏移(率)	1.40 %	-1.58 %	0.58 %	-0.38 %		0.24	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月29日

[illegible]