

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.88	18.18	43.48	1.54	20.58	9.89	1.10	75029.41
1	1.67	18.18	52.22	1.70	19.71	10.75	1.10	72215.52
2	4.05	17.04	43.63	2.42	17.39	11.12	1.11	71367.49
3	8.30	17.48	48.47	2.58	17.81	11.06	1.10	72533.68
4	7.50	17.65	53.77	2.41	17.14	11.30	1.10	71097.45
5	11.11	16.38	55.92	2.40	18.71	10.68	1.03	70590.70
6	9.69	18.19	52.76	2.47	17.98	11.00	1.03	72488.60
7	9.90	17.57	59.26	2.57	17.43	11.21	1.04	71637.44
8	6.92	17.58	46.95	2.15	18.72	10.77	1.05	73788.58
9	7.40	17.18	51.42	2.67	17.07	11.15	1.07	72192.35
10	3.93	17.21	53.16	2.07	18.56	10.80	1.06	73955.07
11	7.98	16.50	44.57	2.27	18.49	10.29	1.07	75980.12
12	9.33	17.32	46.51	2.80	16.80	11.21	1.06	69941.98
13	9.67	17.77	53.76	2.29	19.44	10.70	1.05	73045.83
14	7.55	18.16	51.47	2.06	19.18	11.01	1.05	70701.06
15	6.52	無效	45.88	2.37	17.40	11.34	1.05	67854.90
16	9.29	17.70	52.16	2.16	18.68	10.29	1.06	77016.86
17	9.95	無效	49.10	3.14	16.01	11.48	1.06	69695.81
18	6.43	8.87	65.05	2.19	18.08	11.58	1.07	68081.96
19	6.48	15.45	52.12	1.84	19.70	10.64	1.07	73444.67
20	9.22	19.19	58.15	2.34	17.73	11.31	1.06	70126.80
21	10.08	18.30	47.33	2.43	17.58	10.98	1.05	72212.68
22	10.17	15.57	62.18	2.30	18.12	10.92	1.03	72394.47
23	9.60	16.65	57.16	2.36	19.10	10.76	1.04	72612.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	7.86	17.01	51.94	2.31	18.23	10.93	1.06	72083.57
最大值	11.11	19.19	65.05	3.14	20.58	11.58	1.11	77016.86
發生時間	5	17	18	17	0	18		16
最小值	1.67	8.87	43.48	1.54	16.01	9.89	1.03	67854.90
發生時間	1	18	0	0	17	0		15
零點偏移(率)	0.00 %	0.00 %	-0.03 %	0.00 %		0.06		0.00 %
全幅偏移(率)	-0.91 %	0.03 %	0.02 %	0.03 %		-0.09		0.20 %
有效比率	100.00 %	91.67%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.69	16.51	56.06	0.48	19.43	10.05	1.14	83209.14
1	3.40	16.77	56.52	0.64	19.27	9.94	1.15	84597.27
2	6.75	17.24	56.19	1.29	17.56	9.94	1.15	82778.33
3	6.34	13.88	63.80	1.11	18.24	9.99	1.15	83629.56
4	9.16	14.20	54.96	1.50	17.35	10.16	1.14	83996.51
5	9.01	19.19	63.31	1.31	18.42	9.58	1.13	82407.11
6	9.28	12.85	61.72	2.33	17.13	10.14	1.15	76430.32
7	9.72	19.63	61.03	2.32	16.64	10.10	1.15	78804.72
8	5.42	19.54	55.93	1.55	19.05	9.10	1.15	78227.77
9	9.17	12.46	69.27	2.44	16.78	9.33	1.16	77015.36
10	5.87	16.89	50.17	1.88	17.02	9.43	1.16	73450.90
11	3.51	無效	57.34	0.91	17.68	10.13	1.15	67456.49
12	4.18	8.79	55.74	0.90	19.10	9.63	1.16	74055.06
13	9.80	7.38	64.15	1.19	18.38	9.79	1.18	81941.99
14	7.36	6.79	55.98	0.86	19.19	10.85	1.17	79190.26
15	3.64	13.80	55.65	0.73	19.73	9.80	1.15	78028.29
16	2.07	無效	57.43	1.53	18.25	9.56	1.16	78543.12
17	2.01	11.42	62.64	1.35	18.70	9.49	1.16	78907.41
18	1.85	11.36	62.50	1.31	18.84	9.33	1.15	78515.79
19	0.48	13.61	56.10	0.92	19.73	9.24	1.15	80520.51
20	7.22	19.42	54.80	1.76	17.58	9.64	1.16	81192.31
21	10.04	17.10	54.02	1.92	17.30	9.75	1.17	81485.47
22	8.42	13.23	64.99	1.51	18.36	9.75	1.15	80154.03
23	5.09	14.79	53.96	1.56	18.06	9.93	1.15	77628.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	5.90	14.40	58.51	1.39	18.24	9.78	1.15	79256.93
最大值	10.04	19.63	69.27	2.44	19.73	10.85	1.18	84597.27
發生時間	21	7	9	9	15	14		1
最小值	0.48	6.79	50.17	0.48	16.64	9.10	1.13	67456.49
發生時間	19	14	10	0	7	8		11
零點偏移(率)	-0.58 %	-0.16 %	-0.02 %	-0.02 %		0.03		0.00 %
全幅偏移(率)	-0.79 %	-4.91 %	-0.45 %	-2.58 %		0.00		0.00 %
有效比率	100.00 %	91.67%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.32	17.12	66.93	2.07	16.98	10.68	1.05	82996.37
1	3.95	17.00	58.39	2.06	17.83	10.87	1.05	81529.37
2	6.38	15.56	60.72	2.32	16.84	10.60	1.06	83164.43
3	5.38	19.52	65.20	2.58	15.81	10.90	1.06	82330.13
4	3.62	19.35	57.33	2.49	15.48	10.99	1.08	80678.43
5	6.53	16.32	63.55	2.60	16.13	10.99	1.08	80526.62
6	6.13	15.21	60.23	2.63	15.52	11.15	1.07	79485.88
7	6.63	18.23	65.53	3.01	15.85	10.90	1.08	79856.61
8	5.10	13.09	59.15	2.79	16.42	10.72	1.08	83079.70
9	6.66	14.97	63.63	3.34	14.81	11.19	1.09	78375.77
10	3.98	17.79	55.13	3.03	15.20	10.60	1.05	77198.48
11	5.03	17.35	53.58	3.13	16.43	10.11	1.08	76854.44
12	4.48	17.76	52.14	2.92	16.46	10.08	1.10	76889.88
13	1.92	18.33	60.15	2.67	18.78	9.63	1.06	77791.88
14	5.13	17.42	54.88	2.64	17.24	9.84	1.05	76847.13
15	3.65	17.97	59.79	2.68	18.17	9.97	1.08	78260.80
16	5.25	無效	66.39	2.83	16.42	10.36	1.10	80002.08
17	3.99	無效	51.04	2.90	15.52	10.54	1.09	76986.60
18	4.84	14.19	51.98	2.76	15.90	10.62	1.06	75043.14
19	5.02	14.28	63.62	2.55	17.75	10.13	1.04	79876.90
20	6.79	13.74	55.57	2.82	15.70	10.79	1.03	77081.99
21	6.78	17.35	57.64	2.56	17.06	10.36	1.07	80037.87
22	6.38	12.22	55.33	2.65	16.43	10.40	1.06	79452.69
23	3.85	12.31	59.90	2.48	17.19	10.50	1.02	78398.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	5.03	16.23	59.08	2.69	16.50	10.54	1.07	79281.09
最大值	6.79	19.52	66.93	3.34	18.78	11.19	1.10	83164.43
發生時間	20	3	0	9	13	9		2
最小值	1.92	12.22	51.04	2.06	14.81	9.63	1.02	75043.14
發生時間	13	22	17	1	9	13		18
零點偏移(率)	-0.02 %	-0.03 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-2.54 %	-0.12 %	-1.44 %		0.17		0.00 %
有效比率	100.00 %	91.67%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								