

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年01月17日

報表日期: 113年01月17日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.73	5.00	48.03	0.60	18.46	11.16	1.09	84394.90
1	9.81	12.26	40.49	1.25	17.07	11.30	1.09	84295.28
2	9.73	7.02	58.32	0.76	16.75	11.43	1.10	83334.09
3	9.26	7.94	47.73	1.56	14.40	11.59	1.10	84921.78
4	9.14	8.71	58.03	2.40	13.70	12.02	1.10	81322.19
5	11.69	3.55	45.18	3.95	12.94	12.34	1.09	73770.14
6	9.08	6.02	47.50	2.68	13.42	12.01	1.09	79940.53
7	9.51	5.59	55.35	2.24	13.52	12.23	1.09	78287.58
8	5.80	10.42	48.17	3.75	11.58	13.52	1.09	67926.47
9	4.42	3.37	54.19	3.22	12.20	13.33	1.07	68347.85
10	5.59	4.20	53.91	3.54	11.53	13.27	1.09	68362.29
11	10.07	13.02	42.10	4.10	11.23	12.84	1.07	71628.47
12	5.22	6.61	43.23	2.16	12.98	12.60	1.05	71808.67
13	8.59	4.00	43.59	1.92	13.33	11.88	1.06	80907.43
14	9.59	4.59	41.22	2.72	12.87	12.20	1.06	78186.32
15	8.55	3.07	48.22	2.04	13.40	12.31	1.09	76714.12
16	10.00	2.55	58.42	1.20	14.56	10.96	1.08	88984.37
17	9.66	2.33	45.71	2.06	13.35	12.00	1.09	81417.54
18	8.99	2.37	51.62	1.45	14.84	11.99	1.07	80980.30
19	9.12	2.11	49.35	2.62	13.34	12.06	1.10	81398.24
20	7.69	2.52	57.30	1.68	14.44	12.32	1.10	78128.27
21	8.55	2.36	56.90	0.99	15.06	11.87	1.10	81327.99
22	9.65	2.25	53.15	0.74	16.10	11.34	1.09	84806.73
23	8.38	2.52	55.09	1.08	15.52	11.65	1.07	82651.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.66	5.18	50.12	2.11	14.02	12.09	1.08	78910.13
最 大 值	11.69	13.02	58.42	4.10	18.46	13.52	1.12	88984.37
發生時間	5	11	16	11	0	8		16
最 小 值	4.42	2.11	40.49	0.60	11.23	10.96	1.04	67926.47
發生時間	9	19	1	0	11	16		8
零點偏移(率)	-0.02 %	-0.00 %	-0.08 %	-0.01 %		-0.07		0.10 %
全幅偏移(率)	0.02 %	-0.33 %	-0.20 %	0.09 %		-0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月17日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	7.56	4.54	32.64	2.06	16.72	10.61	1.01	83105.36
1	4.80	6.18	35.33	1.92	16.07	10.77	1.02	83190.30
2	7.19	2.60	45.60	2.22	14.46	11.05	1.02	83154.05
3	7.15	2.45	46.79	2.57	13.76	11.11	1.02	83075.87
4	6.06	3.69	45.01	2.85	12.74	11.43	1.02	80997.59
5	6.61	4.44	44.79	2.76	13.86	11.06	1.02	83456.16
6	8.02	4.34	48.74	3.02	12.48	11.48	1.02	79448.12
7	8.99	4.68	48.31	3.55	12.45	11.53	1.04	80080.16
8	1.81	6.17	51.77	3.56	12.57	12.78	1.04	69681.34
9	1.51	5.20	42.21	3.58	11.34	12.92	1.01	69133.97
10	5.25	5.18	45.08	2.17	11.52	12.30	1.02	76465.11
11	7.45	2.83	46.99	1.75	12.79	12.44	1.02	74201.30
12	6.04	2.99	37.79	1.13	14.56	11.20	1.00	82729.36
13	9.09	3.77	36.85	1.48	14.60	11.13	0.99	82669.26
14	10.50	5.90	43.00	1.72	13.71	11.44	1.02	80458.68
15	9.70	6.88	43.85	1.89	12.98	11.24	1.03	81682.68
16	8.75	6.64	35.42	1.43	15.23	10.38	1.03	85868.75
17	8.12	2.16	44.71	0.77	16.14	10.82	1.00	83165.65
18	8.09	8.42	39.97	1.42	13.99	10.94	1.01	83304.66
19	8.09	5.61	39.90	1.55	13.75	10.73	1.03	85005.34
20	8.51	0.79	45.82	1.52	13.70	11.04	1.04	82285.27
21	9.14	1.60	49.73	1.29	13.73	11.04	1.04	82850.56
22	8.75	2.72	47.24	1.17	14.67	10.89	1.04	82677.19
23	9.44	6.99	38.55	1.30	14.75	10.71	1.03	84188.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.36	4.45	43.17	2.03	13.86	11.29	1.02	80953.11
最 大 值	10.50	8.42	51.77	3.58	16.72	12.92	1.06	85868.75
發生時間	14	18	8	9	0	9		16
最 小 值	1.51	0.79	32.64	0.77	11.34	10.38	0.99	69133.97
發生時間	9	20	0	17	9	16		9
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.04 %		0.00		0.10 %
全幅偏移(率)	0.00 %	-0.03 %	-0.19 %	0.14 %		-0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月17日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.50	2.82	44.87	0.86	15.65	10.61	1.09	76583.14
1	3.27	7.52	49.67	1.28	15.85	10.21	1.09	78301.97
2	12.73	9.02	53.17	2.71	13.74	10.59	1.09	78339.43
3	10.83	3.03	54.63	3.11	13.23	11.01	1.09	78375.97
4	9.74	2.69	53.27	2.80	13.29	11.03	1.09	77993.06
5	8.42	3.22	51.78	2.80	13.02	10.95	1.10	78324.25
6	7.39	4.91	47.23	2.75	13.51	10.74	1.09	77960.67
7	4.06	4.64	52.47	2.96	12.02	11.34	1.07	71129.98
8	1.40	0.96	49.80	2.95	12.22	11.83	1.08	63931.60
9	0.04	6.52	46.74	2.40	12.51	11.76	1.09	64539.61
10	0.69	3.60	45.09	1.94	13.14	11.54	1.09	65738.11
11	1.21	6.19	47.67	1.35	13.99	11.39	1.07	67356.72
12	1.16	6.79	39.95	0.95	14.94	10.34	1.09	77423.86
13	7.24	7.15	48.06	3.41	12.68	11.31	1.09	73569.98
14	5.31	5.13	48.69	2.74	13.43	11.31	1.08	74423.73
15	14.10	3.86	54.23	4.00	13.09	10.56	1.07	74661.24
16	6.01	4.42	51.68	3.71	13.06	10.12	1.09	78183.16
17	4.98	1.91	46.71	1.06	14.90	10.08	1.09	76483.26
18	6.39	1.97	45.99	1.29	13.68	10.36	1.09	73729.21
19	6.35	4.81	47.16	1.24	14.23	10.18	1.09	74407.84
20	4.88	5.76	43.10	0.97	13.80	10.24	1.09	73712.74
21	1.35	3.42	44.02	0.61	14.61	10.18	1.09	74321.51
22	2.03	4.28	41.97	0.58	14.97	10.09	1.09	74877.46
23	3.88	3.77	41.92	0.57	15.58	10.02	1.09	75977.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.29	4.52	47.91	2.04	13.80	10.74	1.09	74181.08
最 大 值	14.10	9.02	54.63	4.00	15.85	11.83	1.13	78375.97
發生時間	15	2	3	15	1	8		3
最 小 值	0.04	0.96	39.95	0.57	12.02	10.02	1.06	63931.60
發生時間	9	8	12	23	7	23		8
零點偏移(率)	-0.02 %	-0.01 %	-0.05 %	-0.05 %		0.03		0.10 %
全幅偏移(率)	0.02 %	0.04 %	0.08 %	0.20 %		0.13		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								