

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月31日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.21	6.27	49.75	2.25	16.87	11.92	0.97	79613.44
1	8.76	3.76	56.88	2.04	20.09	10.94	0.97	85122.65
2	8.46	3.61	52.07	2.11	19.48	11.10	0.96	84411.85
3	9.57	3.16	56.03	2.95	17.04	11.77	0.96	80655.93
4	8.65	4.04	59.34	3.02	17.53	11.86	0.97	79200.48
5	7.54	3.37	48.85	1.65	17.77	11.91	0.95	81725.45
6	5.78	2.80	63.73	1.82	18.92	11.43	0.96	81609.64
7	3.16	2.87	55.22	1.96	18.26	11.29	0.97	82808.59
8	3.75	5.47	49.56	3.28	16.35	11.81	0.97	80211.83
9	10.80	2.95	46.81	4.19	16.44	11.70	0.95	81102.18
10	6.08	2.63	47.00	3.17	16.13	11.89	0.96	79686.18
11	5.60	2.53	52.47	1.08	17.48	11.62	0.94	80616.91
12	6.24	2.69	49.84	1.16	17.47	11.69	0.96	80337.55
13	7.99	2.57	50.35	0.93	17.92	11.57	0.94	80843.37
14	7.98	2.80	45.82	1.34	16.20	11.98	0.94	78383.77
15	6.81	3.87	44.61	2.63	15.87	12.03	0.94	78303.92
16	7.41	3.97	44.55	2.89	16.38	11.81	0.95	80339.66
17	5.96	2.73	54.27	1.81	18.53	11.48	0.95	81506.84
18	7.33	2.66	49.44	2.25	17.63	11.50	0.94	81995.68
19	6.43	3.19	46.96	2.74	17.41	11.40	0.95	81991.49
20	4.44	2.95	49.60	1.92	17.60	11.59	0.96	80721.74
21	7.64	3.10	50.93	1.81	18.38	11.12	0.97	84169.38
22	5.28	3.07	47.95	2.07	16.93	11.81	0.94	79951.57
23	5.76	3.20	52.76	2.09	17.25	11.89	0.93	78710.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.90	3.34	51.03	2.22	17.50	11.63	0.95	81000.84
最 大 值	10.80	6.27	63.73	4.19	20.09	12.03	0.97	85122.65
發生時間	9	0	6	9	1	15		1
最 小 值	3.16	2.53	44.55	0.93	15.87	10.94	0.92	78303.92
發生時間	7	11	16	13	15	1		15
零點偏移(率)	-0.05 %	-0.00 %	-0.01 %	0.00 %		-0.09		0.00 %
全幅偏移(率)	0.00 %	0.64 %	-0.21 %	0.48 %		-0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月31日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.98	2.45	59.28	2.52	14.94	11.61	1.76	75594.59
1	4.08	2.33	61.63	1.92	16.36	11.75	1.79	75430.22
2	0.80	2.26	61.38	2.21	15.19	11.70	1.81	73251.97
3	8.34	2.77	57.47	3.10	13.78	11.73	1.82	73508.31
4	6.71	5.14	55.63	3.50	13.79	11.71	1.81	73646.24
5	5.90	3.27	54.95	1.22	14.12	11.72	1.78	71024.72
6	3.52	3.17	59.16	1.01	14.75	11.50	1.77	72892.02
7	12.76	3.35	56.67	3.47	14.85	11.02	1.84	73035.68
8	4.14	1.94	59.35	2.68	15.21	11.37	1.82	72958.10
9	6.29	2.89	51.75	2.87	13.92	11.36	1.84	71547.83
10	6.47	2.12	55.12	2.21	15.31	11.13	1.83	72880.31
11	3.04	2.53	57.16	2.14	15.17	11.30	1.79	73309.99
12	12.93	1.90	58.77	2.31	15.57	11.17	1.81	72370.56
13	1.67	2.39	52.04	1.97	15.41	11.20	1.82	71359.04
14	7.31	2.75	48.96	2.15	15.87	10.92	1.84	73502.11
15	6.10	2.93	49.69	2.40	15.08	10.98	1.82	72297.18
16	5.85	3.02	50.05	2.80	14.59	11.29	1.80	70531.85
17	2.47	3.06	49.34	2.18	15.08	11.31	1.80	70552.62
18	1.09	2.22	54.65	1.54	16.20	11.12	1.83	72374.76
19	3.33	2.67	53.19	1.53	16.19	10.67	1.81	74443.51
20	1.16	3.34	50.87	1.34	16.26	10.64	1.78	75330.43
21	3.85	4.09	47.55	1.72	15.50	10.77	1.78	73029.72
22	1.95	3.96	49.18	1.76	15.00	10.84	1.79	73053.09
23	3.89	3.35	53.02	2.13	15.07	11.08	1.81	74267.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.23	2.91	54.45	2.19	15.13	11.25	1.81	73008.00
最 大 值	12.93	5.14	61.63	3.50	16.36	11.75	1.88	75594.59
發生時間	12	4	1	4	1	1		0
最 小 值	0.80	1.90	47.55	1.01	13.78	10.64	1.76	70531.85
發生時間	2	12	21	6	3	20		16
零點偏移(率)	-0.16 %	-0.01 %	-0.10 %	-0.05 %		-0.09		0.00 %
全幅偏移(率)	-0.60 %	-0.14 %	-0.74 %	0.08 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								